

NEW BEDFORD, MA, USA

WMO: 725065

Lat: 41.676N

Lon: 70.958W

Elev: 24

StdP: 101.03

Time Zone: -5.00 (NAE)

Period: 96-19

WBAN: 94726

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.6	-11.0	-22.7	0.5	-11.0	-20.1	0.6	-8.6	12.0	2.9	11.1	2.7	3.4	290	0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	31.3	23.2	29.5	22.2	28.0	21.3	24.7	28.9	23.8	27.4	23.0	26.1	4.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.3	18.2	26.5	22.7	17.4	25.6	22.2	16.9	25.1	74.8	28.8	71.3	27.5	68.2	26.1	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 10.3	8.9	8.0														
(5)			DB	-17.5	34.3	3.4	2.0	-19.9	35.8	-21.8	37.0	-23.7	38.1	-26.2	39.6	
			WB	-18.1	26.1	3.2	1.0	-20.4	26.8	-22.3	27.4	-24.0	27.9	-26.4	28.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	-1.1	0.0	3.2	8.7	14.0	18.8	22.4	21.6	17.7	11.8	6.4	2.0
	DBStd	9.12	5.50	4.81	4.68	3.94	3.86	3.60	2.97	3.01	3.66	4.21	4.54	4.90
	HDD10.0	1323	343	280	215	71	7	0	0	0	0	29	127	252
	HDD18.3	3193	601	512	468	291	146	38	4	6	54	208	359	506
	CDD10.0	1512	1	1	6	31	129	263	383	360	232	83	18	4
	CDD18.3	339	0	0	0	1	10	51	129	108	36	4	0	0
	CDH23.3	2494	0	0	1	13	99	375	993	800	194	19	0	0
	CDH26.7	666	0	0	0	3	24	95	306	207	28	2	0	0
(14) Wind	WSAvg	3.4	3.8	3.8	4.1	4.0	3.6	3.2	3.1	2.8	2.8	3.2	3.3	3.5
(15) Precipitation	PrecAvg	1224	96	92	126	106	92	90	79	97	108	102	109	123
	PrecMax	1493	168	198	319	205	185	273	204	196	269	276	178	229
	PrecMin	919	47	51	11	39	29	10	20	10	22	6	20	41
	PrecStd	153	32	36	72	44	35	66	44	42	58	60	43	43
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.5	14.2	20.0	25.0	29.4	32.0	33.8	32.7	29.6	26.0	19.2	16.7
		MCWB	13.1	10.8	13.2	16.5	21.0	23.0	24.3	23.9	23.5	19.9	16.0	14.5
	2%	DB	12.2	11.8	15.3	20.2	26.1	29.1	31.7	30.6	27.2	22.5	17.6	14.1
		MCWB	10.7	9.8	9.7	13.0	18.2	21.5	23.4	23.2	20.8	18.7	15.1	12.6
	5%	DB	9.8	9.7	12.5	17.6	23.2	27.4	29.8	28.8	25.8	20.7	16.1	12.4
		MCWB	8.0	7.2	9.0	11.9	16.6	20.6	22.5	22.1	20.3	17.4	13.6	11.0
	10%	DB	7.5	7.5	10.7	15.4	21.0	25.5	28.1	27.5	23.9	19.0	14.2	10.2
		MCWB	5.6	4.8	7.7	10.3	15.5	19.2	21.7	21.4	19.7	16.2	11.8	8.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.5	12.3	14.6	17.7	21.8	24.3	25.8	25.9	24.3	21.6	17.8	15.3
		MCDB	14.3	12.7	18.3	21.6	28.3	29.9	32.0	30.9	27.5	23.7	18.5	16.3
	2%	WB	11.2	10.3	11.8	15.1	19.7	22.9	24.7	24.8	22.9	19.7	16.1	13.1
		MCDB	11.8	11.4	13.4	18.9	24.0	27.6	29.6	28.3	25.1	21.4	17.2	14.1
	5%	WB	8.0	7.8	10.0	13.3	18.1	21.7	23.8	23.9	22.0	18.3	14.3	11.2
		MCDB	9.1	9.1	12.2	16.0	21.7	25.4	27.7	26.9	24.0	20.1	15.7	12.2
	10%	WB	5.6	5.2	7.8	11.6	16.6	20.7	23.0	23.0	21.1	16.8	12.4	8.7
		MCDB	7.3	7.3	9.8	14.1	19.6	23.8	26.3	25.6	23.1	18.6	13.9	9.8
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	9.2	9.4	10.2	10.3	10.0	10.2	10.3	10.6	10.5	9.7	8.8
		MCDBR	11.3	11.3	12.0	13.6	13.6	12.4	11.7	11.4	11.4	11.3	10.5	10.4
	5% WB	MCWBR	10.5	9.3	8.2	7.8	7.1	6.1	5.0	5.2	6.5	7.6	8.8	9.9
		MCDWR	10.8	11.0	10.9	11.1	11.8	10.3	9.5	9.1	8.5	9.6	9.5	10.2
(40) Clear-Sky Solar Irradiance	taub		0.303	0.311	0.335	0.372	0.410	0.460	0.483	0.438	0.373	0.342	0.315	0.303
		taud	2.509	2.491	2.467	2.390	2.320	2.221	2.162	2.280	2.437	2.531	2.566	2.561
	Ebn at Noon		854	902	915	898	867	822	797	825	862	854	835	826
		Edh at Noon	73	86	99	115	126	140	147	127	101	82	69	64
(44) All-Sky Solar Radiation	RadAvg		1.82	2.70	3.71	4.79	5.34	5.79	5.98	5.37	4.37	2.96	2.01	1.53
	RadStd		0.14	0.26	0.27	0.51	0.53	0.56	0.33	0.28	0.31	0.26	0.14	0.15

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (64 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	+97	+47

Nomenclature: See separate page