

YORK, PA, USA

WMO: 725114

Lat: 39.918N

Lon: 76.874W

Elev: 486

StdP: 14.44

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 93778

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.8	11.6	-5.3	4.2	9.4	-0.3	5.5	14.6	23.7	32.9	20.8	30.5	3.7	280	0.436

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	90.5	74.6	88.1	73.3	85.7	72.0	77.1	86.9	75.5	84.0	74.3	82.4	5.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.8	128.2	81.9	72.7	123.6	80.3	71.9	120.0	79.1	40.7	87.2	39.2	84.2	38.0	82.7	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.4	16.9	14.4	DB	-4.3	94.3	5.2	2.9	-8.0	96.4	-11.0	98.1	-14.0	99.8	-17.7	101.9	(4)
(5)			WB	-4.7	79.6	5.1	1.5	-8.4	80.7	-11.4	81.6	-14.3	82.4	-18.1	83.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.6	29.6	31.8	40.5	51.8	61.7	70.2	74.0	72.4	65.6	54.1	43.9	34.7	
	DBStd	17.57	10.61	9.64	9.55	8.76	7.75	6.00	5.09	5.08	6.81	8.15	8.21	9.49	
	HDD50	2308	635	515	323	78	4	0	0	0	0	48	220	485	
	HDD65	5385	1096	930	760	408	160	23	3	5	75	351	634	940	
	CDD50	3271	4	5	28	131	368	605	744	694	468	176	37	11	
	CDD65	869	0	0	0	11	58	178	281	234	93	14	0	0	
	CDH74	8187	0	2	11	177	610	1629	2692	2081	851	130	4	0	
	CDH80	2599	0	0	0	41	156	491	977	672	239	23	0	0	
Wind	WSAvg	4.9	6.0	6.2	6.7	6.3	4.7	4.4	3.5	3.1	3.5	4.5	5.2	5.5	
Precipitation	PrecAvg	43.7	3.1	2.6	3.7	3.4	4.0	3.7	4.1	4.1	4.3	3.7	3.2	3.6	
	PrecMax	61.9	6.6	5.2	7.8	7.6	6.6	9.3	8.1	6.9	12.2	9.6	5.9	6.7	
	PrecMin	30.7	1.1	0.4	0.5	1.2	1.6	0.8	1.6	1.6	0.0	0.2	1.0	0.7	
	PrecStd	7.8	1.4	1.3	1.7	1.7	1.5	1.9	1.6	1.5	2.9	2.4	1.3	1.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.1	67.9	75.1	84.6	88.0	91.3	94.4	93.0	89.9	83.0	72.6	68.6	
		MCWB	56.7	56.9	59.1	64.9	71.4	74.4	75.8	75.2	73.7	69.4	60.1	60.5	
	2%	DB	57.7	59.1	67.8	79.4	84.2	88.2	91.0	89.6	86.1	77.6	67.0	61.4	
		MCWB	51.7	50.3	56.0	62.4	69.5	73.5	75.4	74.2	71.5	66.2	57.6	56.7	
	5%	DB	50.4	52.5	63.0	73.7	81.0	85.4	88.3	86.3	82.2	73.2	63.4	54.5	
		MCWB	45.6	44.6	52.8	59.8	68.0	71.4	73.9	72.8	69.2	63.7	55.4	49.9	
	10%	DB	45.3	46.0	57.4	69.0	77.0	82.4	85.5	83.7	79.2	69.7	59.1	48.9	
		MCWB	40.7	40.4	48.8	57.8	65.4	70.3	72.7	71.6	67.8	61.6	51.7	44.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.7	59.5	61.7	68.8	74.1	77.1	79.3	78.5	76.6	72.4	64.1	61.6
			MCDB	63.3	65.3	70.6	79.0	84.9	87.1	90.1	88.8	85.7	77.5	68.5	66.7
2%		WB	52.6	50.9	58.3	65.1	71.6	75.1	77.4	76.7	73.8	69.4	60.5	56.7	
		MCDB	56.5	58.3	65.6	74.2	80.7	84.7	87.7	85.6	81.4	75.8	64.9	60.9	
5%		WB	46.2	45.3	54.5	62.2	69.5	73.7	75.9	75.1	72.2	66.1	57.0	50.3	
		MCDB	49.6	50.6	61.7	71.9	78.1	82.6	84.8	82.7	78.8	71.7	62.1	53.8	
10%		WB	41.1	41.0	49.7	59.0	67.4	72.2	74.4	73.6	70.4	62.4	53.2	45.1	
		MCDB	44.8	46.2	57.0	67.5	74.9	80.3	82.5	80.8	76.2	67.4	57.7	48.4	
Mean Daily Temperature Range	5% DB	MDBR	17.8	19.3	21.2	23.2	21.5	20.2	20.8	21.0	22.3	21.7	20.7	17.6	
		MCDBR	25.2	27.5	29.5	30.8	26.0	23.5	23.4	23.4	26.2	27.8	27.1	24.0	
		MCWBR	19.9	19.6	18.8	16.7	13.4	10.7	10.0	10.8	13.1	16.2	18.4	18.9	
	5% WB	MCDBR	23.4	24.3	26.5	25.7	23.0	20.3	19.7	19.7	19.8	21.1	21.3	21.3	
		MCWBR	19.8	19.0	18.7	15.4	12.7	10.3	9.6	10.0	11.0	13.5	16.3	18.4	
Clear-Sky Solar Irradiance	taub	0.309	0.323	0.363	0.398	0.432	0.499	0.512	0.503	0.421	0.365	0.325	0.307		
	taud	2.429	2.370	2.337	2.266	2.206	2.056	2.034	2.046	2.246	2.407	2.482	2.475		
	Ebn at Noon	271	283	282	278	270	251	246	245	259	264	264	264		
	Edh at Noon	26	31	36	42	45	53	53	51	39	30	24	23		
All-Sky Solar Radiation	RadAvg	594	875	1166	1508	1688	1872	1874	1648	1347	969	687	511		
	RadStd	50	107	82	134	196	151	101	91	173	108	62	56		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+245	N/A	
(47) Regional (69 neighbors)		+0.74	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+214	+117	

Nomenclature: See separate page