

YORK, PA, USA

WMO: 725114

Lat: 39.918N

Lon: 76.874W

Elev: 148

StdP: 99.56

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 93778

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.0	-11.3	-20.7	0.6	-12.5	-17.9	0.8	-9.7	10.6	0.5	9.3	-0.9	1.7	280	0.436

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	32.5	23.7	31.2	22.9	29.9	22.2	25.0	30.5	24.2	28.9	23.5	28.0	2.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	18.3	27.7	22.6	17.7	26.8	22.2	17.1	26.2	76.8	30.7	73.4	29.0	70.6	28.2	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.7	7.5	6.4	-20.1	34.6	2.9	1.6	-22.2	35.8	-23.9	36.7	-25.5	37.7	-27.6	38.8		
			-20.4	26.5	2.9	0.8	-22.5	27.0	-24.1	27.5	-25.7	28.0	-27.8	28.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	-1.3	-0.1	4.7	11.0	16.5	21.2	23.3	22.4	18.7	12.3	6.6	1.5
	DBStd	9.76	5.89	5.36	5.31	4.86	4.30	3.33	2.83	2.82	3.78	4.53	4.56	5.27
	HDD10.0	1282	353	286	179	43	2	0	0	0	0	27	122	269
	HDD18.3	2992	609	517	422	227	89	13	2	3	42	195	352	522
	CDD10.0	1817	2	3	16	73	204	336	413	386	260	98	21	6
	CDD18.3	483	0	0	0	6	32	99	156	130	52	8	0	0
	CDH23.3	4548	0	1	6	98	339	905	1496	1156	473	72	2	0
	CDH26.7	1444	0	0	0	23	87	273	543	373	133	13	0	0
Wind	WSAvg	2.2	2.7	2.8	3.0	2.8	2.1	2.0	1.5	1.4	1.5	2.0	2.3	2.5
Precipitation	PrecAvg	1109	78	67	95	87	101	95	104	105	110	95	81	92
	PrecMax	1572	167	131	198	192	167	236	207	174	311	244	151	169
	PrecMin	781	27	11	13	30	40	20	40	41	0	6	25	19
	PrecStd	198	35	34	43	43	37	49	40	38	74	61	34	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.8	19.9	24.0	29.2	31.1	32.9	34.6	33.9	32.2	28.3	22.6	20.3
		MCWB	13.7	13.8	15.1	18.3	21.9	23.6	24.3	24.0	23.2	20.8	15.6	15.8
	2%	DB	14.3	15.0	19.9	26.3	29.0	31.2	32.8	32.0	30.1	25.3	19.4	16.3
		MCWB	10.9	10.2	13.3	16.9	20.9	23.1	24.1	23.4	21.9	19.0	14.2	13.7
	5%	DB	10.2	11.4	17.2	23.1	27.2	29.6	31.3	30.1	27.9	22.9	17.4	12.5
		MCWB	7.5	7.0	11.6	15.4	20.0	21.9	23.3	22.7	20.7	17.6	13.0	9.9
	10%	DB	7.4	7.8	14.1	20.6	25.0	28.0	29.7	28.7	26.2	21.0	15.1	9.4
		MCWB	4.8	4.7	9.3	14.3	18.5	21.3	22.6	22.0	19.9	16.5	11.0	6.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.8	15.3	16.5	20.5	23.4	25.0	26.3	25.8	24.8	22.4	17.8	16.5
		MCDB	17.4	18.5	21.5	26.1	29.4	30.6	32.3	31.5	29.8	25.3	20.3	19.3
	2%	WB	11.4	10.5	14.6	18.4	22.0	24.0	25.2	24.8	23.2	20.8	15.8	13.7
		MCDB	13.6	14.6	18.7	23.5	27.1	29.3	30.9	29.8	27.5	24.3	18.3	16.1
	5%	WB	7.9	7.4	12.5	16.8	20.8	23.2	24.4	24.0	22.3	18.9	13.9	10.2
		MCDB	9.8	10.3	16.5	22.2	25.6	28.1	29.3	28.1	26.0	22.0	16.7	12.1
	10%	WB	5.0	5.0	9.8	15.0	19.7	22.3	23.6	23.1	21.3	16.9	11.8	7.3
		MCDB	7.1	7.9	13.9	19.7	23.8	26.8	28.1	27.1	24.5	19.7	14.3	9.1
Mean Daily Temperature Range	5% DB	MDBR	9.9	10.7	11.8	12.9	11.9	11.2	11.5	11.7	12.4	12.1	11.5	9.8
		MCDBR	14.0	15.3	16.4	17.1	14.5	13.1	13.0	13.0	14.6	15.4	15.1	13.3
		MCWBR	11.1	10.9	10.4	9.3	7.4	5.9	5.6	6.0	7.3	9.0	10.2	10.5
	5% WB	MCDBR	13.0	13.5	14.7	14.3	12.8	11.3	10.9	10.9	11.0	11.7	11.8	11.8
		MCWBR	11.0	10.5	10.4	8.6	7.0	5.7	5.3	5.5	6.1	7.5	9.1	10.2
Clear-Sky Solar Irradiance	taub	0.309	0.323	0.363	0.398	0.432	0.499	0.512	0.503	0.421	0.365	0.325	0.307	
	taud	2.429	2.370	2.337	2.266	2.206	2.056	2.034	2.046	2.246	2.407	2.482	2.475	
	Ebn at Noon	855	893	889	876	850	791	776	771	817	833	832	831	
	Edh at Noon	81	99	114	131	142	166	168	162	124	95	77	72	
All-Sky Solar Radiation	RadAvg	1.87	2.76	3.67	4.75	5.32	5.90	5.91	5.20	4.25	3.06	2.17	1.61	
	RadStd	0.16	0.34	0.26	0.42	0.62	0.48	0.32	0.29	0.54	0.34	0.20	0.18	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (69 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+119	+65	

Nomenclature: See separate page