

SULLIVAN COUNTY AP, NY, USA

WMO: 725145

Lat: 41.701N

Lon: 74.795W

Elev: 1403

StdP: 13.97

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 54746

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.0	4.7	-10.8	3.2	1.8	-6.4	4.1	7.8	26.6	17.1	24.4	17.8	8.6	290	0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	86.3	71.0	83.5	69.3	81.2	67.9	73.2	82.0	71.5	79.9	70.1	77.9	8.4	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.4	117.9	77.6	69.5	114.4	76.6	66.8	103.7	74.3	37.7	81.6	36.2	80.8	35.0	77.3	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.4	19.4	17.3	-7.8	90.6	5.8	2.5	-12.0	92.4	-15.4	93.9	-18.6	95.3	-22.8	97.1		
(5)			-7.1	75.6	6.3	1.8	-11.6	76.9	-15.3	77.9	-18.8	78.9	-23.4	80.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.9	22.8	25.3	33.8	45.5	56.1	64.4	69.1	67.7	60.3	49.4	37.8	28.8	(6)	
	DBStd	18.13	10.87	10.05	9.86	8.91	7.79	6.41	5.21	5.16	6.98	8.16	8.69	8.83	(7)	
	HDD50	3411	842	691	510	189	25	0	0	4	115	377	658		(8)	
	HDD65	7009	1307	1110	967	588	296	87	20	32	175	488	817	1122	(9)	
	CDD50	2270	1	1	9	53	214	434	592	548	313	94	10	1	(10)	
	CDD65	393	0	0	0	3	20	70	147	115	35	3	0	0	(11)	
	CDH74	3181	0	0	5	54	259	588	1184	828	241	22	0	0	(12)	
	CDH80	751	0	0	1	12	58	135	316	182	46	1	0	0	(13)	
(14) Wind	WSAvg	7.0	8.0	8.4	8.7	8.3	7.0	6.0	5.5	5.0	5.6	6.7	7.4	7.9	(14)	
(15) Precipitation	PrecAvg	49.1	3.7	2.8	3.9	3.8	3.8	4.7	4.4	4.6	4.7	4.6	3.7	4.3	(15)	
	PrecMax	62.5	7.1	7.8	6.9	6.9	6.7	11.9	8.1	8.8	10.4	13.6	5.5	7.6	(16)	
	PrecMin	33.9	1.3	1.5	0.9	1.2	1.1	1.5	1.3	1.6	1.7	0.8	1.0	1.8	(17)	
	PrecStd	7.2	1.6	1.3	1.4	1.5	1.7	2.6	2.0	2.0	2.5	2.8	1.2	1.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.1	56.8	69.9	81.4	85.7	88.3	90.2	89.8	84.5	77.1	65.8	57.3	(19)	
		MCWB	53.1	47.8	57.0	61.0	69.5	71.4	72.9	71.9	70.9	63.1	56.7	52.5	(20)	
	2%	DB	48.3	49.7	61.2	72.8	81.1	83.7	87.5	84.2	80.9	72.0	60.8	51.9	(21)	
		MCWB	45.8	42.3	49.7	56.4	65.4	69.2	71.7	70.4	68.0	60.8	54.1	48.5	(22)	
	5%	DB	42.8	44.7	54.7	66.1	75.4	80.9	83.4	81.5	76.5	66.8	55.3	46.0	(23)	
		MCWB	39.1	38.4	46.3	53.2	61.7	68.1	69.6	68.5	66.2	59.7	49.6	43.0	(24)	
	10%	DB	37.0	38.9	48.3	61.4	71.7	77.2	81.0	79.1	72.6	63.5	52.1	42.4	(25)	
		MCWB	34.3	34.4	42.1	49.9	59.2	65.5	68.2	67.2	63.9	56.3	47.3	38.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.4	52.4	57.5	63.7	71.3	73.9	75.5	75.2	73.5	67.5	59.8	54.3	(27)	
		MCDB	56.0	54.8	67.1	76.6	81.5	83.7	85.9	83.8	81.4	71.2	63.4	56.7	(28)	
	2%	WB	46.4	43.8	52.3	59.2	67.6	71.5	73.3	72.6	70.4	64.0	55.6	48.3	(29)	
		MCDB	47.7	48.7	58.9	68.6	77.5	80.1	82.7	80.6	76.6	68.6	59.6	50.4	(30)	
	5%	WB	39.2	38.6	47.3	55.5	64.4	69.7	71.4	70.7	68.0	60.6	51.7	43.9	(31)	
		MCDB	42.2	42.6	53.6	64.7	72.3	77.7	80.3	78.6	73.9	66.0	55.2	46.1	(32)	
	10%	WB	35.1	35.1	42.6	51.6	61.5	67.7	69.9	69.0	66.0	57.1	46.8	38.4	(33)	
		MCDB	37.1	39.2	48.7	59.6	68.4	75.0	77.9	76.2	71.1	62.9	50.5	41.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	14.7	15.9	17.4	20.2	20.8	20.0	20.3	19.7	19.4	18.3	15.6	13.0	(35)	
		MCDBR	19.4	22.0	26.5	29.3	27.7	24.3	23.3	22.2	23.4	24.4	21.8	18.0	(36)	
	5% WB	MCWBR	17.6	16.7	17.3	16.1	14.7	12.8	10.6	10.9	12.7	15.0	16.1	16.0	(37)	
		MCWBR	18.5	20.0	24.5	25.9	24.6	21.6	20.1	19.3	19.3	20.5	18.9	16.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.287	0.310	0.332	0.346	0.384	0.438	0.445	0.429	0.362	0.343	0.305	0.288	(40)	
		taud	2.409	2.350	2.395	2.419	2.338	2.210	2.202	2.239	2.405	2.470	2.531	2.497	(41)	
	Ebn at Noon		275	284	291	293	283	266	263	264	277	269	268	266	(42)	
		Edh at Noon	25	31	34	35	39	45	45	42	33	28	22	21	(43)	
(44) All-Sky Solar Radiation	RadAvg		530	809	1133	1433	1623	1747	1821	1592	1315	869	592	428	(44)	
	RadStd		39	90	94	156	164	166	111	99	148	99	63	48	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (61 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+194	+104

Nomenclature: See separate page