

OSWEGO COUNTY AP, NY, USA

WMO: 725146

Lat: 43.350N

Lon: 76.385W

Elev: 475

StdP: 14.45

Time Zone: -5.00 (NAE)

Period: 99-19

WBAN: 54773

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.1	(c) 3.7	(d) -8.6	(e) 3.5	(f) 0.5	(g) -3.9	(h) 4.5	(i) 6.0	(j) 27.5	(k) 29.6	(l) 24.7	(m) 26.8	(n) 5.2	(o) 120	(p) 0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	87.9	72.9	84.6	71.1	82.1	69.9	75.0	84.3	73.3	81.6	71.7	79.4	8.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.2	121.2	80.1	70.4	114.0	78.3	69.2	109.4	77.2	38.7	84.7	37.2	81.9	35.8	79.4	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.9	19.4	17.1	-8.8	92.4	6.0	3.2	-13.1	94.7	-16.7	96.6	-20.0	98.4	-24.4	100.7
			-9.3	78.0	5.9	1.7	-13.6	79.2	-17.1	80.2	-20.4	81.2	-24.7	82.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.8	23.6	25.2	32.9	45.3	57.4	65.2	70.3	69.0	62.4	50.9	40.3	29.9		
	DBStd	18.61	11.85	10.15	10.34	9.02	8.45	6.66	5.44	5.39	7.20	8.21	8.66	9.35		
	HDD50	3299	818	695	539	195	26	0	0	0	2	90	308	626		
	HDD65	6771	1282	1115	995	594	266	78	15	22	133	442	740	1089		
	CDD50	2506	1	0	9	55	254	458	629	589	374	118	18	1		
	CDD65	503	0	0	0	4	29	86	178	146	55	5	0	0		
	CDH74	4082	0	0	2	54	300	759	1484	1033	419	31	0	0		
	CDH80	1078	0	0	0	9	64	216	425	258	103	3	0	0		
	WSAvg	6.9	8.4	8.6	8.5	8.2	6.4	5.7	5.2	4.8	5.0	6.5	7.6	8.2		
	PrecAvg	44.4	3.8	3.2	3.3	3.6	3.6	3.5	3.4	3.5	3.8	4.3	4.1	4.2		
(15) Precipitation	PrecMax	54.3	7.2	6.1	5.6	7.0	6.5	7.2	8.8	6.6	5.9	8.0	6.5	6.2		
	PrecMin	36.2	2.4	1.5	1.6	1.2	1.3	1.4	0.9	1.1	2.2	0.9	2.0	2.2		
	PrecStd	4.5	1.2	1.1	1.1	1.5	1.6	1.5	1.9	1.3	1.0	1.7	1.1	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.9	57.2	68.9	81.0	85.8	90.2	91.0	90.4	88.1	78.5	67.1	58.4		
		MCWB	52.8	47.7	57.0	64.3	69.9	73.3	74.6	73.4	73.3	66.4	57.1	52.7		
	2%	DB	49.1	48.6	59.5	72.7	81.3	85.9	87.8	85.8	82.8	72.5	62.7	51.4		
		MCWB	44.4	42.8	51.8	57.2	66.9	71.1	73.3	72.0	70.6	62.9	54.6	46.6		
	5%	DB	43.3	43.6	54.0	66.1	77.2	81.9	84.5	82.4	79.1	68.4	58.4	46.2		
		MCWB	39.8	38.8	46.3	53.4	63.9	69.3	71.6	70.5	68.4	61.1	51.4	42.8		
	10%	DB	38.5	38.9	47.6	61.0	72.6	78.5	81.7	79.9	74.8	63.9	54.0	42.5		
		MCWB	35.3	34.9	41.7	51.7	61.6	67.1	70.4	69.0	66.2	57.7	48.6	38.9		
	0.4%	WB	53.0	51.0	58.2	64.9	72.5	75.5	77.8	76.2	75.2	68.6	59.2	53.1		
		MCDB	58.0	54.1	65.1	77.3	82.4	86.5	87.5	84.9	84.7	74.8	64.9	57.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	45.0	43.6	51.9	59.6	69.1	73.2	75.4	74.1	72.2	65.0	56.1	46.9		
		MCDB	48.6	48.4	57.5	69.2	78.1	82.6	84.7	82.3	80.5	70.4	61.6	49.7		
	5%	WB	40.1	39.1	46.5	56.1	66.4	71.1	73.6	72.4	69.7	61.8	52.3	43.2		
		MCDB	43.4	43.2	52.8	64.3	74.4	79.2	81.5	79.8	76.4	67.4	57.0	46.7		
	10%	WB	35.8	35.2	42.2	52.0	63.5	68.9	71.8	70.7	67.5	58.5	48.9	39.0		
		MCDB	38.4	38.6	47.5	59.3	70.4	76.0	79.2	77.3	73.8	63.8	53.6	42.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.7	14.2	15.3	18.4	20.5	19.5	19.4	18.7	19.3	15.8	14.1	11.7		
		MCDBR	17.5	19.1	23.8	29.3	26.0	24.5	22.5	22.0	23.0	21.9	21.4	16.3		
		MCWBR	14.7	15.2	16.3	16.8	14.3	12.7	11.2	10.8	12.5	13.8	15.2	14.0		
		MCDBR	17.3	18.3	21.8	25.5	22.8	20.8	19.0	18.3	20.2	19.0	18.5	15.6		
	5% WB	MCWBR	15.2	15.2	15.9	16.7	13.9	12.2	11.0	9.9	11.7	13.2	14.7	14.1		
(40) Clear-Sky Solar Irradiance	taub		0.294	0.304	0.325	0.359	0.386	0.426	0.431	0.419	0.372	0.351	0.311	0.286		
	taud		2.405	2.375	2.412	2.382	2.354	2.272	2.264	2.285	2.400	2.451	2.515	2.494		
	Ebn at Noon		267	283	291	288	281	269	266	266	271	263	260	261		
	Edh at Noon		24	30	32	36	38	42	42	40	33	28	22	20		
(44) All-Sky Solar Radiation	RadAvg		393	646	1041	1409	1731	1834	1870	1662	1314	780	482	303		
	RadStd		43	67	88	158	167	153	154	85	115	76	63	45		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+239	N/A
(47) Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+130	N/A

Nomenclature: See separate page