

OSWEGO COUNTY AP, NY, USA

WMO: 725146

Lat: 43.350N

Lon: 76.385W

Elev: 145

StdP: 99.60

Time Zone: -5.00 (NAE)

Period: 99-19

WBAN: 54773

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.4	-15.7	-22.6	0.5	-17.5	-20.0	0.6	-14.5	12.3	-1.3	11.1	-2.9	2.3	120	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	31.0	22.7	29.2	21.7	27.8	21.1	23.9	29.0	23.0	27.5	22.1	26.3	3.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.3	17.3	26.7	21.4	16.3	25.7	20.7	15.6	25.1	72.1	29.3	68.7	27.7	65.4	26.3	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	8.7	7.6	DB	-22.7	33.6	3.4	1.8	-25.1	34.8	-27.0	35.9	-28.9	36.9	-31.3	38.2	(4)
(5)			WB	-23.0	25.5	3.3	1.0	-25.3	26.2	-27.3	26.8	-29.1	27.3	-31.5	28.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	-4.6	-3.8	0.5	7.4	14.1	18.5	21.3	20.6	16.9	10.5	4.6	-1.2	(6)	
	DBStd	10.34	6.58	5.64	5.74	5.01	4.70	3.70	3.02	2.99	4.00	4.56	4.81	5.20	(7)	
	HDD10.0	1833	454	386	299	108	14	0	0	0	1	50	171	348	(8)	
	HDD18.3	3762	712	619	553	330	148	43	8	12	74	246	411	605	(9)	
	CDD10.0	1392	1	0	5	31	141	254	349	327	208	66	10	1	(10)	
	CDD18.3	279	0	0	0	2	16	48	99	81	31	3	0	0	(11)	
	CDH23.3	2268	0	0	1	30	167	422	824	574	233	17	0	0	(12)	
	CDH26.7	599	0	0	0	5	36	120	236	143	57	2	0	0	(13)	
(14) Wind	WSAvg	3.1	3.8	3.9	3.8	3.7	2.9	2.5	2.3	2.1	2.2	2.9	3.4	3.7	(14)	
(15) Precipitation	PrecAvg	1129	97	82	84	91	92	90	86	89	96	109	105	106	(15)	
	PrecMax	1380	183	156	142	179	166	182	224	168	149	202	165	157	(16)	
	PrecMin	919	61	38	40	31	33	35	22	28	55	24	52	56	(17)	
	PrecStd	114	31	29	28	39	41	38	47	34	25	42	29	27	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.4	14.0	20.5	27.2	29.9	32.3	32.8	32.4	31.1	25.8	19.5	14.7	(19)	
		MCWB	11.6	8.7	13.9	17.9	21.1	22.9	23.7	23.0	22.9	19.1	14.0	11.5	(20)	
	2%	DB	9.5	9.2	15.3	22.6	27.4	29.9	31.0	29.9	28.2	22.5	17.1	10.8	(21)	
		MCWB	6.9	6.0	11.0	14.0	19.4	21.7	22.9	22.2	21.5	17.2	12.6	8.1	(22)	
	5%	DB	6.3	6.5	12.2	18.9	25.1	27.7	29.1	28.0	26.1	20.2	14.6	7.9	(23)	
		MCWB	4.3	3.8	7.9	11.9	17.7	20.7	22.0	21.4	20.2	16.1	10.8	6.0	(24)	
	10%	DB	3.6	3.8	8.7	16.1	22.6	25.8	27.6	26.6	23.8	17.7	12.2	5.8	(25)	
		MCWB	1.8	1.6	5.4	10.9	16.4	19.5	21.3	20.6	19.0	14.3	9.2	3.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	10.6	14.5	18.3	22.5	24.2	25.4	24.6	24.0	20.3	15.1	11.7	(27)	
		MCDB	14.4	12.3	18.4	25.2	28.0	30.3	30.8	29.4	29.3	23.8	18.3	13.9	(28)	
	2%	WB	7.2	6.5	11.0	15.3	20.6	22.9	24.1	23.4	22.4	18.3	13.4	8.3	(29)	
		MCDB	9.2	9.1	14.2	20.7	25.6	28.1	29.3	27.9	27.0	21.3	16.5	9.8	(30)	
	5%	WB	4.5	4.0	8.0	13.4	19.1	21.7	23.1	22.5	21.0	16.5	11.3	6.2	(31)	
		MCDB	6.4	6.2	11.6	18.0	23.6	26.2	27.5	26.5	24.7	19.7	13.9	8.2	(32)	
	10%	WB	2.1	1.8	5.7	11.1	17.5	20.5	22.1	21.5	19.7	14.7	9.4	3.9	(33)	
		MCDB	3.6	3.6	8.6	15.2	21.4	24.5	26.2	25.2	23.2	17.7	12.0	5.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.6	7.9	8.5	10.2	11.4	10.8	10.8	10.4	10.7	8.8	7.8	6.5	(35)	
		MCDBR	9.7	10.6	13.2	16.3	14.4	13.6	12.5	12.2	12.8	12.1	11.9	9.1	(36)	
	5% WB	MCWBR	8.2	8.4	9.0	9.3	7.9	7.1	6.2	6.0	6.9	7.7	8.4	7.8	(37)	
		MCWBR	9.6	10.1	12.1	14.2	12.6	11.6	10.5	10.2	11.2	10.5	10.3	8.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.294	0.304	0.325	0.359	0.386	0.426	0.431	0.419	0.372	0.351	0.311	0.286	(40)	
		taud	2.405	2.375	2.412	2.382	2.354	2.272	2.264	2.285	2.400	2.451	2.515	2.494	(41)	
	Ebn at Noon		841	893	917	907	886	848	839	837	854	829	819	822	(42)	
		Edh at Noon	76	93	102	114	121	132	132	125	103	87	69	64	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.24	2.04	3.28	4.44	5.46	5.78	5.89	5.24	4.14	2.46	1.52	0.95	(44)	
	RadStd		0.14	0.21	0.28	0.50	0.53	0.48	0.49	0.27	0.36	0.24	0.20	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+133	N/A
(47) Regional (27 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+72	N/A

Nomenclature: See separate page