

GRIFFISS INTL, NY, USA

WMO: 725196

Lat: 43.234N

Lon: 75.412W

Elev: 519

StdP: 14.42

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 64775

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.2	-0.7	-12.9	2.8	-6.2	-7.5	3.7	0.9	26.9	24.4	24.6	23.9	3.6	320	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.5	87.8	72.3	85.2	70.8	82.6	69.3	75.1	83.9	73.3	81.4	71.7	79.2	8.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.4	122.2	79.2	70.7	115.5	77.6	69.2	109.3	76.2	38.8	83.6	37.2	81.6	35.8	79.1	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.4	19.1	17.0	DB	-16.6	92.7	5.5	3.1	-20.5	95.0	-23.7	96.8	-26.8	98.5	-30.8	100.7	(4)
(5)			WB	-16.9	77.8	5.4	2.0	-20.8	79.2	-24.0	80.4	-27.0	81.5	-31.0	83.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.2	20.6	23.2	31.8	45.4	57.8	65.7	70.8	68.7	62.4	50.9	38.6	28.6		
	DBStd	19.59	12.39	11.52	10.69	9.32	8.56	6.42	5.15	5.13	7.43	8.14	8.66	9.89		
	HDD50	3570	913	751	574	199	23	0	0	0	2	88	356	664		
	HDD65	7026	1377	1170	1029	593	255	68	10	23	139	442	792	1128		
	CDD50	2536	0	1	10	59	265	471	645	581	374	116	13	1		
	CDD65	521	0	0	0	3	33	89	190	140	61	5	0	0		
	CDH74	4354	0	0	6	74	384	808	1596	990	463	33	0	0		
	CDH80	1162	0	0	0	14	94	227	473	228	123	3	0	0		
	WSAvg	6.8	7.8	8.0	8.2	8.5	6.7	6.2	5.2	5.2	5.2	6.3	6.8	7.6		
	PrecAvg	44.1	3.3	2.8	3.5	3.5	4.0	4.2	3.9	3.8	4.4	3.4	4.1	4.1		
(15) Precipitation	PrecMax	61.6	6.8	8.8	6.1	6.9	8.4	10.5	8.7	7.6	11.1	7.5	7.5	8.3		
	PrecMin	35.9	1.3	0.6	1.3	1.4	0.7	0.6	1.2	1.3	0.7	0.2	1.3	1.9		
	PrecStd	6.8	1.5	1.5	1.1	1.4	2.0	2.1	2.1	1.5	2.0	1.4	1.5	1.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.4	59.5	71.6	81.5	86.8	90.4	92.2	88.6	88.2	78.7	66.4	56.1		
		MCWB	50.4	52.5	56.1	61.7	68.9	74.5	75.8	73.7	72.9	67.0	55.9	52.1		
	2%	DB	45.5	48.6	59.1	74.9	82.6	86.0	88.3	85.2	83.3	71.7	60.8	49.9		
		MCWB	41.8	42.6	49.2	58.6	66.7	70.7	72.9	71.6	71.0	63.0	53.3	45.7		
	5%	DB	40.6	42.3	52.5	68.2	78.6	82.2	85.2	82.4	79.7	68.0	56.4	45.9		
		MCWB	37.7	38.7	45.1	55.2	64.3	68.0	71.5	69.8	69.2	61.2	50.2	43.3		
	10%	DB	36.8	37.8	47.0	62.2	73.8	78.7	82.4	79.8	75.2	64.1	52.3	41.4		
		MCWB	34.4	34.7	41.3	51.6	61.6	66.2	69.9	68.6	66.5	58.4	47.4	38.9		
	0.4%	WB	50.8	54.4	59.3	64.9	72.0	76.3	77.7	75.9	75.4	69.9	58.4	52.7		
		MCDB	53.8	59.2	68.1	77.2	82.4	88.1	88.0	83.9	82.9	73.1	63.3	55.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	42.9	43.7	51.6	60.8	69.2	73.1	75.6	73.8	72.7	65.5	54.6	46.8		
		MCDB	44.7	48.4	59.0	70.4	79.2	82.5	84.3	81.5	80.9	69.6	59.5	49.2		
	5%	WB	37.9	39.0	46.0	57.1	66.6	70.7	73.8	72.2	70.5	62.3	51.2	43.2		
		MCDB	40.0	42.0	51.4	66.5	74.9	78.1	81.6	79.3	77.5	66.8	55.3	45.7		
	10%	WB	34.8	35.0	41.6	52.8	63.9	68.6	71.9	70.5	68.2	59.0	47.7	39.4		
		MCDB	36.7	37.5	47.2	60.6	71.6	75.6	79.3	76.9	73.9	63.6	51.7	41.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.6	17.1	17.4	21.2	22.8	20.7	20.5	20.0	20.5	17.4	15.8	12.9		
		MCDBR	17.3	21.9	25.3	31.2	28.3	26.0	23.2	22.8	23.9	22.9	22.4	16.5		
		MCWBR	15.0	17.4	16.5	17.3	14.8	12.8	10.6	10.9	12.6	14.3	15.6	14.7		
		MCDBR	16.0	20.3	21.8	28.4	23.8	21.3	19.2	19.0	21.2	18.6	19.3	15.7		
	5% WB	MCWBR	14.4	16.9	15.7	16.7	13.7	11.7	9.8	10.1	12.0	13.1	14.8	14.7		
(40) Clear-Sky Solar Irradiance	taub		0.301	0.309	0.350	0.370	0.400	0.440	0.454	0.436	0.379	0.358	0.317	0.296		
	taud		2.304	2.288	2.301	2.343	2.302	2.213	2.182	2.221	2.367	2.428	2.487	2.406		
	Ebn at Noon		261	280	282	284	277	265	259	260	269	260	257	254		
	Edh at Noon		27	32	36	38	41	44	45	42	34	28	23	22		
(44) All-Sky Solar Radiation	RadAvg		439	710	1098	1379	1646	1756	1804	1608	1290	777	499	332		
	RadStd		51	88	97	170	174	154	161	87	124	86	59	45		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+140	N/A

Nomenclature: See separate page