

ONEIDA COUNTY AP, NY, USA

WMO: 725197

Lat: 43.145N

Lon: 75.384W

Elev: 217

StdP: 98.75

Time Zone: -5.00 (NAE)

Period: 94-06

WBAN: 94794

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.9	-17.3	-25.3	0.4	-19.6	-22.3	0.5	-16.7	11.7	-4.7	10.8	-5.3	2.9	280	0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	30.9	22.7	29.1	21.6	27.8	20.8	24.0	28.6	23.0	27.2	22.1	26.1	3.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.7	17.9	26.1	21.7	16.8	25.5	20.9	16.0	24.5	73.2	28.6	69.3	27.4	65.9	26.1	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.4	7.6	DB	-24.5	33.2	3.9	1.4	-27.3	34.2	-29.6	35.0	-31.7	35.8	-34.5	36.9	(4)
(5)			WB	-24.8	26.1	3.8	1.5	-27.5	27.2	-29.7	28.0	-31.9	28.9	-34.6	30.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.5	-5.7	-4.0	0.3	7.2	13.5	19.2	21.2	20.6	16.4	9.8	4.2	-1.8	(6)	
	DBStd	10.60	7.33	5.96	5.82	4.95	4.30	3.92	2.91	2.99	3.81	4.46	5.08	5.44	(7)	
	HDD10.0	1926	487	392	307	111	14	0	0	0	2	61	186	367	(8)	
	HDD18.3	3879	746	625	561	336	159	38	7	13	82	264	425	624	(9)	
	CDD10.0	1366	1	0	4	27	124	276	347	328	193	55	11	1	(10)	
	CDD18.3	277	0	0	1	2	11	63	95	83	22	1	0	0	(11)	
	CDH23.3	2159	0	0	6	25	121	522	749	585	143	9	0	0	(12)	
	CDH26.7	563	0	0	1	5	26	151	202	147	31	0	0	0	(13)	
(14) Wind	WSAvg	3.7	4.4	4.4	4.3	4.2	3.8	3.2	3.1	2.8	3.1	3.6	4.0	4.1	(14)	
(15) Precipitation	PrecAvg	1121	85	71	89	90	101	106	100	97	113	86	104	103	(15)	
	PrecMax	1565	173	224	154	175	214	267	220	194	282	191	190	211	(16)	
	PrecMin	911	34	16	34	35	18	14	30	34	19	4	34	47	(17)	
	PrecStd	172	37	37	29	36	52	53	54	38	52	35	37	45	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.7	12.6	22.7	27.2	29.2	32.1	32.3	32.4	30.0	24.8	20.0	16.3	(19)	
		MCWB	12.0	7.8	14.5	15.7	19.7	23.6	24.3	23.0	20.3	17.8	14.7	11.7	(20)	
	2%	DB	9.0	8.7	15.9	21.6	26.9	30.2	30.5	30.1	27.1	22.1	17.4	11.0	(21)	
		MCWB	7.0	5.3	10.6	13.1	18.2	22.1	23.4	21.9	20.3	15.9	12.5	8.0	(22)	
	5%	DB	6.1	6.3	12.1	18.8	24.0	28.4	28.9	28.0	24.7	19.3	14.8	7.9	(23)	
		MCWB	4.4	3.5	7.6	11.8	16.3	21.2	22.1	21.2	19.1	14.6	11.3	5.6	(24)	
	10%	DB	3.5	4.0	8.7	15.9	21.3	26.5	27.5	26.6	22.8	17.0	11.7	5.0	(25)	
		MCWB	2.1	1.8	5.6	9.9	15.0	20.3	20.9	20.5	18.1	13.1	9.3	3.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	8.5	15.3	17.4	21.6	24.9	26.4	24.9	22.8	19.0	15.6	12.5	(27)	
		MCDB	13.6	10.4	22.4	24.8	27.7	30.0	29.7	29.6	26.6	22.3	18.5	15.0	(28)	
	2%	WB	7.3	5.5	11.4	14.9	19.3	23.6	24.4	23.3	21.3	16.7	13.9	8.8	(29)	
		MCDB	8.3	7.9	15.4	19.8	24.3	28.4	28.5	27.4	24.9	20.7	16.4	10.5	(30)	
	5%	WB	4.5	3.8	8.1	12.7	17.9	22.4	23.3	22.4	20.2	15.1	11.6	5.8	(31)	
		MCDB	5.9	6.2	11.5	17.1	22.0	26.7	27.4	26.2	23.4	18.7	13.6	7.8	(32)	
	10%	WB	2.3	2.1	5.5	10.6	16.4	21.1	22.2	21.6	19.0	13.7	9.3	3.3	(33)	
		MCDB	3.5	3.9	8.5	14.8	20.4	24.9	26.1	25.1	22.1	16.5	12.0	4.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	8.5	8.7	10.5	11.0	10.8	10.5	10.8	10.4	9.3	7.5	6.8	(35)	
		MCDBR	9.7	10.1	13.8	16.2	15.2	13.1	11.9	12.3	12.5	13.2	11.7	9.9	(36)	
	5% WB	MCWBR	8.4	7.8	9.1	9.8	8.0	6.4	6.0	5.8	6.6	8.1	8.1	7.9	(37)	
		MCWBR	9.6	9.1	12.9	13.6	12.7	11.3	10.5	10.3	10.4	11.4	9.9	9.4	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.299	0.307	0.346	0.365	0.396	0.437	0.451	0.432	0.375	0.355	0.314	0.294	(40)	
		taud	2.312	2.296	2.313	2.354	2.309	2.217	2.188	2.227	2.373	2.431	2.492	2.414	(41)	
	Ebn at Noon	Ebn at Noon	827	886	892	901	878	839	822	825	852	825	815	806	(42)	
		Edh at Noon	84	101	113	118	127	140	142	133	106	89	71	70	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.40	2.26	3.48	4.35	5.18	5.53	5.69	5.07	4.07	2.46	1.59	1.06	(44)	
	RadStd	RadStd	0.16	0.28	0.31	0.53	0.55	0.49	0.50	0.27	0.39	0.27	0.19	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+85	N/A

Nomenclature: See separate page