

GLENN FALLS BENNETT, NY, USA

WMO: 725220

Lat: 43.338N

Lon: 73.610W

Elev: 321

StdP: 14.53

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14750

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.1	-2.1	-17.1	2.2	-7.0	-11.1	3.1	-0.3	19.6	26.2	18.0	25.2	1.6	50	0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	87.8	72.6	84.6	70.6	82.2	69.2	75.2	83.3	73.5	80.9	71.9	78.8	9.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.6	122.4	79.5	71.3	117.0	77.8	69.8	110.8	76.0	38.8	83.7	37.3	81.3	35.8	78.4	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
18.1	16.0	13.5	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-18.8	92.5	7.7	2.5	-24.3	94.3	-28.8	95.8	-33.2	97.1	-38.7	98.9		
			-19.1	79.1	7.6	2.1	-24.6	80.6	-29.0	81.8	-33.3	82.9	-38.8	84.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	46.4	20.0	22.9	32.3	45.3	57.1	65.5	70.2	68.2	60.5	48.7	37.7	27.3	(6)
(7)		DBStd	19.35	12.67	11.14	10.02	8.34	7.57	6.28	5.11	5.27	7.21	7.70	8.58	9.87	(7)
(8)		HDD50	3658	930	759	556	186	19	0	0	0	5	120	378	705	(8)
(9)		HDD65	7222	1394	1179	1015	592	267	69	11	28	172	507	819	1169	(9)
(10)		CDD50	2358	1	0	6	46	238	466	626	565	321	79	9	1	(10)
(11)		CDD65	446	0	0	0	2	21	85	172	127	38	1	0	0	(11)
(12)		CDH74	4082	0	0	9	58	290	834	1545	1018	312	16	0	0	(12)
(13)		CDH80	1083	0	0	2	15	71	230	457	239	68	1	0	0	(13)
(14)	Wind	WSAvg	5.3	5.3	5.6	6.4	6.7	5.8	5.1	4.7	4.2	4.4	4.9	5.2	5.0	(14)
(15)	Precipitation	PrecAvg	35.9	2.6	2.0	3.0	2.9	3.6	3.2	3.2	3.5	3.3	2.8	3.1	2.8	(15)
(16)		PrecMax	54.4	7.5	4.8	6.4	6.5	7.8	8.2	6.9	8.1	7.8	6.8	6.5	7.6	(16)
(17)		PrecMin	21.8	0.4	0.2	0.4	0.6	0.7	0.5	0.8	1.0	0.1	0.0	1.2	1.0	(17)
(18)		PrecStd	6.8	1.7	1.0	1.3	1.3	1.9	1.9	1.5	1.6	2.0	1.5	1.3	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.3	53.5	69.1	81.3	86.1	90.5	91.8	89.5	86.3	76.4	66.4	55.6	(19)
(20)		0.4%	MCWB	52.5	45.0	56.2	61.5	67.4	73.3	75.6	74.4	71.6	64.9	58.9	50.8	(20)
(21)		2%	DB	45.0	46.1	58.5	72.9	81.5	85.9	88.1	85.2	81.5	70.7	60.8	49.5	(21)
(22)		2%	MCWB	40.9	40.1	48.7	56.9	64.6	70.5	73.6	71.6	69.3	62.1	54.8	45.7	(22)
(23)		5%	DB	39.9	42.1	52.0	66.3	76.6	82.1	84.9	82.4	77.4	66.2	56.0	44.7	(23)
(24)		5%	MCWB	36.7	36.9	43.7	53.0	62.3	68.8	71.6	70.4	67.6	58.8	50.5	41.2	(24)
(25)		10%	DB	36.6	38.2	46.6	61.3	72.4	79.1	82.0	80.0	73.6	62.3	51.9	40.6	(25)
(26)		10%	MCWB	33.7	34.1	40.6	49.9	60.1	66.5	69.7	68.7	64.9	55.9	46.9	37.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.7	46.7	57.9	64.4	71.1	76.1	78.0	76.6	74.4	68.2	60.7	51.9	(27)
(28)		0.4%	MCDWB	53.5	51.3	65.6	75.9	81.8	86.3	88.0	85.2	81.5	72.3	64.4	54.2	(28)
(29)		2%	WB	41.8	40.9	50.3	59.5	68.1	73.4	75.7	74.5	71.6	64.0	56.1	46.2	(29)
(30)		2%	MCDWB	44.3	45.2	56.8	69.0	76.5	82.5	84.2	81.4	77.9	68.7	59.8	48.6	(30)
(31)		5%	WB	37.3	37.5	44.9	55.1	65.3	71.3	73.8	72.7	69.4	60.0	51.5	41.6	(31)
(32)		5%	MCDWB	39.8	41.4	50.5	64.6	72.9	78.8	81.4	79.0	75.1	65.0	54.7	44.6	(32)
(33)		10%	WB	34.2	34.7	41.1	51.1	62.4	69.0	72.1	71.1	67.0	56.9	47.3	37.4	(33)
(34)		10%	MCDWB	36.3	37.8	46.7	59.4	69.7	75.4	79.1	77.1	72.2	61.0	50.9	40.0	(34)
(35)	Mean Daily Temperature Range	MDBR	18.0	20.4	19.6	22.0	22.8	21.8	21.7	21.6	22.3	20.5	17.3	15.4	(35)	
(36)		5% DB	MCDBR	17.5	21.7	27.6	32.8	30.1	26.3	24.8	23.8	25.5	26.7	23.9	18.3	(36)
(37)		5% DB	MCWBR	15.4	16.5	18.3	18.6	15.8	13.3	12.0	12.0	14.4	17.5	18.4	15.8	(37)
(38)		5% WB	MCDBR	16.6	20.0	24.7	28.8	24.6	22.5	21.4	20.0	21.4	23.1	20.5	17.8	(38)
(39)		5% WB	MCWBR	15.2	15.9	18.0	18.4	14.5	12.5	11.5	11.4	13.2	17.2	17.6	16.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.300	0.317	0.338	0.354	0.391	0.438	0.454	0.427	0.374	0.349	0.313	0.296	(40)	
(41)		taud	2.342	2.285	2.353	2.403	2.340	2.228	2.192	2.258	2.391	2.465	2.511	2.435	(41)	
(42)		Ebn at Noon	262	277	286	289	280	266	259	263	270	264	259	254	(42)	
(43)		Edh at Noon	26	32	35	36	39	44	45	41	33	27	22	22	(43)	
(44)	All-Sky Solar Radiation	RadAvg	482	756	1107	1414	1615	1749	1797	1616	1308	803	540	377	(44)	
(45)		RadStd	47	67	91	161	178	146	138	85	107	88	57	42	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+126	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+157	N/A

Nomenclature: See separate page