

GLENN FALLS BENNETT, NY, USA

WMO: 725220

Lat: 43.338N

Lon: 73.610W

Elev: 98

StdP: 100.16

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14750

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.9	-18.9	-27.3	0.3	-21.7	-23.9	0.4	-17.9	8.8	-3.2	8.0	-3.8	0.7	50	0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	31.0	22.5	29.2	21.4	27.9	20.7	24.0	28.5	23.0	27.2	22.2	26.0	4.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.6	17.5	26.4	21.8	16.7	25.4	21.0	15.8	24.5	72.4	28.7	68.8	27.4	65.5	25.8	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.1	6.0	DB	-28.2	33.6	4.3	1.4	-31.3	34.6	-33.8	35.4	-36.2	36.2	-39.3	37.2	(4)
(5)			WB	-28.4	26.2	4.2	1.1	-31.4	27.0	-33.9	27.6	-36.3	28.3	-39.3	29.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.0	-6.6	-5.1	0.1	7.4	13.9	18.6	21.2	20.1	15.9	9.3	3.2	-2.6	(6)	
	DBStd	10.75	7.04	6.19	5.56	4.64	4.21	3.49	2.84	2.93	4.01	4.28	4.77	5.49	(7)	
	HDD10.0	2032	517	422	309	103	11	0	0	0	3	67	210	392	(8)	
	HDD18.3	4012	774	655	564	329	148	38	6	16	96	282	455	649	(9)	
	CDD10.0	1310	1	0	3	26	132	259	348	314	178	44	5	1	(10)	
	CDD18.3	248	0	0	0	1	12	47	96	71	21	1	0	0	(11)	
	CDH23.3	2268	0	0	5	32	161	463	858	566	173	9	0	0	(12)	
	CDH26.7	602	0	0	1	8	39	128	254	133	38	1	0	0	(13)	
(14) Wind	WSAvg	2.4	2.4	2.5	2.9	3.0	2.6	2.3	2.1	1.9	1.9	2.2	2.3	2.2	(14)	
(15) Precipitation	PrecAvg	911	66	52	75	73	92	82	81	90	85	72	79	72	(15)	
	PrecMax	1382	190	123	162	164	198	208	176	205	197	173	164	193	(16)	
	PrecMin	553	9	6	10	15	19	12	21	26	2	0	30	26	(17)	
	PrecStd	173	43	25	32	33	47	48	39	41	52	37	34	38	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	12.0	20.6	27.4	30.1	32.5	33.2	31.9	30.2	24.7	19.1	13.1	(19)	
		MCWB	11.4	7.2	13.5	16.4	19.7	23.0	24.2	23.6	22.0	18.3	15.0	10.4	(20)	
	2%	DB	7.2	7.9	14.7	22.7	27.5	29.9	31.2	29.6	27.5	21.5	16.0	9.7	(21)	
		MCWB	5.0	4.5	9.3	13.8	18.1	21.4	23.1	22.0	20.7	16.7	12.7	7.6	(22)	
	5%	DB	4.4	5.6	11.1	19.1	24.8	27.8	29.4	28.0	25.2	19.0	13.3	7.1	(23)	
		MCWB	2.6	2.7	6.5	11.7	16.8	20.4	22.0	21.3	19.8	14.9	10.3	5.1	(24)	
	10%	DB	2.6	3.4	8.1	16.3	22.4	26.2	27.8	26.6	23.1	16.9	11.1	4.8	(25)	
		MCWB	1.0	1.2	4.8	10.0	15.6	19.2	21.0	20.4	18.3	13.3	8.3	2.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.5	8.2	14.4	18.0	21.7	24.5	25.6	24.8	23.5	20.1	15.9	11.0	(27)	
		MCDB	11.9	10.7	18.6	24.4	27.7	30.2	31.1	29.6	27.5	22.4	18.0	12.3	(28)	
	2%	WB	5.4	5.0	10.2	15.3	20.1	23.0	24.3	23.6	22.0	17.8	13.4	7.9	(29)	
		MCDB	6.8	7.3	13.8	20.6	24.7	28.0	29.0	27.5	25.5	20.4	15.4	9.2	(30)	
	5%	WB	2.9	3.1	7.2	12.9	18.5	21.9	23.2	22.6	20.8	15.5	10.8	5.3	(31)	
		MCDB	4.3	5.2	10.3	18.1	22.7	26.0	27.5	26.1	24.0	18.4	12.6	7.0	(32)	
	10%	WB	1.2	1.5	5.0	10.6	16.9	20.6	22.3	21.7	19.4	13.8	8.5	3.0	(33)	
		MCDB	2.4	3.2	8.2	15.2	21.0	24.1	26.2	25.0	22.3	16.1	10.5	4.4	(34)	
(35) Mean Daily Temperature Range	MDBR		10.0	11.3	10.9	12.2	12.7	12.1	12.0	12.0	12.4	11.4	9.6	8.6	(35)	
	5% DB	MCDBR	9.7	12.0	15.3	18.2	16.7	14.6	13.8	13.2	14.1	14.8	13.3	10.2	(36)	
		MCWBR	8.5	9.2	10.2	10.4	8.8	7.4	6.7	6.7	8.0	9.7	10.2	8.8	(37)	
	5% WB	MCDBR	9.2	11.1	13.7	16.0	13.7	12.5	11.9	11.1	11.9	12.9	11.4	9.9	(38)	
		MCWBR	8.5	8.8	10.0	10.2	8.1	6.9	6.4	6.3	7.3	9.6	9.8	9.0	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.300	0.317	0.338	0.354	0.391	0.438	0.454	0.427	0.374	0.349	0.313	0.296	(40)	
	taud		2.342	2.285	2.353	2.403	2.340	2.228	2.192	2.258	2.391	2.465	2.511	2.435	(41)	
	Ebn at Noon		826	873	901	912	882	838	818	829	852	832	816	802	(42)	
	Edh at Noon		81	102	109	112	123	138	142	128	104	85	69	68	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.52	2.38	3.49	4.46	5.09	5.51	5.67	5.09	4.12	2.53	1.70	1.19	(44)	
	RadStd		0.15	0.21	0.29	0.51	0.56	0.46	0.43	0.27	0.34	0.28	0.18	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+70	N/A	(46)	
(47)	Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+87	N/A	(47)	

Nomenclature: See separate page