

GARRETT COUNTY AP, MD, USA

WMO: 725293

Lat: 39.580N

Lon: 79.339W

Elev: 894

StdP: 91.04

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.4	-15.0	-22.4	0.6	-13.4	-19.8	0.7	-12.1	10.9	-1.5	10.1	-2.3	4.3	280	0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	27.1	19.8	25.9	19.1	24.9	18.7	22.3	24.9	21.2	23.5	20.4	22.7	2.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.4	17.9	22.9	20.3	16.7	22.2	19.9	16.3	21.9	69.7	24.4	66.3	22.8	62.6	23.3	27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.7	8.6	7.8		-19.7	28.9	2.9	1.6	-21.8	30.0	-23.6	30.9	-25.2	31.8	-27.3	32.9	
				-20.0	22.4	2.9	1.0	-22.1	23.2	-23.8	23.8	-25.5	24.3	-27.6	25.1	
				DB												
				WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	-4.0	-1.2	2.2	8.3	13.9	17.5	19.6	18.9	16.0	9.9	3.9	-0.5	(6)
(7)		DBStd	9.57	6.72	6.25	6.17	5.74	4.82	3.07	2.55	2.63	3.87	5.28	5.13	5.95	(7)
(8)		HDD10.0	1721	436	317	254	98	21	1	0	0	3	68	192	330	(8)
(9)		HDD18.3	3662	693	548	502	303	149	50	17	26	90	266	433	586	(9)
(10)		CDD10.0	1262	2	3	11	47	141	226	297	275	183	65	9	3	(10)
(11)		CDD18.3	161	0	0	0	3	11	25	56	42	21	4	0	0	(11)
(12)		CDH23.3	534	0	0	0	16	44	78	186	126	73	11	0	0	(12)
(13)		CDH26.7	36	0	0	0	1	1	5	16	8	5	0	0	0	(13)
(14)	Wind	WSAvg	3.8	4.5	4.5	4.4	4.5	3.6	3.1	2.6	2.6	3.0	3.8	4.1	4.4	(14)
(15)	Precipitation	PrecAvg	1188	100	82	109	100	120	121	112	102	91	77	78	98	(15)
(16)		PrecMax	1557	175	127	181	155	196	181	205	206	210	140	165	187	(16)
(17)		PrecMin	930	54	39	39	47	52	57	69	57	17	24	11	45	(17)
(18)		PrecStd	155	33	26	39	32	43	36	36	38	51	35	33	39	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.9	17.1	19.9	25.9	26.3	27.3	27.9	27.7	27.4	25.0	18.9	15.9	(19)
(20)		0.4%	MCWB	10.9	11.3	12.5	12.8	17.5	19.6	21.7	20.8	18.6	19.0	12.3	11.8	(20)
(21)		2%	DB	11.2	12.6	16.4	22.4	24.9	25.2	27.0	26.2	25.2	22.2	16.0	12.4	(21)
(22)		2%	MCWB	9.5	9.8	10.4	12.6	17.0	18.9	21.0	19.3	18.5	16.9	10.2	10.6	(22)
(23)		5%	DB	7.8	10.9	13.8	20.1	22.7	23.8	25.2	25.0	23.0	19.9	13.0	10.9	(23)
(24)		5%	MCWB	6.2	8.8	8.9	11.9	15.8	18.3	19.8	19.2	17.6	15.1	8.7	9.6	(24)
(25)		10%	DB	5.2	7.8	12.0	17.3	21.2	22.4	23.9	22.9	22.1	17.5	12.0	8.0	(25)
(26)		10%	MCWB	3.1	5.6	8.7	10.3	15.4	17.9	19.1	18.3	17.5	14.0	8.3	6.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	12.8	13.6	15.7	20.5	22.2	24.7	24.1	22.0	20.0	14.3	12.8	(27)
(28)		0.4%	MCDWB	13.7	15.5	17.3	20.3	22.6	24.4	25.4	25.9	23.8	23.0	17.3	14.7	(28)
(29)		2%	WB	9.8	11.1	12.0	14.1	18.9	20.7	22.5	21.8	20.5	18.3	12.2	11.1	(29)
(30)		2%	MCDWB	10.9	12.2	14.4	18.8	22.5	22.9	25.6	24.1	23.0	21.2	14.5	12.1	(30)
(31)		5%	WB	6.8	9.0	10.6	13.0	17.6	19.9	21.5	20.7	19.4	17.2	10.3	9.7	(31)
(32)		5%	MCDWB	7.6	10.7	13.4	17.6	20.7	23.0	24.1	22.8	22.7	18.5	12.2	10.5	(32)
(33)		10%	WB	3.1	6.1	8.5	12.0	16.7	19.0	20.7	19.8	18.1	14.9	8.4	7.3	(33)
(34)		10%	MCDWB	4.6	8.1	11.6	15.8	19.4	22.2	22.7	22.4	20.7	17.1	11.2	7.9	(34)
(35)	Mean Daily Temperature Range	MDBR	7.2	7.9	8.3	9.8	8.6	7.7	7.8	7.7	8.3	7.9	7.3	6.4	(35)	
(36)		5% DB	MCDBR	9.6	10.9	11.4	12.6	10.1	8.9	8.7	9.1	9.2	9.8	8.9	(36)	
(37)		5% DB	MCWBR	8.6	8.9	7.3	6.1	5.0	4.6	4.3	4.2	4.6	5.1	6.6	7.2	(37)
(38)		5% WB	MCDWB	9.7	11.1	10.1	11.4	8.8	8.0	8.2	7.4	8.1	8.2	9.3	8.5	(38)
(39)		5% WB	MCWBR	9.1	9.7	7.4	6.4	4.6	4.8	4.4	4.3	4.4	5.2	7.7	7.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.277	0.293	0.317	0.356	0.396	0.432	0.453	0.457	0.377	0.330	0.295	0.278	(40)	
(41)		taud	2.499	2.434	2.449	2.371	2.261	2.180	2.144	2.105	2.325	2.472	2.543	2.533	(41)	
(42)		Ebn at Noon	906	933	942	919	883	848	826	811	864	877	876	879	(42)	
(43)		Edh at Noon	75	93	102	118	135	146	151	153	115	89	72	68	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.65	2.47	3.46	4.59	5.18	5.74	5.63	5.11	4.23	2.98	2.06	1.44	(44)	
(45)		RadStd	0.18	0.38	0.28	0.41	0.47	0.44	0.34	0.29	0.51	0.35	0.23	0.15	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+108	N/A	(47)

Nomenclature: See separate page