

ANSON COUNTY AP, NC, USA

WMO: 725294

Lat: 35.017N

Lon: 80.083W

Elev: 91

StdP: 100.24

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 00383

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.3	-5.0	-17.6	0.8	-0.9	-14.2	1.1	1.1	8.6	9.3	7.4	8.2	0.7	220	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	35.9	23.0	34.4	22.9	33.0	22.9	25.5	30.8	25.0	30.3	24.5	29.8	2.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	19.1	27.1	23.6	18.6	26.8	22.9	17.8	26.3	78.3	31.3	76.3	30.1	74.3	29.9	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.9	5.6	4.8	-11.6	37.3	2.8	1.5	-13.6	38.4	-15.2	39.3	-16.8	40.1	-18.8	41.2		
(5)			-11.9	26.5	2.7	0.6	-13.9	27.0	-15.4	27.3	-17.0	27.7	-18.9	28.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	5.3	7.9	11.1	16.6	21.5	25.6	26.9	26.1	23.0	16.8	10.1	8.1		
	DBStd	8.70	5.53	5.58	5.31	4.32	3.55	2.61	2.08	2.33	3.15	4.57	4.58	5.31		
	HDD10.0	481	167	99	52	3	0	0	0	0	0	4	54	103		
	HDD18.3	1687	406	293	232	83	15	0	0	0	4	85	249	320		
	CDD10.0	2899	20	41	86	202	356	468	523	499	391	213	57	44		
	CDD18.3	1064	1	3	7	31	113	218	264	241	145	36	2	3		
	CDH23.3	10418	2	18	79	319	1027	2248	2715	2322	1306	358	16	8		
	CDH26.7	4512	0	1	9	69	360	1072	1303	1064	542	92	1	0		
(14) Wind	WSAvg	1.5	1.5	1.8	2.0	2.0	1.6	1.4	1.4	1.2	1.4	1.3	1.3	1.3		
(15) Precipitation	PrecAvg	1145	88	85	106	87	83	107	133	111	102	87	77	81		
	PrecMax	1594	234	135	208	195	192	198	328	198	285	372	197	157		
	PrecMin	788	22	37	35	27	33	11	46	15	9	0	10	33		
	PrecStd	189	48	30	44	45	44	51	67	47	74	77	52	34		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.8	25.8	27.8	30.6	34.0	37.0	37.3	37.5	35.0	32.1	25.2	24.4		
		MCWB	16.3	17.5	16.4	19.1	21.8	22.6	23.1	22.9	21.0	22.2	17.1	19.0		
	2%	DB	19.8	22.9	25.8	28.7	32.1	35.2	35.7	35.0	33.0	28.9	22.8	21.7		
		MCWB	15.0	15.6	16.1	18.1	20.9	22.8	23.6	23.2	21.7	20.4	16.4	18.3		
	5%	DB	17.6	20.5	23.2	27.2	30.5	33.7	34.1	33.2	32.0	27.2	21.0	19.9		
		MCWB	13.4	14.3	14.6	17.9	20.8	22.7	23.4	23.6	21.5	19.3	16.0	17.3		
	10%	DB	15.0	17.9	21.0	25.1	28.7	32.4	32.7	32.2	30.1	25.1	19.0	17.6		
		MCWB	11.0	13.0	14.2	16.9	20.4	22.5	23.3	23.3	21.4	18.8	14.5	14.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.4	18.8	18.6	21.9	23.9	25.4	26.2	26.2	25.0	24.0	20.2	20.6		
		MCDB	21.1	23.7	23.0	26.2	29.6	31.4	31.6	31.3	29.4	27.4	21.9	22.2		
	2%	WB	16.6	17.5	17.7	20.7	22.8	24.6	25.5	25.5	24.2	23.1	18.7	19.0		
		MCDB	18.8	21.1	22.0	24.8	27.7	30.8	31.1	30.5	29.2	26.4	21.4	20.8		
	5%	WB	14.5	15.9	16.9	19.6	22.1	24.1	25.0	25.0	23.5	21.9	17.2	17.3		
		MCDB	16.8	19.5	21.0	23.9	27.1	30.3	30.6	30.0	28.0	25.4	19.5	19.4		
	10%	WB	11.6	13.8	15.6	18.6	21.6	23.6	24.5	24.5	22.8	20.4	15.5	15.5		
		MCDB	13.9	17.2	19.9	23.3	26.3	29.3	30.0	29.3	26.8	23.7	18.5	17.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	12.7	13.6	13.5	12.4	12.1	11.5	11.1	12.1	13.6	14.0	11.8		
		MCDBR	15.4	14.8	15.8	15.1	14.1	13.7	13.2	12.9	14.7	15.1	15.8	12.3		
		MCWBR	10.2	8.7	7.7	6.6	5.3	4.1	3.7	3.9	4.9	7.2	9.7	8.6		
	5% WB	MCDBR	12.3	12.4	12.9	11.8	11.5	12.0	10.9	10.8	10.8	11.0	11.1	10.5		
		MCWBR	9.9	8.7	7.6	6.4	4.7	4.2	3.8	3.8	4.3	5.9	8.6	8.3		
(40) Clear-Sky Solar Irradiance	taub		0.315	0.325	0.362	0.405	0.466	0.491	0.544	0.518	0.433	0.388	0.333	0.312		
	taud		2.506	2.470	2.399	2.270	2.146	2.114	1.991	2.051	2.280	2.376	2.487	2.547		
	Ebn at Noon		892	920	909	881	828	804	759	771	826	836	861	875		
	Edh at Noon		83	96	112	134	153	158	178	165	125	104	84	75		
(44) All-Sky Solar Radiation	RadAvg		2.66	3.31	4.39	5.50	6.07	6.42	6.04	5.50	4.67	3.84	2.92	2.30		
	RadStd		0.16	0.38	0.32	0.41	0.49	0.45	0.38	0.26	0.40	0.48	0.24	0.20		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (71 neighbors)		+0.49	N/A	N/A	N/A	N/A	N/A	N/A	+161	+117

Nomenclature: See separate page