

FINDLAY, OH, USA

WMO: 725366

Lat: 41.014N

Lon: 83.669W

Elev: 244

StdP: 98.43

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14825

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.5	-14.5	-21.9	0.5	-17.2	-18.8	0.7	-14.0	13.0	-1.7	12.0	-1.6	4.0	250	0.542

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	32.5	23.1	31.2	22.5	29.8	21.7	24.9	30.4	23.9	28.8	23.0	27.7	4.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.0	18.3	28.2	22.3	17.5	27.1	21.5	16.6	26.0	76.6	30.6	72.6	28.7	69.3	27.7	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.5	10.1	8.8	DB	-20.6	34.6	4.1	1.6	-23.5	35.7	-25.9	36.6	-28.2	37.5	-31.1	38.6	
			WB	-21.0	26.4	4.0	1.3	-23.8	27.4	-26.1	28.1	-28.4	28.9	-31.2	29.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	-3.2	-1.5	3.6	10.3	16.4	21.5	23.2	22.2	18.8	12.3	5.6	-0.1
	DBStd	10.60	6.86	6.39	6.06	5.18	4.78	3.64	2.95	2.90	4.09	4.99	5.36	5.79
	HDD10.0	1515	412	324	216	58	4	0	0	0	1	31	153	316
	HDD18.3	3236	669	555	458	246	96	13	2	4	43	196	383	571
	CDD10.0	1815	2	3	17	67	203	346	409	377	264	104	20	3
	CDD18.3	494	0	0	1	4	37	109	152	123	57	10	0	0
	CDH23.3	4242	0	0	7	50	335	928	1346	987	502	85	2	0
	CDH26.7	1361	0	0	1	6	92	319	474	296	155	17	0	0
Wind	WSAvg	4.2	5.2	4.9	4.8	4.9	4.2	3.6	3.1	2.9	3.2	4.0	4.6	4.7
Precipitation	PrecAvg	875	43	40	64	80	99	98	102	89	74	55	68	60
	PrecMax	1123	118	112	157	170	230	276	265	193	231	139	178	172
	PrecMin	595	12	4	17	21	20	9	7	6	12	13	7	15
	PrecStd	147	26	26	32	36	41	52	56	51	44	30	39	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.7	18.3	23.8	27.5	31.3	33.9	34.3	33.2	32.9	28.9	22.0	17.1
		MCWB	13.1	13.5	16.7	18.0	20.7	22.4	24.8	23.8	22.5	20.3	14.5	14.0
	2%	DB	12.7	13.8	19.5	24.6	29.1	32.1	32.5	31.3	30.7	25.7	18.3	13.4
		MCWB	10.9	10.8	13.8	16.1	19.9	22.3	23.9	23.2	21.5	17.8	13.8	11.1
	5%	DB	9.5	10.2	16.4	22.0	27.3	30.3	31.0	29.7	28.3	23.1	16.3	10.7
		MCWB	7.6	7.4	12.1	14.7	19.0	21.4	22.9	22.2	20.3	16.7	12.6	8.8
	10%	DB	5.9	7.0	13.3	19.2	24.8	28.3	29.4	28.2	26.3	20.7	13.9	7.7
		MCWB	4.0	4.8	9.8	13.3	18.1	20.7	21.9	21.5	19.0	15.6	10.8	5.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.4	14.2	17.3	19.8	22.8	24.7	26.3	25.7	24.2	21.8	17.1	14.6
		MCDB	15.3	16.8	22.5	24.4	28.6	30.8	32.2	31.3	30.3	27.3	20.0	16.8
	2%	WB	11.2	11.0	14.8	17.4	21.4	23.6	25.2	24.6	22.9	19.7	14.8	11.5
		MCDB	12.8	13.5	18.5	23.1	27.1	29.4	30.9	29.4	28.0	23.7	17.4	13.1
	5%	WB	7.7	7.7	12.7	15.7	20.2	22.7	24.1	23.6	21.6	17.9	12.9	8.8
		MCDB	9.3	10.0	16.0	20.3	25.2	28.3	29.0	27.8	26.0	21.9	15.6	10.5
	10%	WB	4.1	4.8	10.1	14.0	19.0	21.8	23.1	22.7	20.5	16.1	10.8	6.0
		MCDB	5.7	7.0	13.4	18.5	23.6	26.9	27.5	26.6	24.6	20.0	13.6	7.7
Mean Daily Temperature Range	5% DB	MDBR	7.6	8.0	9.4	11.2	11.0	10.5	10.7	10.7	11.6	10.6	8.7	6.9
		MCDBR	9.9	11.7	13.5	14.9	13.3	12.6	12.0	11.9	13.7	13.6	11.9	9.8
		MCWBR	8.8	9.5	9.0	8.6	6.7	5.6	5.2	5.5	6.2	7.2	8.4	8.4
	5% WB	MCDBR	9.8	11.2	12.3	12.9	11.6	10.7	10.4	10.2	11.2	11.4	10.7	9.4
		MCWBR	9.0	9.5	9.0	8.5	6.6	5.4	5.2	5.4	5.6	6.8	8.5	8.6
Clear-Sky Solar Irradiance	taub	0.305	0.330	0.352	0.401	0.437	0.448	0.445	0.441	0.392	0.360	0.326	0.305	
	taud	2.395	2.320	2.334	2.214	2.158	2.177	2.204	2.198	2.314	2.385	2.437	2.429	
	Ebn at Noon	848	875	896	870	844	832	831	823	842	831	816	818	
	Edh at Noon	82	102	113	137	149	146	141	138	115	95	78	73	
All-Sky Solar Radiation	RadAvg	1.57	2.50	3.49	4.66	5.46	6.05	6.04	5.38	4.38	2.94	1.91	1.31	
	RadStd	0.16	0.31	0.32	0.40	0.46	0.43	0.35	0.22	0.35	0.24	0.25	0.13	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.69	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+167	+110
(47)	Regional (68 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+100	N/A

Nomenclature: See separate page