

COPPER HARBOR, MI, USA

WMO: 725387

Lat: 47.467N

Lon: 87.883W

Elev: 191

StdP: 99.05

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 94899

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-18.2	-16.4	-22.6	0.5	-17.2	-20.5	0.6	-15.7	16.0	-9.4	14.5	-8.9	4.1	350	0.626

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.0	27.2	19.6	25.3	18.9	23.8	18.2	21.2	25.3	20.1	23.9	19.2	22.7	3.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.6	14.7	23.7	18.6	13.8	22.6	17.6	12.9	21.6	62.3	25.6	58.6	23.9	55.4	22.7	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.1	11.6	10.3	DB	-20.5	30.9	3.6	1.4	-23.1	31.9	-25.2	32.7	-27.2	33.5	-29.8	34.5	(4)
(5)			WB	-20.9	23.5	3.5	0.9	-23.4	24.1	-25.5	24.6	-27.5	25.1	-30.0	25.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.7	-6.8	-7.0	-2.2	2.9	9.0	14.0	18.0	18.4	14.9	8.1	2.1	-3.7	(6)
(7)		DBStd	10.03	5.12	5.34	5.80	4.47	4.21	3.69	3.54	3.14	4.25	4.08	4.60	4.49	(7)
(8)		HDD10.0	2432	521	476	380	218	70	7	0	0	7	89	238	426	(8)
(9)		HDD18.3	4713	779	709	637	464	290	138	51	38	118	318	486	684	(9)
(10)		CDD10.0	868	0	0	2	4	39	126	248	261	154	30	3	0	(10)
(11)		CDD18.3	107	0	0	0	0	1	8	41	41	16	1	0	0	(11)
(12)		CDH23.3	427	0	0	0	0	17	53	156	152	47	3	0	0	(12)
(13)		CDH26.7	68	0	0	0	0	3	10	23	26	6	0	0	0	(13)
(14)	Wind	WSAvg	3.9	4.5	4.8	4.1	3.6	3.1	2.7	3.1	3.3	3.8	4.5	5.0	4.8	(14)
(15)	Precipitation	PrecAvg	717	53	34	38	55	77	69	62	54	77	74	56	57	(15)
(16)		PrecMax	995	139	67	88	114	174	163	168	154	218	208	139	111	(16)
(17)		PrecMin	489	12	11	1	16	32	13	23	9	25	19	26	6	(17)
(18)		PrecStd	140	32	16	23	28	36	33	30	37	39	42	25	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.3	7.2	16.3	18.5	25.8	28.0	29.5	29.6	27.5	22.4	15.5	7.1	(19)
(20)			MCWB	2.8	3.6	10.9	10.8	17.2	19.5	21.1	21.2	20.0	16.6	11.0	4.5	(20)
(21)		2%	DB	3.1	3.9	10.1	14.3	21.2	24.5	26.9	26.7	24.4	18.8	12.5	5.0	(21)
(22)			MCWB	1.6	1.5	6.6	8.1	15.0	17.4	19.7	19.4	18.8	13.7	8.8	3.3	(22)
(23)		5%	DB	1.9	1.9	7.5	11.8	17.9	22.4	25.1	24.9	22.6	16.4	10.0	3.6	(23)
(24)			MCWB	0.9	0.3	4.3	6.5	12.6	16.1	18.9	19.1	17.9	12.8	7.2	2.2	(24)
(25)		10%	DB	0.6	0.2	5.1	9.3	15.5	20.2	23.5	23.3	20.9	14.1	8.3	2.4	(25)
(26)			MCWB	-0.6	-1.3	2.7	5.3	10.7	15.1	18.3	18.4	17.1	11.4	6.0	1.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.1	4.2	12.4	12.1	19.1	20.9	22.8	22.5	21.3	17.2	11.7	5.4	(27)
(28)			MCD B	4.3	6.3	15.2	17.4	23.2	25.8	27.1	26.9	25.0	21.2	14.3	6.4	(28)
(29)		2%	WB	1.9	1.9	6.9	9.1	15.7	18.7	21.0	21.2	20.0	15.0	9.4	3.5	(29)
(30)			MCD B	2.8	3.6	9.3	13.5	19.8	22.4	25.2	25.1	23.4	18.1	12.1	4.5	(30)
(31)		5%	WB	0.8	0.2	4.6	7.1	13.4	17.1	19.9	20.1	18.7	13.1	7.7	2.4	(31)
(32)			MCD B	1.9	1.7	7.1	10.9	17.3	21.1	23.7	23.7	21.8	15.5	9.8	3.5	(32)
(33)		10%	WB	-0.6	-1.1	2.7	5.5	11.2	15.6	19.0	19.1	17.5	11.6	6.4	1.2	(33)
(34)			MCD B	0.6	0.2	4.9	9.0	14.7	19.4	22.6	22.5	20.3	14.1	8.1	2.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.4	6.4	7.3	7.1	8.4	9.1	8.1	7.0	6.9	5.4	5.1	5.0	(35)
(36)			MCD BR	6.9	9.1	10.0	11.5	12.8	12.4	9.8	9.0	8.9	8.7	7.2	6.0	(36)
(37)			MCWBR	5.8	7.1	7.0	7.0	7.8	7.3	5.5	4.9	4.9	5.5	5.0	5.2	(37)
(38)		5% WB	MCD BR	6.7	7.9	9.3	10.6	12.3	11.4	9.1	8.1	7.7	6.3	5.4	(38)	
(39)			MCWBR	5.7	6.4	6.9	7.1	8.5	7.8	5.9	5.0	5.2	5.4	4.9	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.273	0.288	0.311	0.342	0.374	0.382	0.394	0.374	0.366	0.331	0.301	0.269	(40)	
(41)		taud	2.488	2.424	2.399	2.371	2.382	2.378	2.399	2.459	2.459	2.521	2.526	2.513	(41)	
(42)		Ebn at Noon	831	886	913	911	889	882	864	870	844	825	786	793	(42)	
(43)		Edh at Noon	62	82	99	112	116	117	113	102	93	75	61	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.90	1.78	3.32	4.68	5.62	6.16	6.22	5.37	3.83	2.23	1.06	0.66	(44)	
(45)		RadStd	0.08	0.21	0.40	0.54	0.37	0.43	0.30	0.37	0.21	0.27	0.17	0.08	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (21 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page