

JACKSON COUNTY AP, MI, USA

WMO: 725395

Lat: 42.267N

Lon: 84.467W

Elev: 998

StdP: 14.17

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14833

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.4	4.7	-8.0	3.7	1.2	-2.6	4.9	6.8	23.9	25.3	20.8	26.1	6.7	230	0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.6	88.8	73.2	86.1	71.8	83.5	70.3	76.1	84.7	74.4	82.4	72.8	80.3	9.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.3	128.6	80.6	71.9	122.3	79.1	70.2	115.4	77.5	40.2	84.7	38.5	82.4	37.0	80.5	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.6	18.5	16.9	DB	-8.2	93.2	6.2	2.6	-12.6	95.0	-16.2	96.6	-19.7	98.0	-24.2	99.9	(4)
(5)			WB	-8.7	79.4	6.0	1.9	-13.1	80.7	-16.6	81.8	-20.0	82.9	-24.4	84.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.8	23.9	26.2	35.4	47.6	58.5	67.9	71.3	69.7	62.9	51.2	39.7	29.6
	DBStd	18.99	11.68	11.06	11.05	9.26	8.50	6.76	5.67	5.39	7.60	8.71	9.42	9.85
	HDD50	3186	812	668	473	151	20	0	0	0	3	92	332	635
	HDD65	6537	1275	1086	918	525	239	46	11	18	127	435	760	1097
	CDD50	2737	1	2	20	79	283	537	660	609	391	130	22	3
	CDD65	618	0	0	1	4	37	133	207	163	65	8	0	0
	CDH74	5381	0	0	10	46	382	1201	1887	1240	550	65	0	0
	CDH80	1500	0	0	1	4	86	363	596	302	140	8	0	0
Wind	WSAvg	7.9	9.5	9.3	9.0	9.4	7.9	6.6	5.9	5.5	6.0	7.7	8.7	9.0
Precipitation	PrecAvg	30.6	1.4	1.3	2.2	2.8	3.3	3.5	3.3	3.1	3.0	2.2	2.4	2.0
	PrecMax	38.8	3.1	3.0	5.2	5.4	7.2	6.9	6.5	9.3	8.2	6.8	5.5	4.3
	PrecMin	19.9	0.3	0.1	0.3	0.3	1.1	0.5	0.6	0.2	0.4	0.3	0.6	0.4
	PrecStd	4.1	0.8	0.8	1.1	1.1	1.6	1.5	1.7	1.8	1.8	1.5	1.1	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.5	59.5	74.7	79.7	86.4	91.2	93.1	90.2	88.5	80.8	68.8	60.4
		MCWB	53.0	52.9	61.9	62.3	68.5	74.1	75.8	75.1	71.4	68.6	57.2	56.5
	2%	DB	50.6	52.9	65.8	73.8	82.1	87.6	89.1	86.2	84.1	74.9	62.6	53.7
		MCWB	48.0	47.4	55.9	58.9	66.6	71.8	74.4	73.1	69.7	63.1	55.1	48.8
	5%	DB	44.7	46.2	59.0	69.3	78.6	84.3	86.0	83.2	80.3	70.2	58.9	47.6
		MCWB	41.4	40.8	50.7	55.8	65.0	70.0	72.4	71.1	68.0	61.1	52.8	43.4
	10%	DB	39.0	40.9	53.2	64.4	74.1	81.1	83.1	80.8	76.6	66.2	54.6	42.4
		MCWB	36.5	36.9	46.4	53.0	62.7	68.7	70.8	69.7	65.8	58.6	48.7	39.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.0	55.3	62.5	65.6	72.2	76.4	79.2	77.9	75.3	70.7	60.5	56.8
		MCDB	56.2	58.1	73.3	76.5	81.9	87.2	88.6	86.6	84.2	78.9	65.2	60.0
	2%	WB	48.4	47.9	56.9	61.5	69.3	74.2	76.7	75.3	72.5	66.3	57.1	49.9
		MCDB	50.1	51.1	63.9	68.7	78.7	84.2	85.5	82.5	79.9	71.5	61.0	52.6
	5%	WB	41.6	41.3	52.3	58.0	67.1	72.4	74.8	73.6	70.2	62.6	53.4	43.7
		MCDB	44.1	45.3	57.9	66.7	75.4	81.4	82.8	79.8	76.4	68.2	58.4	46.8
	10%	WB	36.5	37.1	46.1	54.5	64.3	70.5	72.9	71.8	67.9	59.3	49.2	39.1
		MCDB	38.8	40.9	52.2	63.3	72.1	78.3	80.4	77.9	74.2	65.3	54.0	41.9
Mean Daily Temperature Range	5% DB	MDBR	13.3	15.0	17.6	20.6	20.6	20.1	20.6	19.4	20.6	18.5	14.9	11.8
		MCDBR	16.9	19.8	25.2	26.5	24.7	23.0	22.7	21.4	23.5	23.5	19.8	17.6
		MCWBR	14.9	15.8	16.8	15.2	12.9	10.8	10.5	10.2	11.3	13.9	14.4	14.5
	5% WB	MCDBR	16.9	18.8	22.6	22.8	21.3	19.5	19.4	17.3	19.2	20.3	18.7	16.0
		MCWBR	15.7	15.9	16.5	15.6	12.7	10.6	10.6	9.4	10.8	14.1	15.1	14.6
Clear-Sky Solar Irradiance	taub	0.297	0.347	0.348	0.392	0.423	0.443	0.432	0.427	0.383	0.347	0.315	0.301	
	taud	2.375	2.189	2.342	2.240	2.202	2.184	2.223	2.232	2.338	2.435	2.476	2.405	
	Ebn at Noon	268	266	284	278	271	265	266	264	268	266	260	256	
	Edh at Noon	25	36	35	42	45	46	44	42	35	28	23	23	
All-Sky Solar Radiation	RadAvg	472	757	1132	1453	1693	1909	1937	1669	1351	874	548	379	
	RadStd	45	99	111	133	155	122	93	76	123	82	73	39	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (65 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page