

POCONO MOUNTAINS, PA, USA

WMO: 725434

Lat: 41.139N

Lon: 75.379W

Elev: 1916

StdP: 13.71

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 54789

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.5	5.0	-9.9	3.5	3.8	-5.6	4.4	7.6	28.6	19.6	26.7	21.3	11.6	300	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.2	84.4	69.6	82.1	68.6	79.6	67.6	72.7	80.1	71.3	77.7	70.0	76.1	9.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.5	120.5	75.3	69.6	116.7	74.5	68.0	110.4	73.3	37.5	80.0	36.3	77.8	35.1	75.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.2	20.6	18.4	-5.7	88.7	5.6	2.7	-9.7	90.6	-12.9	92.2	-16.0	93.7	-20.1	95.7		
			-6.5	75.2	5.3	1.4	-10.3	76.2	-13.4	77.0	-16.4	77.8	-20.2	78.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.0	23.5	25.5	33.3	46.0	56.3	64.1	69.0	66.9	60.5	49.3	38.6	29.3
	DBStd	18.03	11.35	10.09	10.44	9.46	8.29	6.32	4.90	5.14	6.58	8.55	9.08	9.49
	HDD50	3372	821	688	526	184	30	0	0	0	3	120	355	645
	HDD65	6941	1285	1107	982	574	292	93	17	39	165	489	791	1107
	CDD50	2270	0	1	10	65	225	422	590	523	318	99	14	3
	CDD65	362	0	0	0	4	22	64	142	97	30	3	0	0
	CDH74	2425	0	0	0	52	193	436	974	567	191	12	0	0
	CDH80	462	0	0	0	10	26	81	212	103	30	0	0	0
Wind	WSAvg	8.4	10.1	10.5	10.2	9.7	7.9	7.1	6.2	5.9	6.5	8.3	9.1	10.0
Precipitation	PrecAvg	51.1	3.6	2.9	4.3	4.1	4.0	4.9	4.2	4.5	5.2	4.9	4.4	4.6
	PrecMax	67.5	9.1	7.6	8.5	8.2	9.2	11.7	8.7	8.9	10.9	13.4	5.9	9.5
	PrecMin	39.2	1.8	1.1	1.1	2.1	0.9	2.2	1.7	1.3	1.7	1.2	2.1	2.0
	PrecStd	7.4	2.0	1.4	1.6	1.7	1.9	2.4	1.6	2.0	2.5	3.2	1.1	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.3	57.6	66.9	81.4	83.2	86.2	88.3	87.0	83.7	75.6	65.4	59.2
		MCWB	51.8	52.9	54.2	60.5	66.4	70.3	71.8	70.7	69.4	63.2	54.8	55.3
	2%	DB	49.9	50.6	59.6	72.9	79.4	82.1	84.7	82.9	79.7	70.5	60.6	52.8
		MCWB	46.7	46.1	50.9	55.9	64.7	68.6	70.6	69.9	68.0	61.2	54.2	49.9
	5%	DB	44.8	45.4	54.4	67.4	75.3	79.1	82.1	79.9	75.3	66.7	56.6	47.9
		MCWB	41.5	40.4	47.5	54.4	62.3	67.2	69.2	68.7	64.8	60.8	51.5	45.2
	10%	DB	39.2	39.6	49.7	62.1	71.3	75.6	79.5	77.1	72.2	63.1	53.1	43.3
		MCWB	36.2	35.3	43.4	50.5	59.9	64.7	67.9	66.6	63.8	57.5	48.6	39.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.5	54.7	56.5	63.5	69.8	72.9	74.9	74.4	72.5	67.7	59.7	56.3
		MCDB	55.1	57.7	62.9	72.9	79.3	80.5	83.9	81.9	79.6	70.8	63.4	58.2
	2%	WB	47.6	46.4	52.4	59.5	67.5	71.1	72.9	72.4	70.1	65.0	56.1	50.5
		MCDB	49.2	48.8	57.2	69.1	75.4	78.2	81.1	78.6	75.3	68.1	58.7	52.3
	5%	WB	41.6	40.5	48.5	56.2	65.1	69.3	71.3	70.8	68.0	62.0	52.6	45.7
		MCDB	43.9	44.4	53.3	64.1	72.0	76.5	78.1	76.3	72.5	65.3	55.4	47.5
	10%	WB	36.6	35.5	43.9	53.0	62.7	67.6	70.1	69.3	66.0	58.2	48.8	40.4
		MCDB	39.2	39.5	49.0	60.7	67.9	73.7	76.4	74.4	70.1	62.2	52.2	42.8
Mean Daily Temperature Range	5% DB	MDBR	13.8	14.9	16.4	19.1	18.9	17.8	18.2	17.4	17.8	16.0	14.7	12.5
		MCDBR	18.6	19.9	22.3	25.8	23.1	20.8	20.6	19.5	21.9	21.0	19.3	16.9
		MCWBR	17.0	16.6	15.2	13.3	11.3	10.0	9.2	9.1	11.3	12.3	13.9	15.6
	5% WB	MCDBR	18.1	18.6	19.9	22.5	19.3	17.8	17.5	16.2	17.1	16.4	17.2	16.6
		MCWBR	17.7	17.0	16.6	14.2	10.8	9.4	8.7	8.4	10.5	11.8	14.8	16.6
Clear-Sky Solar Irradiance	taub	0.284	0.306	0.331	0.350	0.385	0.434	0.438	0.428	0.353	0.339	0.301	0.283	
	taud	2.451	2.381	2.407	2.397	2.322	2.210	2.209	2.227	2.415	2.469	2.538	2.521	
	Ebn at Noon	279	287	292	292	283	268	265	265	280	272	271	271	
	Edh at Noon	24	30	33	36	40	45	44	43	33	28	23	21	
All-Sky Solar Radiation	RadAvg	538	816	1116	1446	1634	1765	1831	1590	1312	889	610	446	
	RadStd	41	96	94	151	174	161	106	100	162	104	64	52	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (58 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+207	+115	

Nomenclature: See separate page