

MARSHALLTOWN, IA, USA

WMO: 725461

Lat: 42.111N

Lon: 92.916W

Elev: 297

StdP: 97.81

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 94988

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.4	-19.4	-25.8	0.4	-22.1	-22.9	0.5	-18.9	14.9	-5.3	13.0	-7.9	3.7	310	0.593

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	32.4	24.7	31.1	23.9	29.4	22.7	25.9	30.6	25.1	29.5	24.1	28.1	5.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.6	20.3	29.0	23.7	19.2	28.0	22.7	18.0	26.9	82.1	30.8	78.0	29.5	74.0	28.4	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	11.1	9.6	DB	-26.8	34.5	3.0	1.6	-29.0	35.7	-30.8	36.6	-32.5	37.5	-34.6	38.7	(4)
(5)			WB	-27.0	27.8	3.0	0.9	-29.2	28.5	-30.9	29.0	-32.5	29.5	-34.7	30.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.2	-6.6	-4.7	2.2	9.5	15.9	21.1	23.0	21.4	17.8	10.5	3.1	-3.9	(6)
(7)		DBStd	11.74	6.97	7.09	6.68	5.47	4.78	3.43	3.19	3.05	4.49	5.46	5.86	6.66	(7)
(8)		HDD10.0	1977	516	413	255	73	8	0	0	0	2	61	218	432	(8)
(9)		HDD18.3	3777	774	646	500	269	106	13	3	7	63	250	458	689	(9)
(10)		CDD10.0	1674	0	1	14	57	191	333	402	354	237	76	11	1	(10)
(11)		CDD18.3	433	0	0	1	3	30	96	147	103	48	7	0	0	(11)
(12)		CDH23.3	3952	0	0	6	53	281	862	1383	852	449	65	1	0	(12)
(13)		CDH26.7	1229	0	0	0	11	72	273	483	242	134	14	0	0	(13)
(14)	Wind	WSAvg	4.6	5.2	5.2	5.4	5.7	5.2	4.2	3.4	3.1	3.7	4.5	5.0	5.0	(14)
(15)	Precipitation	PrecAvg	867	24	28	56	82	104	116	102	120	94	64	43	32	(15)
(16)		PrecMax	1219	96	88	115	163	254	287	288	379	227	145	141	87	(16)
(17)		PrecMin	438	2	2	11	22	23	29	21	12	7	2	0	6	(17)
(18)		PrecStd	194	20	22	30	37	64	59	55	81	61	42	33	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	15.6	23.9	28.1	31.5	33.0	34.6	33.0	32.4	28.5	22.0	14.8	(19)
(20)			MCWB	6.0	10.2	16.2	17.7	22.1	24.4	26.0	24.4	22.8	20.4	14.4	11.9	(20)
(21)		2%	DB	7.1	11.1	19.2	24.5	28.5	31.3	32.6	31.1	30.2	24.9	17.7	10.2	(21)
(22)			MCWB	3.9	7.8	13.2	15.9	19.8	23.3	25.9	24.6	22.2	17.5	12.8	7.7	(22)
(23)		5%	DB	4.0	7.5	16.0	21.9	26.5	29.8	31.1	29.1	27.9	22.4	14.7	7.5	(23)
(24)			MCWB	2.1	5.0	11.8	14.3	18.3	22.0	25.0	23.5	20.8	16.7	10.5	5.1	(24)
(25)		10%	DB	2.1	4.0	12.3	18.9	24.1	28.0	29.2	27.7	26.0	19.6	12.2	4.4	(25)
(26)			MCWB	0.8	2.3	8.4	12.6	17.3	21.1	23.7	22.4	19.5	14.9	8.6	2.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	11.6	17.2	19.0	23.0	26.4	27.9	26.5	24.8	21.8	15.8	12.7	(27)
(28)			MCDWB	10.3	14.9	22.2	25.6	29.7	31.7	32.3	31.0	29.9	26.0	19.4	14.5	(28)
(29)		2%	WB	4.2	7.9	14.9	16.9	21.5	24.8	26.6	25.3	23.6	19.7	13.6	8.7	(29)
(30)			MCDWB	6.8	10.3	18.1	22.5	27.1	29.5	31.2	29.7	28.0	22.7	17.2	9.5	(30)
(31)		5%	WB	2.3	4.9	11.7	15.2	20.0	23.7	25.6	24.3	22.3	17.6	11.2	5.2	(31)
(32)			MCDWB	3.9	7.4	15.5	20.5	24.5	28.1	30.1	28.1	26.1	20.7	14.3	7.2	(32)
(33)		10%	WB	0.8	2.4	8.6	13.3	18.7	22.4	24.6	23.3	20.9	15.5	8.7	2.8	(33)
(34)			MCDWB	1.8	4.1	12.0	17.9	22.8	26.8	28.7	26.8	24.2	19.2	11.6	4.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.9	9.3	10.3	12.0	11.4	10.9	10.8	10.9	12.6	11.7	10.3	8.8	(35)
(36)			MCDBR	11.3	12.3	15.3	16.4	13.7	12.6	11.5	12.0	14.0	14.6	14.4	11.7	(36)
(37)			MCWBR	8.9	9.0	9.6	9.1	6.8	6.3	6.1	6.4	6.8	8.1	9.5	8.9	(37)
(38)		5% WB	MCDBR	10.6	11.9	13.8	13.6	11.6	11.0	10.6	10.7	11.6	11.6	13.0	10.8	(38)
(39)			MCWBR	8.5	9.0	9.0	8.7	6.5	6.6	6.2	6.2	6.5	7.8	9.4	8.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.284	0.304	0.329	0.377	0.407	0.420	0.435	0.415	0.385	0.340	0.301	0.281	(40)	
(41)		taud	2.401	2.349	2.386	2.279	2.264	2.277	2.214	2.284	2.322	2.445	2.483	2.433	(41)	
(42)		Ebn at Noon	867	901	918	891	869	856	837	844	844	849	842	839	(42)	
(43)		Edh at Noon	78	97	106	128	133	132	139	126	113	88	73	70	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.88	2.90	3.82	4.71	5.57	6.17	6.27	5.42	4.51	2.99	2.02	1.52	(44)	
(45)		RadStd	0.19	0.22	0.38	0.39	0.41	0.56	0.40	0.35	0.32	0.37	0.17	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page