

AMES, IA, USA

WMO: 725472

Lat: 41.991N

Lon: 93.619W

Elev: 291

StdP: 97.88

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 94989

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.5	-18.6	-25.2	0.4	-21.0	-22.8	0.5	-18.1	13.8	-5.8	12.2	-6.8	3.5	310	0.565

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	32.7	24.5	31.3	23.8	29.9	22.9	26.2	30.7	25.1	29.6	24.1	28.3	5.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	20.6	29.2	23.7	19.3	28.1	22.7	18.1	26.9	82.7	30.8	78.3	29.6	74.3	28.4	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.7	10.5	9.0	DB	-26.7	35.0	3.6	1.4	-29.3	36.0	-31.3	36.9	-33.3	37.6	-35.9	38.7	(4)
(5)			WB	-26.9	28.0	3.5	1.0	-29.4	28.7	-31.4	29.2	-33.4	29.8	-35.9	30.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	-6.2	-4.3	2.8	10.1	16.3	21.4	23.3	21.7	18.0	10.8	3.4	-3.6	(6)	
	DBStd	11.63	6.76	6.93	6.58	5.26	4.59	3.38	3.00	2.89	4.26	5.27	5.72	6.47	(7)	
	HDD10.0	1891	502	400	238	61	6	0	0	0	1	54	208	421	(8)	
	HDD18.3	3659	760	633	482	251	95	11	2	5	57	239	448	678	(9)	
	CDD10.0	1732	0	1	16	64	200	343	414	362	242	79	11	1	(10)	
	CDD18.3	459	0	0	1	3	31	103	157	109	48	6	0	0	(11)	
	CDH23.3	4367	0	0	7	65	309	975	1502	938	493	76	2	0	(12)	
	CDH26.7	1416	0	0	0	14	79	329	544	281	151	18	0	0	(13)	
(14) Wind	WSAvg	4.1	4.6	4.6	4.8	5.1	4.6	3.8	3.0	2.7	3.3	4.0	4.5	4.4	(14)	
(15) Precipitation	PrecAvg	909	22	26	57	98	131	131	123	111	74	59	48	27	(15)	
	PrecMax	1418	46	47	160	203	231	322	346	341	137	192	120	60	(16)	
	PrecMin	590	9	6	2	29	35	21	30	18	19	5	2	0	(17)	
	PrecStd	201	9	12	38	41	50	79	76	78	36	45	31	17	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	16.3	24.0	28.8	32.0	33.6	34.7	33.6	32.5	28.8	22.6	14.9	(19)	
		MCWB	6.5	11.4	16.3	17.8	21.8	23.7	26.1	24.5	22.8	20.1	14.7	11.6	(20)	
	2%	DB	7.4	11.2	20.0	25.1	28.8	32.0	32.8	31.3	30.7	25.5	18.1	10.3	(21)	
		MCWB	4.1	7.9	13.7	16.3	19.9	23.3	25.6	24.7	22.4	17.5	12.8	7.6	(22)	
	5%	DB	4.5	7.6	16.3	22.4	26.9	30.2	31.3	29.5	28.1	22.6	15.0	7.5	(23)	
		MCWB	2.4	5.0	11.8	14.3	18.7	22.2	24.8	23.6	20.9	16.5	10.4	5.0	(24)	
	10%	DB	2.4	4.4	12.7	19.5	24.6	28.5	29.7	27.9	26.3	19.9	12.3	4.8	(25)	
		MCWB	0.9	2.6	8.7	12.9	17.6	21.3	23.8	22.6	19.6	14.7	8.8	2.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	12.1	17.4	19.4	23.4	26.2	28.0	26.9	24.9	21.8	15.9	12.3	(27)	
		MCDB	11.3	15.5	22.0	26.3	29.7	31.8	32.7	31.1	30.3	25.7	19.8	14.0	(28)	
	2%	WB	4.6	8.2	15.1	17.3	21.7	24.8	26.7	25.4	23.6	19.5	13.8	8.4	(29)	
		MCDB	7.3	10.9	18.3	22.6	26.9	29.8	31.2	29.8	28.2	23.2	17.9	9.3	(30)	
	5%	WB	2.6	5.1	12.1	15.6	20.2	23.7	25.6	24.4	22.4	17.6	11.3	5.2	(31)	
		MCDB	4.3	7.5	16.0	21.0	25.0	28.4	30.0	28.5	26.6	20.5	14.3	7.5	(32)	
	10%	WB	1.0	2.8	9.0	13.7	18.9	22.5	24.6	23.5	21.0	15.6	8.8	2.9	(33)	
		MCDB	2.2	4.5	12.8	18.6	23.1	27.0	28.7	27.1	24.8	19.5	12.0	4.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.3	9.4	10.3	12.0	11.5	11.2	11.0	11.2	13.1	12.3	10.7	9.1	(35)	
		MCDBR	12.6	12.7	15.5	17.0	14.1	13.1	12.0	12.7	14.9	15.9	15.6	12.5	(36)	
	5% WB	MCWBR	9.7	9.5	9.7	9.5	6.9	6.3	6.1	6.9	7.5	8.8	9.9	9.7	(37)	
		MCWBR	11.6	12.4	14.3	14.1	12.0	11.3	10.9	11.2	12.3	12.2	14.0	11.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.287	0.308	0.327	0.384	0.413	0.425	0.441	0.423	0.391	0.344	0.301	0.287	(40)	
		taud	2.415	2.358	2.408	2.272	2.260	2.272	2.209	2.268	2.311	2.437	2.499	2.436	(41)	
	Ebn at Noon		864	896	921	885	864	851	833	837	839	845	845	832	(42)	
		Edh at Noon	78	97	104	129	134	133	140	128	114	89	72	70	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.90	2.91	3.79	4.74	5.60	6.22	6.32	5.45	4.53	3.03	2.06	1.56	(44)	
	RadStd		0.19	0.21	0.37	0.39	0.43	0.56	0.42	0.36	0.32	0.37	0.17	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (48 neighbors)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page