

WEBSTER CITY, IA, USA

WMO: 725478

Lat: 42.436N

Lon: 93.869W

Elev: 1121

StdP: 14.11

Time Zone: -6.00 (NAC)

Period: 95-19

WBAN: 04920

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.1	-2.5	-15.2	2.5	-7.9	-9.4	3.5	-2.0	32.3	16.6	28.7	15.5	8.4	320	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	92.0	76.0	90.0	75.5	86.5	73.0	80.2	88.2	78.0	86.0	76.0	83.9	12.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.5	148.9	85.5	75.2	137.9	83.4	73.1	128.0	81.4	44.7	89.0	42.4	86.0	40.2	84.1	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.8	24.8	21.6	-15.6	98.0	4.9	6.5	-19.1	102.7	-22.0	106.6	-24.7	110.2	-28.2	115.0		
(5)			-16.0	82.9	4.5	3.3	-19.2	85.3	-21.8	87.2	-24.3	89.0	-27.6	91.4	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.9	20.7	23.3	36.0	49.2	61.2	71.3	74.4	71.4	64.3	51.5	37.3	24.5	(6)	(7)
	DBStd	21.49	12.21	12.63	12.18	9.90	8.87	6.40	5.87	5.64	8.40	9.83	10.70	11.75	(7)	(8)
	HDD50	3552	909	749	458	132	12	0	0	0	4	100	397	791	(8)	(9)
	HDD65	6765	1374	1167	899	481	182	17	4	10	113	433	830	1255	(9)	(10)
	CDD50	3145	0	2	25	107	358	638	756	663	433	145	17	1	(10)	(11)
	CDD65	884	0	0	1	6	63	205	295	208	92	14	0	0	(11)	(12)
	CDH74	8705	0	7	14	132	693	2016	2933	1776	962	167	5	0	(12)	(13)
	CDH80	3097	0	5	1	33	226	767	1141	548	329	47	0	0	(13)	(14)
	WSAvg	10.1	11.0	11.2	11.8	12.6	11.8	9.5	7.1	6.3	7.8	10.1	11.3	10.9	(14)	(15)
	PrecAvg	37.8	1.1	1.1	2.2	3.7	5.0	6.1	5.2	4.9	2.8	2.4	1.9	1.2	(15)	(16)
(16) Precipitation	PrecMax	54.8	2.2	2.0	4.7	8.1	8.4	11.7	12.5	13.1	6.3	7.2	4.4	2.6	(16)	(17)
	PrecMin	26.9	0.2	0.2	0.1	1.0	1.8	1.6	1.9	1.0	0.9	0.4	0.0	0.0	(17)	(18)
	PrecStd	7.0	0.5	0.6	1.3	1.8	1.8	3.1	2.8	3.1	1.4	1.6	1.2	0.7	(18)	(19)
															(19)	(20)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.9	58.9	76.1	84.0	91.4	94.7	95.6	92.7	92.9	86.1	72.6	58.8	(20)	(21)
		MCWB	44.6	50.9	59.9	64.0	71.0	76.0	79.5	78.4	72.7	67.7	59.0	52.6	(21)	(22)
	2%	DB	44.7	50.0	66.4	77.3	85.9	90.8	92.6	89.6	88.1	79.0	64.3	49.7	(22)	(23)
		MCWB	39.4	45.6	56.0	60.4	67.3	73.8	78.3	78.5	71.8	63.4	54.7	44.0	(23)	(24)
	5%	DB	38.6	44.7	60.8	72.2	81.6	88.1	90.0	85.9	83.8	72.8	58.6	44.6	(24)	(25)
		MCWB	35.5	40.5	53.1	57.0	65.0	72.4	77.4	75.3	70.0	61.1	49.8	40.5	(25)	(26)
	10%	DB	35.8	38.9	54.1	66.4	77.1	84.3	86.3	82.2	80.5	68.0	53.8	39.0	(26)	(27)
		MCWB	33.7	35.7	47.9	54.3	62.6	70.6	74.8	72.8	67.4	57.9	47.0	35.8	(27)	(28)
	0.4%	WB	45.1	51.1	62.8	66.6	75.0	80.3	84.6	82.7	77.3	71.1	61.1	53.7	(28)	(29)
		MCDB	53.0	57.0	73.0	78.3	86.0	90.4	92.2	90.4	87.0	82.5	70.0	57.9	(29)	(30)
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	39.4	45.1	57.7	62.6	70.8	77.6	81.5	79.0	74.6	66.8	55.9	44.6	(30)	(31)
		MCDB	43.7	48.9	65.0	73.8	81.3	86.8	88.6	86.8	82.7	75.2	63.7	47.5	(31)	(32)
	5%	WB	35.9	40.3	53.2	59.2	68.0	75.3	78.8	76.8	72.3	62.8	51.0	39.7	(32)	(33)
		MCDB	38.7	44.2	60.3	69.0	77.7	84.5	86.5	83.7	79.9	70.1	57.1	43.8	(33)	(34)
	10%	WB	33.4	35.9	47.4	55.7	65.5	72.9	76.8	74.5	69.7	59.1	46.6	36.1	(34)	(35)
		MCDB	35.2	38.9	53.9	64.4	74.2	81.6	84.5	81.0	76.7	66.7	52.6	39.1	(35)	(36)
	5% DB	MDBR	15.8	16.3	17.5	21.7	21.0	20.2	20.0	19.6	23.3	21.5	18.4	15.3	(36)	(37)
		MCDBR	19.7	20.0	27.6	31.9	26.7	23.6	21.7	21.3	26.9	28.0	27.9	21.0	(37)	(38)
		MCWBR	16.0	15.7	17.8	17.4	12.6	11.1	11.9	13.5	13.8	15.7	18.2	16.9	(38)	(39)
		MCWBR	19.9	18.5	25.6	26.4	22.7	20.7	19.3	19.5	21.7	23.1	25.9	19.9	(39)	(40)
(40) Clear-Sky Solar Irradiance	taub		0.284	0.294	0.320	0.374	0.403	0.422	0.432	0.416	0.387	0.341	0.297	0.278	(40)	(41)
		taud	2.412	2.396	2.427	2.305	2.292	2.285	2.233	2.278	2.319	2.442	2.505	2.452	(41)	(42)
	Ebn at Noon		274	290	294	283	277	271	266	267	267	268	268	267	(42)	(43)
		Edh at Noon	24	29	32	39	41	42	43	40	36	28	22	22	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg		595	920	1200	1504	1777	1971	2023	1729	1418	948	641	481	(44)	(45)
	RadStd		62	71	119	134	131	163	119	117	97	121	48	38	(45)	(46)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (55 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page