

YORK, NE, USA

WMO: 725512

Lat: 40.894N

Lon: 97.626W

Elev: 507

StdP: 95.38

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 14989

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.1	-17.2	-23.9	0.5	-18.5	-21.2	0.6	-15.8	14.0	-1.3	12.4	-3.9	3.9	0	0.594

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	34.1	23.8	32.7	23.4	32.0	23.2	26.2	31.7	25.2	30.4	24.2	29.3	5.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.8	21.1	29.7	23.7	19.7	28.6	22.6	18.4	27.4	84.0	32.2	80.4	30.2	75.8	29.2	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.5	11.1	9.6	-24.4	36.8	1.9	1.6	-25.7	38.0	-26.8	38.9	-27.8	39.8	-29.2	41.0		
(5)			-24.2	28.4	2.0	0.8	-25.7	29.0	-26.9	29.5	-28.0	29.9	-29.5	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	-4.0	-2.6	4.8	10.3	16.6	22.4	24.1	22.5	18.9	11.3	4.2	-2.8	(6)
(7)		DBStd	11.35	6.47	6.65	6.57	5.52	5.16	3.49	3.11	3.11	4.46	5.35	5.67	6.16	(7)
(8)		HDD10.0	1680	434	355	186	62	8	0	0	0	1	48	187	398	(8)
(9)		HDD18.3	3411	693	588	420	246	96	7	2	4	46	227	426	657	(9)
(10)		CDD10.0	1872	0	1	25	71	212	371	436	388	269	88	12	0	(10)
(11)		CDD18.3	560	0	0	1	4	42	128	179	133	64	8	0	0	(11)
(12)		CDH23.3	5811	0	0	27	81	504	1337	1843	1237	677	100	5	0	(12)
(13)		CDH26.7	2304	0	0	6	22	188	541	798	474	244	31	1	0	(13)
(14)	Wind	WSAvg	4.5	4.6	4.7	5.3	5.5	5.2	4.4	3.3	3.2	3.9	4.6	4.8	4.5	(14)
(15)	Precipitation	PrecAvg	717	18	20	52	69	111	103	93	79	70	45	37	20	(15)
(16)		PrecMax	1026	54	69	240	170	229	362	247	255	212	150	155	94	(16)
(17)		PrecMin	440	0	2	1	4	21	21	13	6	2	0	0	0	(17)
(18)		PrecStd	152	14	15	45	41	53	67	53	45	52	36	34	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.7	19.1	27.1	29.8	34.0	36.1	36.3	35.2	33.7	31.1	23.7	14.0	(19)
MCWB			7.2	10.4	15.5	17.0	19.9	22.8	24.9	24.6	21.9	20.1	13.3	8.0	(20)	
2%		DB	9.9	13.7	22.6	25.2	31.1	33.6	34.0	32.9	32.1	26.0	19.1	11.2	(21)	
		MCWB	5.2	7.6	13.0	14.7	19.3	23.0	25.0	24.6	21.8	16.4	11.7	6.9	(22)	
5%		DB	7.2	9.9	18.9	22.7	28.7	32.2	32.7	31.3	29.8	22.9	16.1	8.0	(23)	
		MCWB	3.4	5.9	12.2	14.0	18.4	22.7	24.7	24.2	21.5	15.0	9.8	4.5	(24)	
10%		DB	4.0	6.3	15.2	19.9	26.2	29.8	31.2	29.0	27.5	20.9	12.8	5.1	(25)	
		MCWB	1.7	3.3	9.8	12.8	17.5	21.5	24.2	23.1	19.6	14.3	7.9	2.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	11.6	17.5	18.8	22.6	26.3	27.8	27.6	24.2	21.1	15.1	10.3	(27)
MCDWB			13.1	17.0	21.6	25.3	29.3	32.0	33.2	33.4	30.1	26.9	19.7	12.7	(28)	
2%		WB	5.4	7.9	15.2	16.8	21.2	24.8	26.4	26.0	23.1	18.8	12.5	6.7	(29)	
		MCDWB	9.4	12.7	20.1	22.7	27.5	30.4	32.0	31.3	28.7	23.4	18.4	10.4	(30)	
5%		WB	3.7	5.5	12.7	15.3	20.0	23.7	25.5	24.8	22.1	16.7	10.4	4.7	(31)	
		MCDWB	6.5	9.7	18.1	21.0	25.7	29.3	30.9	29.7	27.8	21.3	15.0	8.1	(32)	
10%		WB	2.1	3.5	10.1	13.7	18.7	22.6	24.6	23.8	21.0	14.7	8.3	2.8	(33)	
		MCDWB	4.4	6.2	15.9	19.0	24.3	28.2	29.8	28.2	25.9	19.5	12.9	5.2	(34)	
(35)	Mean Daily Temperature Range	MDBR	10.3	10.8	12.8	13.1	12.6	12.2	11.7	11.7	13.4	13.1	12.6	10.3	(35)	
5% DB		MCDBR	14.1	16.5	18.6	17.4	16.5	14.3	13.5	14.0	14.9	16.9	17.3	14.2	(36)	
		MCWBR	9.8	10.6	10.2	9.3	6.8	6.3	6.6	6.8	6.5	8.9	10.1	10.1	(37)	
		MCDBR	13.2	15.5	15.6	14.8	13.4	12.5	11.9	12.0	12.5	13.4	15.9	13.5	(38)	
5% WB		MCWBR	9.4	10.3	9.1	8.7	6.5	6.6	6.6	6.8	6.2	8.3	10.0	9.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.277	0.285	0.315	0.354	0.379	0.390	0.405	0.404	0.368	0.327	0.286	0.275	(40)	
taud		2.477	2.484	2.432	2.343	2.346	2.367	2.367	2.328	2.329	2.382	2.484	2.515	2.486	(41)	
Ebn at Noon		893	938	940	918	898	885	866	858	868	874	875	865	(42)		
Edh at Noon		75	87	103	121	123	121	125	121	107	86	72	69	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2.17	3.03	4.04	5.10	5.95	6.76	6.67	5.80	4.71	3.38	2.40	1.82	(44)	
(45)		RadStd	0.19	0.21	0.33	0.30	0.38	0.41	0.36	0.34	0.30	0.35	0.17	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page