

KEARNEY, NE, USA

WMO: 725526

Lat: 40.733N

Lon: 99.000W

Elev: 649

StdP: 93.77

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 14905

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.7	-16.2	-24.9	0.4	-16.7	-21.4	0.6	-15.3	14.8	-1.3	12.9	-2.0	4.5	320	0.646

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	34.5	22.8	32.8	22.6	31.9	22.3	25.0	31.7	24.1	30.6	23.2	29.6	6.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.8	19.0	29.3	22.2	18.3	28.7	21.2	17.1	27.6	80.5	31.7	75.9	30.7	72.2	29.4	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.7	12.0	10.8	-23.0	37.4	2.7	1.3	-25.0	38.3	-26.6	39.1	-28.1	39.8	-30.1	40.8		
			-23.6	26.9	2.7	1.1	-25.6	27.7	-27.1	28.3	-28.7	28.9	-30.7	29.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	-3.2	-1.5	4.4	9.9	15.9	21.8	24.3	22.9	18.8	11.2	3.8	-2.1	(6)
	DBStd	11.07	6.44	6.90	6.48	5.45	4.73	3.79	3.06	2.98	4.52	5.18	5.70	5.90	(7)
	HDD10.0	1618	408	324	192	66	7	0	0	0	2	47	197	375	(8)
	HDD18.3	3377	667	556	432	256	106	12	2	3	48	227	436	633	(9)
	CDD10.0	1831	0	2	19	64	189	353	444	399	266	83	11	0	(10)
	CDD18.3	547	0	0	1	4	29	116	188	143	62	5	0	0	(11)
	CDH23.3	5604	0	1	17	84	363	1204	1898	1277	668	89	3	0	(12)
(13)	CDH26.7	2283	0	0	2	22	121	487	863	514	249	23	0	0	(13)
(14) Wind	WSAvg	5.1	4.8	5.2	5.7	6.2	5.7	5.2	4.2	4.0	4.8	5.1	5.1	4.7	(14)
(15) Precipitation	PrecAvg	662	13	13	37	57	113	107	87	91	46	62	24	13	(15)
	PrecMax	979	36	38	82	121	208	194	312	189	122	236	62	43	(16)
	PrecMin	392	2	0	0	12	30	39	2	25	7	8	0	2	(17)
	PrecStd	136	9	10	26	28	52	46	69	40	32	48	19	11	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.0	19.9	26.0	29.1	32.8	36.1	37.4	36.1	34.1	29.8	22.9	15.9	(19)
		MCWB	7.3	9.6	13.1	15.2	18.9	22.0	23.5	22.9	20.4	17.1	12.0	7.2	(20)
	2%	DB	11.9	15.1	22.2	26.0	30.1	33.2	34.9	33.1	32.1	26.0	19.0	12.1	(21)
		MCWB	5.3	7.1	11.9	14.5	19.1	22.2	23.8	23.3	20.7	15.4	10.2	6.1	(22)
	5%	DB	8.0	11.7	18.0	22.6	27.5	32.0	32.9	32.0	29.6	22.7	16.1	8.7	(23)
		MCWB	3.2	5.9	10.4	13.4	17.5	21.7	23.6	23.2	20.0	14.0	8.7	4.1	(24)
	10%	DB	5.9	7.9	15.0	19.4	24.9	29.1	31.7	29.2	27.4	20.2	12.7	6.3	(25)
		MCWB	2.0	3.7	8.6	11.9	16.5	20.6	23.0	22.1	18.7	13.1	7.3	2.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.5	10.4	15.8	17.3	21.7	25.2	26.5	25.9	23.5	19.3	13.7	9.6	(27)
		MCDB	15.3	18.2	21.5	24.2	28.4	31.7	33.6	32.0	30.2	25.8	19.4	15.3	(28)
	2%	WB	5.3	7.8	13.3	15.7	20.2	23.7	25.2	24.7	22.0	17.2	11.3	6.0	(29)
		MCDB	10.6	14.0	19.4	23.2	27.4	30.6	32.2	30.8	29.1	22.7	17.4	11.3	(30)
	5%	WB	3.6	5.9	11.1	14.1	18.9	22.4	24.4	23.8	20.9	15.3	9.5	4.3	(31)
		MCDB	7.8	11.3	17.7	21.8	25.8	29.7	31.2	29.8	27.6	20.7	15.6	8.6	(32)
	10%	WB	2.0	3.8	8.9	12.6	17.4	21.3	23.6	22.7	19.8	13.7	7.4	2.5	(33)
		MCDB	5.3	7.9	15.3	18.7	23.2	28.5	30.2	28.5	25.7	19.4	12.6	6.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.2	11.7	13.4	13.2	12.2	12.3	12.2	12.0	13.6	13.4	12.7	11.0	(35)
		MCDBR	15.3	17.0	19.1	18.3	15.9	15.1	14.6	14.8	16.2	17.6	17.7	15.1	(36)
		MCWBR	10.3	10.7	10.9	9.8	7.6	6.8	7.0	7.0	7.3	9.2	10.6	10.2	(37)
	5% WB	MCDBR	14.6	16.0	17.3	16.3	14.1	13.6	13.2	13.0	14.1	14.6	16.8	14.5	(38)
		MCWBR	10.1	10.4	10.3	9.3	7.4	7.1	7.1	6.9	7.0	8.7	10.5	10.2	(39)
(40) Clear-Sky Solar Irradiance	taub		0.272	0.274	0.300	0.340	0.366	0.381	0.396	0.392	0.357	0.313	0.275	0.266	(40)
	taud		2.494	2.509	2.466	2.370	2.374	2.374	2.363	2.361	2.413	2.519	2.542	2.510	(41)
	Ebn at Noon		903	954	957	932	910	893	875	870	881	893	894	883	(42)
	Edh at Noon		74	84	99	117	120	120	121	117	104	83	70	67	(43)
(44) All-Sky Solar Radiation	RadAvg		2.24	3.07	4.18	5.25	6.07	6.97	6.84	5.95	4.82	3.45	2.48	1.92	(44)
	RadStd		0.20	0.22	0.35	0.29	0.39	0.43	0.29	0.32	0.29	0.34	0.17	0.18	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page