

NORTH OMAHA, NE, USA

WMO: 725530

Lat: 41.367N

Lon: 96.017W

Elev: 406

StdP: 96.54

Time Zone: -6.00 (NAC)

Period: 86-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.2	-17.8	-28.0	0.3	-20.6	-24.0	0.5	-17.2	12.6	-4.4	11.2	-4.5	4.5	310	0.542

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	34.5	23.9	32.7	23.7	31.1	22.8	25.4	31.7	24.6	30.7	23.8	29.7	4.8	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.6	19.3	29.0	22.7	18.3	28.4	21.9	17.4	27.6	80.3	31.7	76.5	30.5	73.4	29.7	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	8.6	7.9	-24.1	36.6	3.6	2.7	-26.7	38.5	-28.8	40.1	-30.8	41.6	-33.4	43.5		
(5)			-24.5	27.1	3.5	0.8	-27.0	27.6	-29.1	28.0	-31.0	28.5	-33.5	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	-2.6	-2.0	5.0	11.2	17.7	22.8	24.3	23.0	18.7	11.3	3.0	-2.5	(6)
(7)		DBStd	11.38	6.34	7.14	6.66	5.94	4.41	3.83	3.37	3.75	4.63	5.51	5.96	6.69	(7)
(8)		HDD10.0	1622	391	335	183	53	3	0	0	2	51	218	387		(8)
(9)		HDD18.3	3323	649	568	415	228	66	8	2	6	52	224	459	646	(9)
(10)		CDD10.0	1948	0	1	29	89	240	384	442	402	262	92	8	0	(10)
(11)		CDD18.3	607	0	0	2	14	45	142	185	150	62	7	0	0	(11)
(12)		CDH23.3	5584	0	0	26	154	371	1375	1758	1324	504	71	0	0	(12)
(13)		CDH26.7	2116	0	0	6	52	94	548	722	514	169	10	0	0	(13)
(14)	Wind	WSAvg	4.0	4.3	4.1	4.7	4.6	4.0	3.6	3.4	3.8	4.0	4.4	4.3	(14)	
(15)	Precipitation	PrecAvg	770	16	15	50	75	104	101	96	84	91	63	34	23	(15)
(16)		PrecMax	1060	41	62	134	181	229	224	245	201	358	136	130	113	(16)
(17)		PrecMin	542	0	0	0	9	14	0	0	16	0	0	0	0	(17)
(18)		PrecStd	151	12	13	42	45	49	59	57	57	67	41	29	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.2	17.7	26.4	31.7	31.3	36.3	36.4	36.8	33.6	28.1	20.2	13.7	(19)
(20)		MCWB	7.3	9.6	15.4	18.8	20.5	23.7	24.4	24.8	21.8	18.3	15.1	7.1		(20)
(21)		2%	DB	11.2	13.0	22.1	27.8	29.2	33.6	34.2	33.6	30.9	25.4	16.7	9.7	(21)
(22)		MCWB	5.5	7.0	12.8	16.9	19.8	23.4	24.4	24.4	21.5	16.6	12.4	5.0		(22)
(23)		5%	DB	8.1	9.8	18.2	24.1	27.2	31.7	32.6	31.4	28.4	22.9	14.2	7.0	(23)
(24)		MCWB	4.2	5.2	11.2	16.0	18.6	22.9	24.3	23.7	20.8	15.2	9.5	3.7		(24)
(25)		10%	DB	5.6	7.0	15.6	21.1	25.3	29.8	30.7	29.5	26.2	20.1	12.0	4.8	(25)
(26)		MCWB	2.4	3.5	10.6	13.8	17.7	21.6	23.7	22.6	19.9	13.8	8.4	2.2		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	9.8	16.5	19.9	23.1	25.5	26.6	26.5	24.1	19.5	16.3	7.6	(27)
(28)		MDCB	12.8	17.0	22.5	29.1	28.6	32.4	32.7	32.7	29.2	26.7	19.0	12.0		(28)
(29)		2%	WB	6.3	7.4	14.5	18.2	21.4	24.5	25.5	25.3	23.0	17.8	13.1	5.7	(29)
(30)		MDCB	10.7	12.7	19.6	25.7	26.9	31.6	31.7	31.6	28.6	23.2	16.0	9.2		(30)
(31)		5%	WB	4.3	5.5	12.5	16.6	20.1	23.4	24.8	24.4	21.9	16.2	10.4	4.0	(31)
(32)		MDCB	7.9	9.6	18.2	22.8	25.3	30.3	30.8	30.1	27.0	21.7	13.6	6.9		(32)
(33)		10%	WB	2.6	3.7	10.4	14.5	18.8	22.4	24.0	23.6	20.8	14.4	8.0	2.3	(33)
(34)		MDCB	5.5	6.7	15.5	20.8	23.5	28.8	29.9	28.7	25.3	19.7	11.8	4.3		(34)
(35)	Mean Daily Temperature Range	MDBR	10.0	9.5	11.1	11.7	10.8	10.5	9.7	9.9	11.0	11.3	9.2	8.6	(35)	
(36)		5% DB	MCDBR	13.6	14.2	15.9	14.7	12.8	12.0	11.6	11.6	12.7	15.0	12.9	11.0	(36)
(37)		MCWBR	9.2	9.3	9.2	7.4	6.6	5.8	5.4	5.2	6.0	8.3	9.1	7.9	(37)	
(38)		5% WB	MCDBR	12.8	13.7	14.3	13.9	11.3	11.3	10.7	10.8	11.3	14.0	11.4	10.6	(38)
(39)		MCWBR	8.8	9.2	8.8	7.3	6.5	6.0	5.7	5.4	6.0	8.6	8.9	8.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.279	0.312	0.328	0.384	0.407	0.412	0.423	0.412	0.373	0.329	0.295	0.282	(40)	
(41)		taud	2.449	2.378	2.399	2.257	2.261	2.306	2.270	2.306	2.373	2.484	2.505	2.457	(41)	
(42)		Ebn at Noon	884	897	922	886	870	864	850	849	862	869	858	848	(42)	
(43)		Edh at Noon	76	96	106	131	134	129	132	124	108	86	72	70	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.99	2.94	3.81	4.88	5.79	6.44	6.50	5.59	4.62	3.22	2.24	1.68	(44)	
(45)		RadStd	0.18	0.17	0.34	0.35	0.43	0.50	0.42	0.37	0.30	0.38	0.15	0.17	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page