

CONVERSE COUNTY AP, WY, USA

WMO: 725686

Lat: 42.796N

Lon: 105.380W

Elev: 1505

StdP: 84.51

Time Zone: -7.00 (NAM)

Period: 99-19

WBAN: 94057

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-22.5	-18.8	-26.0	0.4	-22.6	-22.2	0.6	-18.4	15.4	6.6	14.1	6.3	1.5	310	0.690

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.9	35.2	15.9	33.6	15.9	32.1	15.7	18.4	28.9	17.7	28.0	16.9	27.5	5.5	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.8	13.5	20.8	14.5	12.4	20.1	13.5	11.6	19.7	58.1	28.6	55.4	27.4	53.1	27.2	22.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.7	11.9	10.6	-28.8	37.7	4.3	1.2	-31.9	38.6	-34.4	39.3	-36.9	40.0	-40.0	40.8		
(5)			-28.3	20.2	4.3	0.9	-31.4	20.8	-34.0	21.4	-36.4	21.9	-39.5	22.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.2	-3.1	-3.3	2.8	6.5	11.5	17.7	22.6	21.1	15.7	7.7	1.6	-3.6
	DBStd	10.56	6.32	6.80	5.89	4.85	4.71	3.90	2.95	3.20	4.36	5.37	6.23	6.67
	HDD10.0	1962	408	373	231	121	39	1	0	0	7	104	255	423
	HDD18.3	4007	666	605	483	354	214	57	5	12	101	329	501	681
	CDD10.0	1294	0	1	6	17	87	232	392	345	177	32	4	1
	CDD18.3	299	0	0	0	0	3	38	138	99	21	0	0	0
	CDH23.3	5039	0	0	2	13	149	742	2012	1524	558	39	0	0
	CDH26.7	2373	0	0	0	1	37	319	1060	736	214	6	0	0
Wind	WSAvg	4.4	4.3	4.5	4.9	5.2	4.8	4.4	4.0	4.0	3.9	4.3	4.2	4.3
Precipitation	PrecAvg	351	11	14	24	45	64	53	37	26	28	33	14	10
	PrecMax	527	25	46	69	110	178	115	82	57	76	140	26	25
	PrecMin	235	2	1	5	9	24	13	7	4	2	2	0	1
	PrecStd	70	6	11	16	26	42	31	21	15	17	30	7	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.2	16.0	22.6	25.1	30.5	36.0	37.7	36.1	33.3	27.3	21.4	14.1
		MCWB	4.5	6.6	9.1	10.6	13.9	14.9	17.0	16.6	15.0	11.8	8.5	5.2
	2%	DB	11.3	12.6	18.9	22.5	27.3	32.9	36.0	34.4	31.3	24.0	17.9	11.2
		MCWB	3.6	4.9	7.5	9.6	13.6	15.4	16.6	15.6	14.2	10.6	7.1	3.8
	5%	DB	8.8	9.8	16.1	19.9	24.6	30.5	34.1	32.8	29.3	21.3	15.2	8.8
		MCWB	2.8	3.4	6.4	8.7	12.9	15.2	16.2	15.5	13.4	9.7	6.0	2.6
	10%	DB	6.7	7.3	13.1	17.0	21.8	27.7	32.5	31.2	26.8	18.0	12.4	6.5
		MCWB	1.6	1.9	5.2	7.7	11.9	14.8	16.2	15.3	12.6	8.6	4.7	1.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	6.8	9.7	11.8	16.8	18.9	20.0	18.8	16.9	12.9	9.2	5.6
		MCDB	12.5	14.8	20.7	22.1	26.4	27.8	30.0	29.7	28.8	22.7	19.3	13.2
	2%	WB	4.1	5.1	8.1	10.3	14.9	17.4	18.8	17.9	15.5	11.6	7.7	4.2
		MCDB	10.2	11.9	17.4	19.9	23.3	26.8	29.3	28.5	26.6	21.5	17.5	10.6
	5%	WB	2.9	3.6	6.8	9.2	13.7	16.5	18.0	17.1	14.6	10.4	6.3	2.8
		MCDB	8.3	9.5	15.1	18.4	21.9	26.5	28.5	27.7	25.1	19.8	14.5	8.3
	10%	WB	1.6	2.0	5.5	8.1	12.5	15.6	17.3	16.4	13.7	9.1	5.0	1.6
		MCDB	6.5	6.9	12.8	16.0	20.3	25.2	27.8	27.2	23.6	17.3	12.1	6.4
Mean Daily Temperature Range	5% DB	MDBR	13.4	13.1	14.3	14.4	14.6	16.7	17.9	17.8	17.8	15.6	14.8	13.0
		MCDBR	15.8	15.8	19.1	21.0	19.9	21.2	20.6	20.7	22.1	21.7	19.6	15.2
		MCWBR	9.5	9.4	9.7	9.9	8.3	7.5	6.3	6.3	8.2	10.3	10.6	9.2
	5% WB	MCDBR	14.7	15.0	18.1	18.5	17.4	18.3	17.1	17.3	18.3	19.3	18.8	14.5
		MCWBR	9.2	9.2	9.5	9.3	8.1	7.5	6.0	5.7	7.2	9.4	10.3	9.1
Clear-Sky Solar Irradiance	taub	0.240	0.249	0.271	0.295	0.313	0.322	0.348	0.343	0.308	0.275	0.254	0.243	
	taud	2.581	2.555	2.532	2.484	2.499	2.482	2.440	2.435	2.524	2.595	2.565	2.557	
	Ebn at Noon	938	978	985	976	960	947	918	913	929	931	907	898	
	Edh at Noon	64	78	91	103	105	107	111	108	91	74	64	60	
All-Sky Solar Radiation	RadAvg	2.09	2.95	4.21	5.23	6.10	7.28	7.18	6.22	5.02	3.38	2.25	1.71	
	RadStd	0.10	0.18	0.33	0.34	0.52	0.44	0.28	0.19	0.34	0.28	0.17	0.10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page