

CRAIG-MOFFAT, CO, USA

WMO: 725700

Lat: 40.493N

Lon: 107.524W

Elev: 6190

StdP: 11.69

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24046

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.6	-8.2	-20.2	2.3	-11.9	-14.1	3.2	-7.3	24.4	36.3	20.6	33.6	0.9	280	0.645

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.9	91.2	57.8	89.1	57.4	86.3	56.8	61.6	80.7	60.4	79.6	59.4	78.6	8.5	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.5	85.8	64.5	54.6	80.1	64.5	52.6	74.2	64.7	30.4	80.1	29.5	79.5	28.6	78.2	67.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.3	20.2	17.4	DB	-24.2	95.7	7.5	2.1	-29.6	97.2	-34.0	98.4	-38.2	99.6	-43.6	101.2	(4)
(5)			WB	-23.8	63.9	6.4	1.7	-28.3	65.1	-32.1	66.1	-35.6	67.0	-40.2	68.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.7	16.5	22.5	33.6	42.4	51.1	60.5	68.1	65.7	56.8	43.9	31.6	18.8		
	DBStd	19.23	11.25	10.52	9.01	6.97	6.61	5.81	4.00	3.79	6.31	7.92	9.89	10.95		
	HDD50	4374	1038	770	508	237	68	5	0	0	17	212	551	968		
	HDD65	8320	1503	1190	973	678	431	153	16	36	252	654	1001	1433		
	CDD50	1727	0	0	1	9	102	321	561	488	222	23	0	0		
	CDD65	197	0	0	0	0	1	19	112	59	6	0	0	0		
	CDH74	6593	0	0	0	4	157	1296	2667	1843	602	24	0	0		
	CDH80	2579	0	0	0	0	25	465	1229	707	152	1	0	0		
	WSAvg	5.3	3.6	4.7	5.8	7.2	6.6	6.5	5.6	5.3	5.2	5.1	4.4	3.9		
	PrecAvg	16.5	1.1	1.1	1.2	1.8	1.8	1.1	1.2	1.3	1.7	1.6	1.3	1.1		
(15) Precipitation	PrecMax	21.5	2.5	2.2	2.1	3.7	5.3	3.5	2.7	3.9	4.1	3.3	2.9	3.4		
	PrecMin	10.8	0.0	0.2	0.0	0.8	0.3	0.2	0.0	0.2	0.5	0.4	0.5	0.4		
	PrecStd	3.1	0.6	0.5	0.6	0.7	1.1	0.8	0.6	0.7	0.9	0.7	0.6	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.8	50.4	68.3	73.1	83.2	92.8	95.0	92.4	88.5	77.2	65.1	50.6		
		MCWB	35.4	38.6	45.3	48.3	54.3	57.2	59.0	58.4	57.4	51.0	44.3	38.4		
	2%	DB	39.3	44.9	61.5	69.6	78.4	88.8	92.3	89.8	84.0	72.5	59.4	42.9		
		MCWB	33.1	36.0	42.8	46.4	52.4	56.0	58.3	57.3	54.7	49.2	42.0	35.0		
	5%	DB	36.5	41.0	56.0	65.7	74.6	85.5	90.2	87.4	81.1	68.3	54.2	38.6		
		MCWB	31.8	34.1	40.7	44.8	51.0	55.0	58.1	57.0	53.8	47.7	40.2	32.6		
	10%	DB	33.9	37.5	50.3	61.3	70.6	81.9	87.7	84.2	77.2	63.4	48.3	34.9		
		MCWB	30.7	32.0	38.4	43.3	49.8	54.6	57.9	56.6	52.8	45.7	37.7	30.4		
	0.4%	WB	36.9	39.4	46.2	50.0	57.4	60.3	63.5	63.1	60.2	53.4	45.7	39.2		
		MCDB	41.6	48.4	65.7	70.5	78.1	81.4	81.6	81.4	79.9	70.4	60.9	48.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	34.4	36.6	43.7	47.5	54.2	58.7	62.1	61.4	57.9	51.0	43.0	35.7		
		MCDB	38.1	43.4	59.9	65.6	72.9	81.1	81.4	79.0	75.5	68.2	57.7	41.8		
	5%	WB	32.5	34.7	41.2	45.7	52.4	57.2	61.0	60.2	56.3	49.0	41.0	33.1		
		MCDB	35.9	40.3	54.6	63.1	70.7	79.3	80.7	78.1	73.2	65.2	53.2	37.5		
	10%	WB	30.3	32.8	38.8	44.0	50.7	55.8	59.9	59.1	54.6	46.7	38.3	30.8		
		MCDB	33.8	37.3	49.6	59.5	68.1	77.4	79.5	77.0	71.2	61.4	47.3	34.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	24.4	23.7	25.9	28.1	31.3	37.7	37.9	36.6	36.3	32.2	27.1	23.8		
		MCDBR	23.7	24.2	35.1	39.7	40.9	45.4	43.3	43.2	44.4	42.5	36.6	24.7		
		MCWBR	18.0	16.8	18.5	19.3	18.0	17.7	15.1	15.6	18.4	21.6	21.4	17.5		
		MCDBR	20.9	22.0	32.5	35.4	36.4	38.8	34.4	33.0	34.3	37.5	34.1	22.5		
	5% WB	MCWBR	16.3	15.4	17.6	17.7	16.5	16.0	12.4	12.6	14.7	19.4	20.1	16.2		
(40) Clear-Sky Solar Irradiance	taub		0.235	0.248	0.270	0.304	0.312	0.316	0.346	0.345	0.297	0.271	0.250	0.240		
	taud		2.497	2.508	2.532	2.453	2.493	2.474	2.439	2.433	2.570	2.617	2.584	2.495		
	Ebn at Noon		304	314	316	308	306	303	293	291	301	301	296	292		
	Edh at Noon		23	27	30	34	34	35	36	35	28	24	21	21		
(44) All-Sky Solar Radiation	RadAvg		701	957	1389	1722	2023	2434	2272	1970	1661	1159	768	580		
	RadStd		46	71	132	118	150	144	96	84	104	95	87	52		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page