

RIFLE GARFIELD COUNTY AP, CO, USA

WMO: 725717

Lat: 39.528N

Lon: 107.720W

Elev: 5522

StdP: 11.99

Time Zone: -7.00 (NAM)

Period: 97-19

WBAN: 03016

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-0.2	5.3	-7.1	4.6	4.1	-2.0	6.0	12.2	20.9	33.8	18.2	31.6	2.3	190	0.578

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.7	95.1	58.9	92.7	58.4	90.4	58.0	63.1	82.1	62.1	80.8	61.1	79.7	10.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.2	92.3	65.3	57.1	85.5	65.5	55.0	79.1	66.1	31.3	81.1	30.5	80.4	29.7	79.6	67.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.5	19.7	17.1	DB	-8.9	99.6	4.9	1.5	-12.4	100.7	-15.3	101.6	-18.0	102.4	-21.6	103.6	(4)
(5)			WB	-9.4	65.5	4.8	1.1	-12.9	66.2	-15.7	66.9	-18.3	67.5	-21.8	68.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	25.5	31.5	41.0	47.6	56.8	67.4	74.0	70.9	62.8	49.5	36.9	25.2	(6)
(7)		DBStd	18.05	8.16	7.85	7.30	6.83	7.07	5.91	3.73	3.61	5.98	7.26	8.00	8.62	(7)
(8)		HDD50	2973	760	519	289	122	23	0	0	0	3	95	394	768	(8)
(9)		HDD65	6401	1225	939	745	522	264	43	0	3	104	481	842	1233	(9)
(10)		CDD50	2675	0	0	9	50	234	522	744	647	387	80	2	0	(10)
(11)		CDD65	628	0	0	0	0	10	115	279	186	38	0	0	0	(11)
(12)		CDH74	10696	0	0	2	28	560	2601	3837	2592	1015	61	0	0	(12)
(13)		CDH80	4993	0	0	0	3	144	1257	2065	1190	329	5	0	0	(13)
(14)	Wind	WSAvg	5.3	3.2	4.3	5.8	7.2	6.9	6.9	5.7	5.4	5.3	5.0	3.9	3.4	(14)
(15)	Precipitation	PrecAvg	11.9	0.9	0.7	0.9	0.9	1.1	0.9	0.9	1.1	1.1	1.3	1.0	1.1	(15)
(16)		PrecMax	21.8	2.6	2.2	3.0	2.6	3.2	3.7	2.6	2.6	3.3	3.6	3.6	3.2	(16)
(17)		PrecMin	6.9	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.1	0.1	0.2	0.0	0.0	(17)
(18)		PrecStd	3.5	0.6	0.6	0.7	0.6	0.8	0.9	0.8	0.6	0.9	1.0	0.7	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.4	57.6	72.4	77.6	89.9	97.0	99.4	95.6	91.1	80.7	66.1	51.9	(19)
(20)			MCWB	36.8	42.2	47.2	49.5	55.6	58.5	61.1	59.3	58.5	52.2	46.0	39.5	(20)
(21)		2%	DB	44.4	52.1	66.3	73.0	83.5	93.3	96.6	92.7	87.1	74.8	61.4	45.3	(21)
(22)			MCWB	35.2	39.0	44.8	47.6	53.2	56.8	59.7	58.6	56.4	50.5	43.5	35.5	(22)
(23)		5%	DB	39.6	47.3	62.5	70.1	80.6	90.9	93.4	90.3	83.8	70.7	56.7	41.0	(23)
(24)			MCWB	33.0	37.1	43.0	46.3	52.0	56.1	59.3	58.4	55.0	49.0	41.8	33.4	(24)
(25)		10%	DB	36.9	43.7	57.2	65.7	76.4	88.0	91.1	87.6	80.8	66.1	51.7	36.9	(25)
(26)			MCWB	31.9	35.2	40.8	45.1	50.6	55.5	59.1	58.5	54.5	47.2	39.8	31.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.2	43.2	48.2	51.1	58.0	61.1	64.7	64.3	61.4	55.5	47.5	40.8	(27)
(28)			MCD B	45.5	52.9	68.6	73.4	84.0	85.1	82.7	82.1	80.8	70.2	62.8	49.9	(28)
(29)		2%	WB	36.6	40.3	45.9	49.1	55.0	59.5	63.6	62.8	59.6	53.0	44.7	36.9	(29)
(30)			MCD B	41.3	49.7	64.0	68.6	76.5	85.3	83.0	80.6	75.9	67.9	58.1	42.8	(30)
(31)		5%	WB	34.6	38.0	43.7	47.5	53.3	58.2	62.5	61.8	58.3	51.0	42.7	34.3	(31)
(32)			MCD B	39.0	45.8	59.7	66.1	74.9	84.0	81.9	78.9	74.0	66.3	54.5	39.8	(32)
(33)		10%	WB	32.6	36.0	41.7	46.0	51.7	56.8	61.7	60.8	56.8	49.1	40.6	32.2	(33)
(34)			MCD B	36.7	42.4	55.8	63.2	72.8	82.1	80.9	77.8	72.6	63.6	50.9	36.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	21.2	21.2	26.6	27.7	31.2	36.0	33.7	32.1	32.2	29.1	24.9	20.8	(35)
(36)			MCDBR	22.2	25.7	35.2	37.6	39.0	41.0	38.4	38.0	38.6	37.0	33.2	24.1	(36)
(37)			MCWBR	14.8	14.6	17.2	17.1	15.5	15.6	13.5	13.2	15.0	17.6	17.9	15.7	(37)
(38)		5% WB	MCD BR	18.6	22.1	32.4	33.4	35.1	36.2	29.6	28.6	28.2	31.0	30.1	20.9	(38)
(39)			MCWBR	12.6	12.9	16.1	15.6	14.2	13.7	9.7	9.8	11.0	15.0	16.6	14.0	(39)
(40)																
(41)	Clear-Sky Solar Irradiance	taub	0.249	0.262	0.287	0.317	0.328	0.321	0.362	0.358	0.308	0.288	0.259	0.253	(41)	
(42)		taud	2.509	2.488	2.476	2.428	2.460	2.481	2.410	2.417	2.561	2.584	2.593	2.508	(42)	
(43)		Ebn at Noon	300	309	310	304	301	302	288	287	298	296	295	290	(43)	
		Edh at Noon	23	28	31	35	35	34	36	36	29	25	22	22		
(44)	All-Sky Solar Radiation	RadAvg	769	1019	1466	1796	2043	2447	2208	1915	1669	1202	838	646	(44)	
(45)		RadStd	45	79	129	124	149	154	114	92	98	104	79	56	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (22 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page