

SALT LAKE CITY INTL, UT, USA

WMO: 725720

Lat: 40.778N

Lon: 111.969W

Elev: 4225

StdP: 12.59

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24127

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	15.6	4.0	7.9	16.2	7.9	9.6	22.0	27.1	44.2	24.5	43.2	5.1	140	0.579

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.9	98.3	62.6	95.9	61.9	93.4	61.3	66.2	87.5	65.1	86.6	64.0	85.8	10.6	340

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.3	91.4	72.5	57.7	83.3	73.4	55.4	76.5	74.1	33.1	87.2	32.2	86.1	31.2	85.7	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
24.9	20.9	18.5	5.0	102.3	6.2	2.2	0.6	103.9	-3.0	105.2	-6.5	106.5	-11.0	108.1		
			4.2	68.6	6.0	1.5	-0.1	69.6	-3.6	70.5	-7.0	71.4	-11.4	72.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.1	31.1	35.9	44.8	50.8	60.4	71.3	80.9	78.4	67.8	53.6	41.4	31.5
	DBStd	18.71	8.34	8.32	7.86	7.86	8.50	8.54	5.01	5.16	8.09	8.17	8.64	8.29
	HDD50	2189	586	398	200	84	13	1	0	0	2	53	278	574
	HDD65	5329	1051	815	626	430	195	40	0	1	64	363	707	1037
	CDD50	3685	0	3	39	109	334	640	957	880	536	165	21	1
	CDD65	1350	0	0	0	4	51	228	492	417	148	10	0	0
	CDH74	16452	0	0	3	60	635	2918	6318	4839	1564	115	0	0
	CDH80	8183	0	0	0	8	198	1400	3509	2459	588	21	0	0
Wind	WSAvg	8.2	6.5	7.7	8.7	9.3	8.7	9.0	8.8	9.2	8.6	7.8	7.2	6.8
Precipitation	PrecAvg	15.8	1.3	1.3	1.8	2.1	1.8	0.9	0.7	0.7	1.2	1.4	1.3	1.4
	PrecMax	24.3	3.2	4.9	4.0	4.6	5.2	3.9	2.6	3.7	7.0	3.9	3.3	4.4
	PrecMin	8.7	0.1	0.1	0.2	0.4	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.6	0.7	0.7	0.9	1.1	1.2	0.8	0.6	0.7	1.2	0.9	0.7	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.0	61.9	72.5	80.1	90.0	99.1	102.0	99.1	93.5	83.0	69.0	57.4
		MCWB	43.2	45.5	50.1	54.1	57.5	62.5	63.4	63.5	61.5	56.7	48.5	44.4
	2%	DB	49.7	56.8	67.6	74.6	85.3	95.4	99.5	96.3	89.8	77.1	63.3	52.3
		MCWB	40.2	43.5	48.2	51.4	56.5	59.9	63.0	62.1	59.7	54.2	47.1	41.9
	5%	DB	46.0	52.4	63.2	70.1	81.3	92.0	97.3	94.2	86.7	72.0	59.6	47.4
		MCWB	38.8	42.0	46.4	49.9	55.5	59.5	62.5	61.6	58.8	52.5	45.2	39.4
	10%	DB	42.4	48.4	59.0	65.8	76.7	88.5	94.7	91.8	83.1	67.8	55.2	43.2
		MCWB	36.8	39.8	44.6	48.4	54.4	58.8	62.1	61.2	57.8	50.8	43.6	37.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.4	47.2	52.2	56.4	60.8	65.7	68.0	67.5	66.3	58.6	51.0	45.9
		MCDB	51.8	57.4	68.0	76.3	83.2	93.0	89.0	88.2	85.1	75.9	64.1	54.8
	2%	WB	41.5	44.5	49.7	53.1	58.8	63.2	66.5	65.8	63.5	56.2	48.5	42.8
		MCDB	48.1	54.4	64.5	70.1	79.0	88.5	87.8	86.4	81.7	72.2	59.9	50.2
	5%	WB	39.3	42.4	47.5	51.0	57.0	61.5	65.5	64.5	61.5	54.0	46.4	40.5
		MCDB	45.1	51.1	61.4	66.9	76.0	85.5	87.1	85.7	79.0	68.7	57.0	46.9
	10%	WB	37.1	40.5	45.5	49.4	55.3	60.1	64.5	63.4	59.7	51.8	44.5	37.9
		MCDB	42.0	47.6	57.5	64.0	73.6	83.3	86.3	85.3	78.0	66.1	54.1	42.9
Mean Daily Temperature Range	5% DB	MDBR	13.9	15.8	19.0	19.8	21.7	24.5	24.9	24.3	23.7	21.4	17.8	13.4
		MCDBR	18.1	20.3	24.8	26.5	27.4	28.4	27.5	26.6	27.0	26.3	23.4	17.3
		MCWBR	10.9	10.8	11.9	11.4	9.8	9.5	8.7	8.6	9.6	10.8	11.4	9.9
	5% WB	MCDBR	16.6	18.9	23.8	24.2	25.3	26.3	24.2	23.6	22.9	24.2	22.0	16.2
		MCWBR	10.5	10.5	12.0	11.3	9.9	9.8	8.4	8.4	8.9	10.4	11.4	9.8
Clear-Sky Solar Irradiance	taub		0.256	0.268	0.283	0.319	0.323	0.321	0.348	0.347	0.311	0.288	0.267	0.253
	taud		2.474	2.513	2.546	2.436	2.485	2.527	2.476	2.472	2.554	2.594	2.584	2.509
	Ebn at Noon		293	305	311	303	302	302	292	290	296	294	288	286
	Edh at Noon		23	27	29	35	34	33	34	33	29	24	21	21
All-Sky Solar Radiation	RadAvg		658	933	1387	1761	2073	2466	2368	2059	1690	1173	763	548
	RadStd		62	97	95	110	171	182	108	102	120	85	76	66

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	-0.68	N/A	N/A	N/A	+198
Regional (9 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+122

Nomenclature: See separate page