

HUNT FIELD, WY, USA

WMO: 725760

Lat: 42.815N

Lon: 108.726W

Elev: 1704

StdP: 82.46

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24021

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-21.5	-18.3	-24.6	0.5	-20.1	-21.9	0.6	-16.4	13.0	4.5	10.8	3.8	1.1	120	0.598

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	33.5	14.9	32.0	14.4	30.5	14.1	16.6	28.4	15.8	27.8	15.2	27.4	4.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.0	11.5	19.1	11.6	10.5	19.2	10.3	9.6	19.5	52.6	28.2	50.2	27.8	48.1	27.3	20.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	9.0	7.5	-26.1	36.0	3.3	1.2	-28.5	36.8	-30.5	37.5	-32.3	38.1	-34.8	39.0		
(5)			-26.3	18.0	3.2	0.9	-28.6	18.7	-30.5	19.2	-32.3	19.7	-34.7	20.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-5.2	-3.4	2.6	6.5	11.7	17.6	22.6	21.5	15.9	7.8	0.8	-5.3		
	DBStd	11.00	6.17	6.29	5.57	4.94	4.80	4.22	2.78	2.99	4.76	5.48	6.25	6.36		
	HDD10.0	2116	472	376	234	124	39	3	0	0	11	104	278	475		
	HDD18.3	4151	731	609	488	354	209	62	4	10	98	327	526	733		
	CDD10.0	1318	0	0	4	21	91	231	391	356	187	35	2	0		
	CDD18.3	313	0	0	0	0	4	40	137	108	24	1	0	0		
	CDH23.3	3947	0	0	0	5	84	582	1654	1257	351	14	0	0		
	CDH26.7	1583	0	0	0	0	12	206	750	513	100	1	0	0		
(14) Wind	WSAvg	2.8	2.1	2.4	3.0	3.3	3.2	3.4	3.2	3.1	2.9	2.5	2.3	2.1		
(15) Precipitation	PrecAvg	331	12	16	31	52	62	34	18	13	26	32	20	16		
	PrecMax	542	34	44	118	164	173	134	64	58	119	125	86	51		
	PrecMin	137	0	0	0	5	2	0	0	0	0	0	0	1		
	PrecStd	82	9	11	25	31	44	33	16	12	24	24	17	12		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	13.4	19.8	23.8	28.2	33.8	35.8	34.3	31.7	25.3	18.2	11.8		
		MCWB	3.6	4.7	7.3	9.9	12.5	14.4	15.7	14.9	14.2	11.0	7.1	4.3		
	2%	DB	8.1	10.4	16.5	20.8	25.8	31.3	34.2	32.7	29.4	22.1	15.1	8.7		
		MCWB	2.1	3.4	6.0	8.2	11.7	13.7	15.4	14.5	12.9	9.7	5.9	2.5		
	5%	DB	5.7	7.9	14.1	18.2	23.3	29.1	32.6	31.4	27.5	19.3	12.6	6.2		
		MCWB	0.8	2.0	5.2	7.4	11.1	13.4	14.9	14.2	12.4	8.7	4.7	1.1		
	10%	DB	3.5	5.6	11.6	15.9	20.8	26.9	31.0	29.8	25.1	16.9	10.0	3.5		
		MCWB	-0.6	0.4	4.0	6.4	10.2	13.0	14.6	13.9	11.6	7.5	3.5	-0.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	5.3	7.9	10.5	14.5	16.6	18.0	17.0	15.8	11.8	7.8	4.7		
		MCDB	9.3	11.9	18.2	22.3	24.4	28.2	29.0	29.3	27.1	22.1	16.6	11.3		
	2%	WB	2.4	3.8	6.5	9.0	12.7	15.5	16.9	16.1	14.3	10.4	6.2	2.8		
		MCDB	7.5	10.2	15.4	19.1	22.7	27.2	28.7	28.0	25.5	20.4	14.2	8.4		
	5%	WB	1.0	2.1	5.4	7.8	11.7	14.6	16.3	15.4	13.3	9.2	5.0	1.2		
		MCDB	5.4	7.4	13.6	17.3	21.6	25.9	28.2	27.7	24.2	18.2	12.1	5.9		
	10%	WB	-0.4	0.6	4.1	6.7	10.7	13.6	15.6	14.7	12.4	8.0	3.7	-0.4		
		MCDB	3.4	5.1	11.1	15.2	19.8	24.7	27.8	26.9	23.0	16.0	9.9	3.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.6	11.1	12.3	12.7	13.0	15.0	16.0	15.7	14.7	13.0	11.7	10.4		
		MCDBR	13.2	13.6	15.6	16.6	16.5	18.0	17.8	17.4	17.3	16.5	14.8	13.2		
		MCWBR	8.6	8.2	8.1	8.0	7.3	7.4	6.7	6.6	7.2	7.9	8.1	8.5		
		MCDBR	12.8	13.1	14.9	15.7	15.2	16.2	15.7	15.8	15.2	15.4	14.5	12.8		
	5% WB	MCWBR	8.6	8.2	8.0	7.8	7.1	7.4	6.2	6.1	6.4	7.5	8.2	8.4		
(40) Clear-Sky Solar Irradiance	taub		0.236	0.242	0.261	0.308	0.318	0.315	0.343	0.332	0.300	0.267	0.245	0.236		
	taud		2.521	2.524	2.514	2.404	2.437	2.475	2.426	2.445	2.528	2.596	2.573	2.525		
	Ebn at Noon		939	986	996	961	953	953	922	924	938	940	920	906		
	Edh at Noon		67	80	92	112	111	108	112	106	90	74	64	61		
(44) All-Sky Solar Radiation	RadAvg		2.14	3.14	4.43	5.52	6.33	7.53	7.28	6.35	5.14	3.50	2.34	1.74		
	RadStd		0.14	0.20	0.26	0.32	0.53	0.47	0.31	0.20	0.35	0.23	0.17	0.12		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page