

JACKSON HOLE, WY, USA

WMO: 725776

Lat: 43.600N

Lon: 110.733W

Elev: 6419

StdP: 11.59

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24166

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.9	-8.7	-20.5	2.3	-12.2	-15.0	3.1	-7.9	29.0	21.4	25.5	23.6	6.3	20	0.719

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.6	84.1	55.6	81.5	54.7	79.0	54.0	58.7	76.8	57.1	75.3	55.7	74.1	10.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.8	75.5	61.7	50.6	69.5	61.2	48.1	63.1	61.0	28.3	76.3	27.2	75.5	26.3	73.3	65.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.2	20.6	18.4	DB	-23.5	88.2	5.2	3.0	-27.2	90.4	-30.3	92.1	-33.2	93.8	-37.0	95.9	(4)
(5)			WB	-22.9	61.5	3.9	2.0	-25.7	62.9	-28.0	64.1	-30.2	65.2	-33.0	66.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.5	16.1	17.2	26.5	36.7	45.7	52.8	61.1	59.6	50.9	39.0	26.9	16.4		
	DBStd	17.98	11.41	11.10	8.40	6.54	6.73	6.03	4.66	4.27	6.72	7.40	9.30	11.34		
	HDD50	5455	1050	918	727	400	165	42	2	1	69	347	692	1042		
	HDD65	10044	1515	1338	1192	850	597	365	135	173	422	808	1142	1507		
	CDD50	906	0	0	0	0	33	127	345	299	97	5	0	0		
	CDD65	20	0	0	0	0	0	0	14	6	0	0	0	0		
	CDH74	1870	0	0	0	0	20	126	924	670	130	0	0	0		
	CDH80	411	0	0	0	0	2	10	252	136	11	0	0	0		
	WSAvg	7.3	7.6	7.9	8.6	8.3	7.9	7.2	6.7	6.5	6.4	7.1	6.7	6.8		
	PrecAvg	22.0	2.6	1.9	1.9	1.7	2.0	1.9	1.1	1.3	1.4	1.7	2.1	2.8		
(15) Precipitation	PrecMax	30.2	4.6	4.9	4.3	2.5	3.9	4.3	3.2	2.3	3.0	3.1	4.7	7.6		
	PrecMin	15.4	0.6	0.7	0.7	0.5	0.4	0.6	0.2	0.3	0.3	0.2	0.4	1.1		
	PrecStd	4.4	1.2	0.8	0.9	0.6	1.0	1.1	0.8	0.6	0.6	0.8	1.0	1.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.8	41.8	52.1	65.7	76.6	81.4	89.9	87.7	81.3	70.5	55.2	41.7		
		MCWB	34.6	35.1	39.0	45.8	52.0	54.8	57.8	56.8	53.6	47.3	41.3	34.2		
	2%	DB	37.0	38.3	45.3	61.1	70.4	77.9	85.8	83.5	78.0	64.2	50.0	37.5		
		MCWB	32.6	33.0	35.2	42.5	50.2	53.6	56.1	54.8	52.5	45.0	39.1	32.9		
	5%	DB	35.1	36.1	42.2	54.9	66.1	74.3	82.3	81.1	74.1	59.8	45.2	35.7		
		MCWB	31.3	31.7	33.8	40.6	48.0	52.8	55.7	54.0	50.6	43.2	36.3	32.0		
	10%	DB	32.5	33.7	38.8	50.2	62.9	71.3	79.6	78.6	70.2	54.6	40.7	32.9		
		MCWB	29.7	30.2	32.4	38.9	46.3	51.7	55.0	53.5	49.8	41.1	34.4	30.0		
	0.4%	WB	36.2	35.5	39.0	46.5	54.7	57.1	61.2	59.8	56.9	48.8	42.3	36.5		
		MCDB	39.0	39.9	49.5	63.1	72.5	76.0	79.4	77.3	73.5	64.8	52.5	39.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	33.4	33.6	36.4	43.5	51.4	55.1	59.4	57.7	54.5	46.4	39.5	33.7		
		MCDB	36.5	37.4	42.7	58.4	67.3	73.4	77.6	75.7	71.8	61.6	47.6	37.2		
	5%	WB	31.8	32.2	34.8	41.3	49.3	53.7	58.0	56.4	52.7	44.3	37.1	32.0		
		MCDB	34.6	35.6	41.0	53.6	63.5	71.7	76.3	74.8	69.9	57.3	43.4	34.9		
	10%	WB	29.6	30.1	33.1	39.3	47.1	52.2	56.7	55.0	50.5	42.0	34.9	29.9		
		MCDB	31.8	33.0	38.6	48.6	60.0	69.3	74.9	73.3	66.8	53.6	40.3	32.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.7	19.8	19.9	21.4	25.5	28.9	34.6	35.5	32.1	26.4	20.2	17.8		
		MCDBR	15.3	16.6	22.7	32.7	34.6	37.5	40.6	41.3	40.9	37.6	26.6	14.8		
		MCWBR	12.1	12.8	15.0	17.6	16.9	17.9	17.8	18.1	19.0	20.8	16.7	11.5		
		MCDBR	12.6	15.0	20.1	28.6	31.0	34.2	34.2	34.4	35.2	33.1	23.6	13.1		
	5% WB	MCWBR	10.5	11.9	13.8	15.8	15.6	16.6	15.8	15.9	16.8	18.7	15.2	10.8		
(40) Clear-Sky Solar Irradiance	taub		0.235	0.246	0.262	0.298	0.305	0.312	0.327	0.333	0.302	0.281	0.251	0.233		
	taud		2.352	2.311	2.331	2.363	2.489	2.515	2.496	2.457	2.549	2.569	2.517	2.403		
	Ebn at Noon		292	306	313	307	306	303	297	292	296	291	285	282		
	Edh at Noon		24	30	35	37	33	33	33	33	28	24	21	21		
(44) All-Sky Solar Radiation	RadAvg		587	871	1271	1648	1859	2207	2306	1948	1525	966	596	443		
	RadStd		58	104	109	136	194	197	121	115	135	87	64	51		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page