

POCATELLO, ID, USA

WMO: 725780

Lat: 42.920N

Lon: 112.571W

Elev: 1357

StdP: 86.05

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24156

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.0	-15.1	-21.2	0.7	-17.6	-18.1	0.9	-13.7	15.1	2.8	13.2	2.3	1.5	20	0.664

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	34.9	16.4	33.3	16.0	31.7	15.5	18.5	30.3	17.5	29.3	16.6	28.6	4.5	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.9	12.5	21.5	13.3	11.2	21.2	12.0	10.3	20.8	57.5	29.9	54.2	29.1	51.3	28.4	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
12.8	11.5	10.3		-22.0	37.4	3.5	1.1	-24.5	38.2	-26.6	38.8	-28.6	39.5	-31.2	40.3	
				-22.3	20.7	3.5	1.5	-24.8	21.8	-26.8	22.7	-28.8	23.5	-31.3	24.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	-3.3	-1.2	4.0	7.6	12.4	17.1	22.0	20.8	15.6	8.4	2.1	-3.3
	DBStd	9.72	5.44	5.14	4.17	3.85	4.05	3.83	2.68	2.78	3.97	4.44	4.91	5.51
	HDD10.0	1771	412	314	191	91	22	2	0	0	6	82	240	412
	HDD18.3	3814	669	547	445	321	188	66	5	10	98	307	488	670
	CDD10.0	1249	0	0	4	19	96	214	372	336	173	33	2	0
	CDD18.3	254	0	0	0	0	3	28	119	88	16	1	0	0
	CDH23.3	4947	0	0	0	15	148	678	1969	1620	489	28	0	0
	CDH26.7	2243	0	0	0	2	35	262	997	778	166	5	0	0
Wind	WSAvg	4.2	4.1	4.4	4.8	5.2	4.5	4.3	3.7	3.7	3.6	4.1	4.2	4.1
Precipitation	PrecAvg	303	27	24	31	30	35	25	15	16	22	25	27	28
	PrecMax	516	82	79	76	84	84	102	58	101	87	82	72	86
	PrecMin	136	5	3	2	2	5	0	0	0	0	0	0	2
	PrecStd	80	16	16	18	18	21	22	15	17	19	18	14	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	13.5	20.3	25.3	30.2	34.7	37.4	36.1	32.9	26.6	18.2	11.1
		MCWB	5.2	6.7	8.9	11.9	14.5	15.9	17.8	16.4	16.2	12.6	8.7	6.1
	2%	DB	7.3	10.1	17.1	21.9	27.1	31.9	35.5	34.5	30.7	23.1	14.9	8.7
		MCWB	3.6	5.2	7.9	10.0	13.4	15.6	16.9	15.8	14.5	11.3	7.4	4.6
	5%	DB	5.3	7.9	14.3	19.0	24.6	29.8	33.9	33.0	28.6	20.5	12.4	6.4
		MCWB	2.4	4.0	6.5	8.9	12.4	15.2	16.5	15.5	13.7	10.2	6.2	3.3
	10%	DB	3.7	5.9	11.6	16.3	22.0	27.5	32.2	31.3	26.3	17.7	10.1	4.2
		MCWB	1.5	2.9	5.5	7.7	11.5	14.3	16.1	15.1	12.9	8.8	5.2	2.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	7.3	10.0	12.3	15.7	18.3	20.4	18.9	18.4	13.6	9.9	6.7
		MCDB	9.0	12.1	17.7	24.3	26.4	30.7	31.3	30.6	26.9	24.1	15.4	10.4
	2%	WB	4.0	5.7	8.4	10.6	14.2	16.9	19.0	17.7	16.1	12.3	8.0	5.1
		MCDB	6.7	9.3	15.8	20.0	24.2	29.0	30.9	29.3	26.2	20.9	13.7	8.1
	5%	WB	2.7	4.5	7.2	9.4	13.1	15.8	18.0	16.8	15.0	10.9	6.7	3.6
		MCDB	4.9	7.5	13.4	17.7	22.8	27.8	30.1	28.9	25.0	18.7	11.6	6.1
	10%	WB	1.5	3.0	5.9	8.2	12.0	14.8	17.1	16.0	13.8	9.6	5.5	2.0
		MCDB	3.4	5.7	11.1	15.3	20.6	25.9	29.1	28.3	24.0	16.7	9.6	4.0
Mean Daily Temperature Range	5% DB	MDBR	8.4	9.2	11.6	13.2	14.8	16.8	19.3	19.6	17.9	14.7	11.4	8.3
		MCDBR	9.7	11.0	16.3	19.2	20.0	21.8	22.6	22.6	22.7	20.1	15.7	9.3
		MCWBR	6.7	7.1	9.1	9.5	8.7	8.9	8.5	8.5	9.5	10.0	9.3	6.3
	5% WB	MCDBR	8.4	10.2	14.9	16.9	18.1	20.4	19.8	19.4	18.7	17.6	14.1	8.7
		MCWBR	6.0	6.8	8.6	8.6	8.1	8.6	7.9	7.7	8.0	9.0	8.7	6.0
Clear-Sky Solar Irradiance	taub	0.246	0.257	0.270	0.296	0.312	0.314	0.330	0.328	0.302	0.278	0.257	0.245	
	taud	2.477	2.531	2.584	2.495	2.498	2.522	2.487	2.471	2.544	2.595	2.590	2.534	
	Ebn at Noon	919	964	988	974	959	955	935	928	935	927	903	892	
	Edh at Noon	70	79	86	102	105	103	105	104	89	74	63	61	
All-Sky Solar Radiation	RadAvg	1.72	2.64	3.98	5.33	6.45	7.53	7.52	6.50	5.16	3.43	2.08	1.39	
	RadStd	0.21	0.31	0.29	0.35	0.60	0.56	0.35	0.32	0.33	0.23	0.18	0.19	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	-0.39	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page