

IDAHO FALLS, ID, USA

WMO: 725785

Lat: 43.519N

Lon: 112.064W

Elev: 4733

StdP: 12.35

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24145

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.5	0.4	-10.7	3.7	-4.9	-5.0	5.0	1.4	29.2	33.6	26.7	31.4	5.4	0	0.671

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.8	92.2	60.9	89.7	60.5	86.9	59.7	64.9	83.6	63.1	82.0	61.6	81.5	10.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.8	88.5	71.4	56.5	81.1	69.1	54.3	75.0	68.0	32.3	83.3	30.8	81.8	29.6	81.4	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
27.1	24.2	20.7	-13.0	97.0	7.7	2.0	-18.5	98.4	-23.0	99.6	-27.3	100.7	-32.8	102.2	
			DB												
			WB	-13.5	69.4	7.4	2.3	-18.8	71.0	-23.1	72.3	-27.3	73.6	-32.7	75.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.9	20.9	25.3	36.6	44.9	53.1	61.0	69.4	67.1	58.2	45.4	33.5	22.4
	DBStd	18.27	10.02	9.84	8.24	6.67	7.02	6.73	4.14	4.61	7.05	7.72	9.00	10.05
	HDD50	3796	903	693	417	180	49	6	0	0	17	180	496	855
	HDD65	7621	1368	1113	879	603	372	152	12	32	218	606	946	1320
	CDD50	1949	0	0	3	28	145	337	602	531	263	39	1	0
	CDD65	295	0	0	0	0	3	32	149	97	14	0	0	0
	CDH74	6918	0	0	0	18	189	926	2833	2288	638	26	0	0
	CDH80	2793	0	0	0	1	37	306	1293	972	180	4	0	0
Wind	WSAvg	8.7	7.6	8.7	9.8	10.6	9.9	9.6	8.2	7.9	7.8	8.4	8.5	7.9
Precipitation	PrecAvg	10.6	0.7	0.7	0.8	1.0	1.4	1.2	0.6	0.7	0.8	0.8	0.9	0.8
	PrecMax	15.8	2.4	2.4	1.8	2.5	4.3	3.1	1.9	2.6	2.7	2.8	2.4	2.0
	PrecMin	5.7	0.0	0.1	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.5	0.4	0.6	0.4	0.7	1.0	0.8	0.5	0.6	0.7	0.6	0.6	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.7	51.3	67.4	76.7	84.1	91.6	96.2	94.8	89.4	77.7	62.7	48.6
		MCWB	38.1	42.3	47.3	52.2	56.3	60.2	62.5	60.2	59.2	53.8	46.5	41.1
	2%	DB	38.6	45.4	60.9	70.6	79.4	87.3	92.9	91.5	84.9	71.7	56.3	43.2
		MCWB	35.2	38.4	44.4	49.0	55.2	59.4	62.0	59.8	56.7	51.4	43.9	38.1
	5%	DB	36.1	41.1	55.1	65.5	74.9	83.6	90.4	89.2	81.5	66.1	51.6	38.9
		MCWB	33.7	36.1	42.3	47.1	53.6	58.7	61.6	59.3	56.1	49.2	42.1	35.3
	10%	DB	34.0	37.7	50.2	60.8	70.4	79.9	87.7	86.2	77.4	61.3	47.2	36.1
		MCWB	32.3	34.3	40.3	44.9	51.8	57.5	61.1	58.6	54.5	46.8	40.1	33.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.7	42.9	48.3	53.0	59.5	64.9	68.7	64.4	63.3	55.4	47.9	42.3
		MCDB	42.3	51.0	61.2	73.8	77.8	84.0	86.6	84.3	78.0	72.1	58.0	47.4
	2%	WB	35.8	39.4	45.9	50.2	56.7	61.8	66.3	62.8	60.2	52.9	45.2	38.5
		MCDB	37.9	44.1	57.5	67.9	74.5	81.5	84.8	82.8	76.7	67.0	54.8	42.3
	5%	WB	34.0	37.0	43.6	47.9	54.6	59.9	64.4	61.5	58.2	50.6	42.7	35.7
		MCDB	35.6	40.3	54.1	63.4	71.6	79.5	83.0	82.8	75.8	63.8	50.3	38.6
	10%	WB	32.3	34.9	41.2	45.9	52.8	58.3	62.8	60.1	55.9	48.2	40.6	33.4
		MCDB	33.9	37.6	49.4	58.5	68.1	77.1	81.7	80.8	73.4	59.9	47.1	35.7
Mean Daily Temperature Range	5% DB	MDBR	14.7	16.5	19.9	24.2	26.3	30.0	35.8	35.8	31.7	25.9	19.9	15.1
		MCDBR	14.7	17.2	28.5	34.3	35.2	38.3	40.6	41.3	39.9	34.8	27.1	15.6
		MCWBR	11.9	11.4	15.4	16.7	14.8	15.2	14.9	14.3	15.8	17.4	16.4	11.5
	5% WB	MCDBR	12.6	15.2	25.6	30.4	31.9	34.9	36.4	35.5	32.9	30.1	24.2	14.3
		MCWBR	10.7	10.6	14.6	15.3	13.9	14.6	15.0	13.0	13.6	15.5	15.1	11.1
Clear-Sky Solar Irradiance	taub	0.240	0.252	0.267	0.299	0.310	0.313	0.330	0.329	0.302	0.275	0.255	0.242	
	taud	2.415	2.445	2.556	2.469	2.497	2.512	2.477	2.452	2.533	2.592	2.569	2.494	
	Ebn at Noon	291	306	313	307	305	303	296	293	296	294	285	281	
	Edh at Noon	23	27	28	33	33	33	34	33	28	23	20	20	
All-Sky Solar Radiation	RadAvg	521	818	1248	1676	2019	2351	2401	2053	1603	1048	628	419	
	RadStd	62	93	89	110	187	179	108	102	107	71	54	53	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page