

IDAHO FALLS, ID, USA

WMO: 725785

Lat: 43.519N

Lon: 112.064W

Elev: 1443

StdP: 85.15

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24145

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.9	-17.5	-23.7	0.5	-20.5	-20.5	0.7	-17.0	13.0	0.9	11.9	-0.3	2.4	0	0.671

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.9	33.4	16.1	32.1	15.9	30.5	15.4	18.3	28.7	17.3	27.8	16.4	27.5	4.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.9	12.6	21.9	13.6	11.6	20.6	12.4	10.7	20.0	57.3	28.5	53.9	27.7	51.0	27.5	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.1	10.8	9.3	-25.0	36.1	4.3	1.1	-28.0	36.9	-30.5	37.6	-32.9	38.2	-36.0	39.0
			-25.3	20.8	4.1	1.3	-28.2	21.7	-30.6	22.4	-32.9	23.1	-35.9	24.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-6.2	-3.7	2.6	7.2	11.7	16.1	20.8	19.5	14.6	7.5	0.8	-5.3
	DBStd	10.15	5.56	5.46	4.58	3.70	3.90	3.74	2.30	2.56	3.91	4.29	5.00	5.58
	HDD10.0	2109	502	385	232	100	27	3	0	0	9	100	276	475
	HDD18.3	4234	760	618	488	335	207	84	7	18	121	337	526	733
	CDD10.0	1083	0	0	2	16	81	187	334	295	146	22	1	0
	CDD18.3	164	0	0	0	0	2	18	83	54	8	0	0	0
	CDH23.3	3843	0	0	0	10	105	514	1574	1271	354	14	0	0
	CDH26.7	1552	0	0	0	1	21	170	718	540	100	2	0	0
(14) Wind	WSAvg	3.9	3.4	3.9	4.4	4.8	4.4	4.3	3.6	3.5	3.5	3.7	3.8	3.5
(15) Precipitation	PrecAvg	269	19	19	21	26	36	31	15	18	20	21	24	21
	PrecMax	402	61	60	45	64	110	78	48	66	69	70	62	52
	PrecMin	145	1	2	0	1	2	2	0	0	0	0	0	1
	PrecStd	63	11	14	11	18	25	21	13	15	18	15	15	13
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.5	10.7	19.7	24.8	29.0	33.1	35.7	34.9	31.9	25.4	17.0	9.2
		MCWB	3.4	5.7	8.5	11.2	13.5	15.7	17.0	15.7	15.1	12.1	8.0	5.0
	2%	DB	3.7	7.5	16.1	21.4	26.3	30.7	33.8	33.1	29.4	22.0	13.5	6.2
		MCWB	1.8	3.5	6.9	9.4	12.9	15.2	16.7	15.4	13.7	10.8	6.6	3.4
	5%	DB	2.3	5.1	12.8	18.6	23.8	28.7	32.5	31.8	27.5	19.0	10.9	3.9
		MCWB	1.0	2.3	5.7	8.4	12.0	14.9	16.5	15.1	13.4	9.6	5.6	1.8
	10%	DB	1.1	3.2	10.1	16.0	21.3	26.6	30.9	30.1	25.2	16.3	8.4	2.3
		MCWB	0.1	1.3	4.6	7.2	11.0	14.2	16.2	14.8	12.5	8.2	4.5	0.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.7	6.1	9.1	11.6	15.3	18.3	20.4	18.0	17.4	13.0	8.9	5.7
		MCDB	5.7	10.6	16.2	23.2	25.4	28.9	30.4	29.1	25.5	22.3	14.4	8.5
	2%	WB	2.1	4.1	7.7	10.1	13.7	16.5	19.0	17.1	15.6	11.6	7.3	3.6
		MCDB	3.3	6.7	14.2	20.0	23.6	27.5	29.3	28.2	24.8	19.5	12.7	5.7
	5%	WB	1.1	2.8	6.5	8.9	12.6	15.5	18.0	16.4	14.5	10.4	5.9	2.1
		MCDB	2.0	4.6	12.3	17.4	22.0	26.4	28.3	28.2	24.3	17.6	10.2	3.6
	10%	WB	0.2	1.6	5.1	7.7	11.6	14.6	17.1	15.6	13.3	9.0	4.8	0.8
		MCDB	1.1	3.1	9.7	14.7	20.1	25.0	27.6	27.1	23.0	15.5	8.4	2.0
(35) Mean Daily Temperature Range	MDBR		8.2	9.2	11.1	13.4	14.6	16.7	19.9	19.9	17.6	14.4	11.1	8.4
	5% DB	MCDBR	8.2	9.6	15.8	19.1	19.6	21.3	22.6	22.9	22.2	19.3	15.1	8.7
		MCWBR	6.6	6.3	8.6	9.3	8.2	8.5	8.3	8.0	8.8	9.6	9.1	6.4
	5% WB	MCDBR	7.0	8.4	14.2	16.9	17.7	19.4	20.2	19.7	18.3	16.7	13.5	8.0
		MCWBR	5.9	5.9	8.1	8.5	7.7	8.1	8.3	7.2	7.5	8.6	8.4	6.2
(40) Clear-Sky Solar Irradiance	taub		0.240	0.252	0.267	0.299	0.310	0.313	0.330	0.329	0.302	0.275	0.255	0.242
	taud		2.415	2.445	2.556	2.469	2.497	2.512	2.477	2.452	2.533	2.592	2.569	2.494
	Ebn at Noon		917	964	987	969	961	954	934	925	933	926	898	886
	Edh at Noon		73	85	88	104	105	104	106	105	89	73	63	62
(44) All-Sky Solar Radiation	RadAvg		1.64	2.58	3.94	5.28	6.36	7.41	7.57	6.47	5.05	3.30	1.98	1.32
	RadStd		0.20	0.29	0.28	0.35	0.59	0.56	0.34	0.32	0.34	0.22	0.17	0.17

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page