

EUREKA, NV, USA

WMO: 725824

Lat: 39.517N

Lon: 115.967W

Elev: 6539

StdP: 11.54

Time Zone: -8.00 (NAP)

Period: 90-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	0.1	6.9	-7.8	4.6	9.6	-3.2	5.9	19.7	32.4	37.0	27.7	31.8	4.1	220	0.618

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.9	90.9	55.3	88.1	54.6	84.8	53.6	59.1	79.1	57.1	79.3	55.5	79.1	11.0	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
52.4	74.6	63.6	48.1	63.5	63.8	45.4	57.3	64.9	28.5	77.9	27.1	78.8	26.1	79.3	66.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.9	20.6	18.1	-2.3	93.0	7.7	4.0	-7.8	95.9	-12.3	98.3	-16.6	100.5	-22.2	103.5		
(5)			-3.3	60.6	7.3	3.4	-8.6	63.1	-12.8	65.1	-16.9	67.0	-22.2	69.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.5	27.5	30.8	38.3	43.4	51.3	59.7	69.8	68.1	59.4	48.7	33.2	27.1		
	DBStd	16.83	8.39	9.44	7.58	7.74	8.27	7.92	5.03	5.32	6.96	8.89	9.77	9.51		
	HDD50	3287	699	537	368	222	88	18	0	0	12	127	506	710		
	HDD65	7085	1164	957	828	648	427	187	19	33	188	505	954	1175		
	CDD50	2025	0	0	4	24	128	309	615	560	295	88	2	0		
	CDD65	348	0	0	0	0	3	29	168	127	21	0	0	0		
	CDH74	6087	0	0	2	1	153	877	2649	1842	519	44	0	0		
	CDH80	2186	0	0	0	0	45	242	1129	661	106	3	0	0		
	WSAvg	7.5	6.9	7.1	8.2	8.4	7.9	7.7	7.7	8.0	7.5	7.1	6.9	6.8		
	PrecAvg	9.1	0.8	0.9	1.0	1.0	1.0	0.6	0.5	0.6	0.6	0.7	0.6	0.7		
(15) Precipitation	PrecMax	12.9	1.8	1.9	3.0	2.6	3.0	2.2	1.7	1.8	1.7	2.8	1.8	1.5		
	PrecMin	4.4	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	2.1	0.6	0.5	0.7	0.7	0.9	0.6	0.4	0.5	0.4	0.7	0.4	0.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.4	57.0	70.2	72.4	84.5	89.3	97.3	92.7	86.2	79.3	62.0	52.1		
		MCWB	37.9	41.5	44.5	46.6	53.2	54.1	56.5	55.2	52.6	49.3	41.9	37.2		
	2%	DB	46.8	52.6	63.0	67.9	78.5	85.8	93.1	89.9	82.8	73.4	56.8	46.5		
		MCWB	36.1	38.7	42.1	44.9	50.5	53.3	56.3	54.7	51.4	47.5	40.2	35.2		
	5%	DB	42.3	47.7	56.9	63.5	72.7	82.5	90.1	86.9	80.5	70.3	53.6	43.3		
		MCWB	33.2	36.7	40.2	42.8	48.3	51.9	55.7	54.4	50.9	46.6	39.4	33.0		
	10%	DB	38.8	43.8	52.5	59.3	69.2	79.9	86.4	83.8	76.8	65.8	48.4	39.3		
		MCWB	32.1	34.8	38.7	41.6	47.1	51.1	54.2	53.8	49.8	44.7	36.7	30.9		
	0.4%	WB	40.2	42.3	45.7	47.7	54.9	55.4	61.5	60.8	56.5	50.8	45.4	39.7		
		MCDB	48.6	54.6	67.5	68.7	81.9	83.1	82.1	75.4	72.9	73.4	57.2	46.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	37.2	39.7	42.9	45.9	51.9	53.8	59.8	58.5	54.2	48.6	42.2	36.7		
		MCDB	43.0	49.9	59.9	65.2	73.5	81.7	80.8	76.6	75.5	71.5	52.0	44.9		
	5%	WB	35.0	37.5	41.1	44.0	50.0	52.7	58.2	56.9	52.4	47.0	40.1	34.0		
		MCDB	40.8	45.6	56.0	61.0	69.1	80.0	81.1	77.9	74.4	68.6	50.7	41.5		
	10%	WB	32.8	35.5	39.1	42.1	48.1	51.5	56.3	55.5	50.9	45.3	37.7	32.0		
		MCDB	38.1	43.1	50.5	57.2	66.3	77.7	80.8	77.8	72.8	64.5	48.1	38.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.2	17.8	21.3	22.6	25.2	29.9	30.9	28.6	28.4	24.9	20.2	16.9		
		MCDBR	20.0	22.3	30.1	30.9	33.8	36.3	39.6	34.5	35.6	33.5	28.0	21.1		
		MCWBR	13.2	13.1	15.9	15.0	15.0	15.5	15.2	14.3	15.9	16.7	16.0	13.8		
	5% WB	MCDBR	17.3	19.7	27.9	27.4	30.4	34.0	33.0	28.3	28.6	31.1	23.7	19.5		
		MCWBR	12.0	12.3	15.1	13.9	13.6	14.6	11.7	11.1	12.9	15.5	14.3	13.3		
(40) Clear-Sky Solar Irradiance	taub		0.230	0.238	0.250	0.275	0.285	0.286	0.305	0.299	0.271	0.254	0.236	0.230		
	taud		2.635	2.627	2.619	2.527	2.546	2.572	2.542	2.536	2.624	2.652	2.663	2.634		
	Ebn at Noon		311	321	325	318	315	313	306	306	312	310	306	303		
	Edh at Noon		21	24	27	32	32	31	32	31	27	23	20	19		
(44) All-Sky Solar Radiation	RadAvg		743	1033	1472	1853	2139	2512	2282	2129	1808	1301	876	634		
	RadStd		89	115	97	121	221	187	151	148	93	92	45	86		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (5 neighbors)	+0.72	N/A	N/A	+0.94	N/A	N/A	N/A	N/A	+225	+110	

Nomenclature: See separate page