

BLUE CANYON, CA, USA

WMO: 725845

Lat: 39.277N

Lon: 120.710W

Elev: 5276

StdP: 12.10

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23225

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	21.1	23.6	-6.9	4.6	42.8	-1.6	6.1	42.6	25.6	34.5	22.0	35.8	5.7	60	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	83.8	58.7	81.3	57.8	79.2	56.4	62.5	78.3	60.5	76.8	59.0	75.3	6.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.1	81.6	70.8	53.6	74.3	70.0	51.3	68.3	69.1	30.7	78.3	29.2	76.9	27.9	75.2	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.8	16.2	13.1	DB	17.0	87.7	3.2	2.3	14.7	89.3	12.8	90.6	11.0	91.9	8.7	93.6	(4)
(5)			WB	14.6	65.5	3.2	3.6	12.3	68.1	10.4	70.2	8.7	72.2	6.4	74.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.9	40.5	38.6	41.5	44.5	52.8	62.0	70.2	69.4	64.2	54.5	44.8	38.9	(6)
(7)		DBStd	14.37	8.91	8.97	8.93	9.72	9.83	8.92	5.77	5.64	8.53	9.15	9.38	8.29	(7)
(8)		HDD50	1907	315	334	292	224	89	16	0	0	9	63	211	354	(8)
(9)		HDD65	5301	760	738	729	616	390	155	21	24	114	339	607	808	(9)
(10)		CDD50	2606	20	16	28	58	176	375	626	603	436	201	55	12	(10)
(11)		CDD65	522	0	0	0	0	12	64	182	161	91	12	0	0	(11)
(12)		CDH74	2362	0	0	0	0	36	294	911	740	352	29	0	0	(12)
(13)		CDH80	346	0	0	0	0	1	44	147	110	43	1	0	0	(13)
(14)	Wind	WSAvg	5.5	5.7	6.2	6.3	6.0	5.4	5.2	4.5	4.6	5.1	5.3	5.4	6.3	(14)
(15)	Precipitation	PrecAvg	70.4	12.2	10.3	9.4	5.2	2.1	0.8	0.1	0.6	1.3	4.3	10.7	11.5	(15)
(16)		PrecMax	121.7	33.9	37.7	22.2	14.2	5.3	2.7	1.0	3.7	7.0	22.3	28.3	41.6	(16)
(17)		PrecMin	23.5	0.7	0.8	1.7	0.7	0.1	0.0	0.0	0.0	0.0	0.0	1.0	0.4	(17)
(18)		PrecStd	20.7	8.2	8.2	5.6	3.8	1.5	0.8	0.3	1.0	1.9	4.6	7.0	9.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.7	62.7	65.5	70.4	78.5	85.2	86.9	86.2	85.0	78.1	68.7	61.6	(19)
(20)			MCWB	42.3	44.1	46.1	50.4	55.9	61.2	60.1	58.5	54.6	52.2	48.4	42.3	(20)
(21)		2%	DB	58.5	58.6	61.3	66.4	73.6	80.4	83.9	83.0	80.4	72.8	64.7	57.1	(21)
(22)			MCWB	40.7	42.5	45.0	48.5	54.2	58.1	59.9	57.7	54.8	50.4	46.6	40.2	(22)
(23)		5%	DB	55.6	55.2	57.9	63.0	70.4	77.2	81.2	80.7	78.0	69.7	61.0	53.8	(23)
(24)			MCWB	39.7	40.7	43.4	46.9	52.3	56.7	58.9	56.7	54.0	49.1	44.5	38.2	(24)
(25)		10%	DB	52.7	52.0	54.3	59.2	66.9	74.6	79.0	78.4	75.5	66.5	57.9	50.7	(25)
(26)			MCWB	38.5	38.9	41.6	45.0	50.4	55.1	57.5	55.6	53.3	47.6	42.9	37.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.7	47.2	49.4	53.3	59.4	63.9	65.1	62.8	68.6	55.1	51.0	46.2	(27)
(28)			MCDWB	52.6	56.8	60.7	64.7	72.3	80.0	81.8	80.5	70.8	70.0	64.4	51.8	(28)
(29)		2%	WB	44.1	44.5	46.9	50.5	56.2	60.9	62.6	60.3	60.0	52.9	48.3	43.8	(29)
(30)			MCDWB	51.3	53.8	57.5	62.9	69.9	76.8	79.4	77.8	72.0	67.8	60.8	49.1	(30)
(31)		5%	WB	42.3	42.5	44.9	48.4	54.1	58.6	60.9	58.8	57.1	51.3	46.3	42.0	(31)
(32)			MCDWB	50.4	51.5	54.8	60.0	67.5	74.1	77.8	76.4	72.5	65.9	57.5	47.7	(32)
(33)		10%	WB	40.8	40.6	43.1	46.3	51.9	56.4	59.4	57.3	55.0	49.6	44.6	40.3	(33)
(34)			MCDWB	49.5	49.2	51.9	56.9	65.2	71.9	76.1	74.9	71.9	63.7	54.5	47.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.1	10.0	11.2	12.6	13.0	13.4	12.9	13.4	13.6	12.5	10.4	9.7	(35)
(36)			MCDBR	12.7	12.6	14.0	15.6	15.0	14.1	13.2	13.5	14.0	13.6	12.1	12.6	(36)
(37)			MCWBR	8.7	9.0	10.5	11.0	10.6	10.6	9.0	8.2	8.3	8.4	8.5	8.6	(37)
(38)		5% WB	MCDWR	11.0	11.2	13.0	14.7	14.7	13.8	12.6	12.9	13.6	12.9	11.5	10.0	(38)
(39)			MCWBR	8.4	9.0	10.1	11.0	10.8	11.0	9.2	8.5	9.3	8.7	8.6	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.276	0.275	0.296	0.306	0.312	0.305	0.307	0.294	0.299	0.285	0.268	0.282	(40)	
(41)		taud	2.528	2.557	2.500	2.486	2.497	2.538	2.541	2.566	2.563	2.602	2.612	2.506	(41)	
(42)		Ebn at Noon	289	305	307	308	306	307	305	308	302	298	292	277	(42)	
(43)		Edh at Noon	23	26	31	33	34	32	32	30	29	25	21	22	(43)	
(44)	All-Sky Solar Radiation	RadAvg	722	992	1400	1850	2255	2623	2617	2355	1892	1323	841	615	(44)	
(45)		RadStd	110	141	170	189	189	139	111	92	80	101	70	106	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.48	N/A	N/A	N/A	N/A	N/A	-212	-324	+198	+97
(47) Regional (26 neighbors)		+0.79	N/A	-1.98	N/A	N/A	N/A	-58	-175	+236	+95

Nomenclature: See separate page