

TRUCKEE-TAHOE, CA, USA

WMO: 725846

Lat: 39.320N

Lon: 120.139W

Elev: 5900

StdP: 11.82

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 93201

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 0.5	(c) 6.7	(d) -2.8	(e) 5.9	(f) 4.0	(g) 1.3	(h) 7.3	(i) 9.8	(j) 28.7	(k) 38.3	(l) 26.2	(m) 39.2	(n) 0.3	(o) 170	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.8	88.2	58.3	84.5	56.8	82.3	56.0	61.6	80.2	59.9	79.0	58.5	78.2	9.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
55.4	81.6	65.9	53.5	76.1	65.5	49.9	66.3	64.6	30.6	80.0	29.1	79.1	28.0	78.4	69.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	DB	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.2	18.7	16.6		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.0	28.5	30.3	35.7	39.8	48.4	55.1	62.5	61.5	54.2	45.2	36.2	29.8
	DBStd	13.62	8.23	7.06	6.89	7.00	6.81	6.04	5.12	4.22	5.43	6.93	8.03	8.40
	HDD50	3349	667	551	445	307	114	26	0	0	22	177	414	626
	HDD65	7709	1132	971	910	755	514	299	110	124	325	614	864	1091
	CDD50	1163	0	0	0	2	65	177	387	356	148	28	0	0
	CDD65	48	0	0	0	0	0	0	32	15	1	0	0	0
	CDH74	4252	0	0	0	0	104	493	1733	1417	448	57	0	0
	CDH80	1227	0	0	0	0	10	79	597	452	82	7	0	0
Wind	WSAvg	4.7	3.9	4.2	5.3	5.8	5.7	4.8	4.9	4.8	4.4	4.2	4.0	4.0
Precipitation	PrecAvg	29.0	5.5	4.5	4.0	2.0	1.4	0.6	0.3	0.4	0.5	1.5	2.8	5.8
	PrecMax	54.6	12.1	9.4	14.3	5.7	4.0	1.5	0.8	1.4	3.3	4.6	6.1	16.9
	PrecMin	18.7	0.9	0.7	0.9	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.5	1.3
	PrecStd	8.7	3.4	2.6	3.3	1.5	1.1	0.5	0.2	0.4	0.7	1.3	1.7	4.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	56.9	66.0	72.2	81.5	85.3	91.4	90.4	84.9	80.5	66.5	54.7
		MCWB	39.9	41.7	46.8	49.0	56.4	57.9	59.5	58.5	55.4	52.6	47.7	41.1
	2%	DB	47.8	50.7	61.2	67.6	77.2	82.0	89.8	88.0	82.1	74.0	61.3	50.0
		MCWB	39.8	39.4	44.7	47.7	54.0	56.3	59.3	56.9	53.7	50.1	44.6	40.6
	5%	DB	45.0	45.9	55.5	63.1	72.7	80.5	86.3	84.3	79.5	70.5	55.4	46.3
		MCWB	36.8	36.9	41.9	45.8	52.4	55.4	58.3	56.1	53.8	48.9	42.4	39.1
	10%	DB	41.1	42.8	51.8	57.2	68.5	76.7	82.5	82.0	75.4	65.7	51.7	43.3
		MCWB	35.4	35.9	40.4	42.8	50.5	53.7	56.9	55.7	52.2	47.4	40.8	37.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.2	43.4	48.3	51.2	58.8	61.8	64.5	62.5	61.4	54.4	49.1	46.2
		MCDB	48.0	52.5	62.6	67.4	75.5	79.3	82.1	80.5	71.8	73.8	63.6	50.0
	2%	WB	40.1	40.7	45.5	48.8	55.8	59.0	62.3	60.3	58.1	52.0	46.4	43.0
		MCDB	45.5	48.8	59.5	64.2	73.8	77.7	81.8	79.3	75.0	71.3	58.7	47.0
	5%	WB	37.8	38.4	43.1	46.4	53.6	56.7	60.5	58.9	55.6	49.8	43.9	40.4
		MCDB	41.7	44.1	54.7	60.8	71.3	76.2	80.8	78.5	73.6	68.4	53.6	45.1
	10%	WB	36.4	36.5	40.7	44.2	51.3	54.9	59.1	57.1	53.5	47.4	41.5	38.1
		MCDB	40.1	41.0	50.3	56.6	67.1	73.7	79.5	77.4	73.8	63.9	50.0	42.2
Mean Daily Temperature Range	5% DB	MDBR	21.7	23.0	25.0	26.2	31.3	36.9	40.8	40.3	39.5	34.8	26.9	22.6
		MCDBR	27.2	29.7	33.9	38.9	40.3	43.3	44.1	44.8	46.2	44.8	37.0	27.7
		MCWBR	18.5	19.6	19.0	20.5	18.9	19.9	17.2	18.7	21.7	23.1	21.9	18.3
	5% WB	MCDBR	21.2	25.0	32.4	35.9	38.9	41.2	39.9	38.8	40.3	42.4	33.0	22.6
MCWBR		15.2	17.0	18.7	19.4	18.7	19.7	16.5	17.5	20.2	22.6	20.3	15.9	
Clear-Sky Solar Irradiance	taub		0.270	0.283	0.296	0.308	0.318	0.312	0.317	0.308	0.299	0.284	0.267	0.267
	taud		2.491	2.478	2.462	2.451	2.455	2.494	2.500	2.506	2.545	2.580	2.580	2.509
	Ebn at Noon		291	301	306	307	304	305	302	304	302	298	292	284
	Edh at Noon		24	28	32	35	35	34	33	32	29	25	22	22
All-Sky Solar Radiation	RadAvg		740	1013	1434	1883	2256	2620	2586	2337	1895	1335	861	629
	RadStd		103	130	147	171	192	147	123	99	79	97	64	97

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (20 neighbors)	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+157	+74

Nomenclature: See separate page