

TRUCKEE-TAHOE, CA, USA

WMO: 725846

Lat: 39.320N

Lon: 120.139W

Elev: 1798

StdP: 81.51

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 93201

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -17.5	(c) -14.1	(d) -19.3	(e) 0.8	(f) -15.6	(g) -17.0	(h) 1.0	(i) -12.3	(j) 12.8	(k) 3.5	(l) 11.7	(m) 4.0	(n) 0.2	(o) 170	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 22.7	(c) 31.2	(d) 14.6	(e) 29.2	(f) 13.8	(g) 27.9	(h) 13.3	(i) 16.5	(j) 26.8	(k) 15.5	(l) 26.1	(m) 14.7	(n) 25.6	(o) 4.4	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.0	11.7	18.8	12.0	10.9	18.6	9.9	9.5	18.1	53.3	26.7	49.9	26.2	47.2	25.8	20.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.9	(b) 8.4	(c) 7.4	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 9.9	(b) 8.4	(c) 7.4	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-2.0	-0.9	2.0	4.3	9.1	12.8	16.9	16.4	12.3	7.3	2.3	-1.2	(6)
(7)		DBStd	7.57	4.57	3.92	3.83	3.89	3.78	3.35	2.84	2.34	3.01	3.85	4.46	4.67	(7)
(8)		HDD10.0	1861	371	306	247	171	63	14	0	0	12	98	230	348	(8)
(9)		HDD18.3	4283	629	539	506	419	286	166	61	69	181	341	480	606	(9)
(10)		CDD10.0	646	0	0	0	1	36	98	215	198	82	16	0	0	(10)
(11)		CDD18.3	27	0	0	0	0	0	0	18	8	1	0	0	0	(11)
(12)		CDH23.3	2362	0	0	0	0	58	274	963	787	249	32	0	0	(12)
(13)		CDH26.7	682	0	0	0	0	6	44	332	251	46	4	0	0	(13)
(14)	Wind	WSAvg	2.1	1.8	1.9	2.4	2.6	2.5	2.1	2.2	2.1	2.0	1.9	1.8	1.8	(14)
(15)	Precipitation	PrecAvg	737	139	114	102	51	35	16	7	9	12	38	70	148	(15)
(16)		PrecMax	1386	307	240	362	146	101	39	21	35	83	118	156	430	(16)
(17)		PrecMin	475	23	19	22	9	1	1	1	0	0	1	12	32	(17)
(18)		PrecStd	221	86	66	85	37	27	13	5	10	18	32	43	112	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	13.9	18.9	22.3	27.5	29.6	33.0	32.4	29.4	27.0	19.2	12.6	(19)
(20)		MCWB	4.4	5.4	8.2	9.4	13.5	14.4	15.3	14.7	13.0	11.4	8.7	5.1	(20)	
(21)		2%	DB	8.8	10.4	16.2	19.8	25.1	27.8	32.1	31.1	27.8	23.4	16.3	10.0	(21)
(22)		MCWB	4.4	4.1	7.1	8.7	12.2	13.5	15.1	13.8	12.0	10.0	7.0	4.8	(22)	
(23)		5%	DB	7.2	7.7	13.0	17.3	22.6	27.0	30.1	29.1	26.4	21.4	13.0	7.9	(23)
(24)		MCWB	2.6	2.7	5.5	7.7	11.3	13.0	14.6	13.4	12.1	9.4	5.8	3.9	(24)	
(25)		10%	DB	5.0	6.0	11.0	14.0	20.3	24.8	28.0	27.8	24.1	18.7	11.0	6.3	(25)
(26)		MCWB	1.9	2.1	4.7	6.0	10.3	12.1	13.8	13.2	11.2	8.6	4.9	3.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	6.3	9.1	10.7	14.9	16.6	18.0	16.9	16.3	12.4	9.5	7.9	(27)
(28)		MCDWB	8.9	11.4	17.0	19.7	24.1	26.3	27.9	26.9	22.1	23.2	17.5	10.0	(28)	
(29)		2%	WB	4.5	4.9	7.5	9.3	13.2	15.0	16.9	15.7	14.5	11.1	8.0	6.1	(29)
(30)		MCDWB	7.5	9.3	15.3	17.9	23.2	25.4	27.7	26.3	23.9	21.8	14.9	8.3	(30)	
(31)		5%	WB	3.2	3.5	6.2	8.0	12.0	13.7	15.8	15.0	13.1	9.9	6.6	4.7	(31)
(32)		MCDWB	5.4	6.7	12.6	16.0	21.8	24.6	27.1	25.8	23.1	20.2	12.0	7.3	(32)	
(33)		10%	WB	2.5	2.5	4.9	6.8	10.7	12.7	15.1	14.0	11.9	8.5	5.3	3.4	(33)
(34)		MCDWB	4.5	5.0	10.2	13.7	19.5	23.1	26.4	25.2	23.2	17.7	10.0	5.7	(34)	
(35)	Mean Daily Temperature Range	MDBR	12.1	12.8	13.9	14.6	17.4	20.5	22.7	22.4	22.0	19.3	15.0	12.5	(35)	
(36)		5% DB	MCDBR	15.1	16.5	18.9	21.6	22.4	24.1	24.5	24.9	25.7	24.9	20.5	15.4	(36)
(37)		MCWBR	10.3	10.9	10.6	11.4	10.5	11.0	9.5	10.4	12.1	12.8	12.2	10.2	(37)	
(38)		5% WB	MCDBR	11.8	13.9	18.0	19.9	21.6	22.9	22.1	21.5	22.4	23.6	18.3	12.5	(38)
(39)		MCWBR	8.4	9.5	10.4	10.8	10.4	10.9	9.1	9.7	11.2	12.5	11.3	8.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.270	0.283	0.296	0.308	0.318	0.312	0.317	0.308	0.299	0.284	0.267	0.267	(40)	
(41)		taud	2.491	2.478	2.462	2.451	2.455	2.494	2.500	2.506	2.545	2.580	2.580	2.509	(41)	
(42)		Ebn at Noon	916	949	966	969	958	961	953	957	952	938	919	895	(42)	
(43)		Edh at Noon	76	89	101	109	111	107	105	102	92	79	69	70	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.33	3.19	4.52	5.93	7.11	8.26	8.15	7.37	5.97	4.21	2.71	1.98	(44)	
(45)		RadStd	0.33	0.41	0.46	0.54	0.60	0.46	0.39	0.31	0.25	0.31	0.20	0.31	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (20 neighbors)	+0.33	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+87	+41

Nomenclature: See separate page