

LAKE TAHOE, CA, USA

WMO: 725847

Lat: 38.898N

Lon: 119.995W

Elev: 6314

StdP: 11.64

Time Zone: -8.00 (NAP)

Period: 00-19

WBAN: 93230

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.4	9.1	-3.7	5.7	17.2	0.7	7.2	21.4	25.7	37.4	22.4	37.1	2.8	190	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.4	84.5	56.9	82.2	55.8	80.0	55.0	60.1	78.3	58.5	77.2	57.0	75.8	7.8	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.1	76.1	66.2	50.6	69.2	65.8	48.2	63.3	64.9	29.2	77.9	28.0	77.1	26.9	75.8	65.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.1	18.3	16.0	-6.2	88.8	5.0	2.0	-9.8	90.2	-12.8	91.4	-15.6	92.6	-19.2	94.0		
			-6.9	63.0	4.8	1.7	-10.4	64.3	-13.3	65.3	-16.0	66.2	-19.5	67.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.6	30.5	31.2	35.8	40.3	47.8	56.0	62.7	60.8	54.8	45.7	37.2	31.0
	DBStd	13.04	7.27	7.60	7.14	6.71	6.32	5.83	4.23	3.89	5.80	5.99	7.21	7.46
	HDD50	3149	605	527	440	292	116	17	0	0	25	155	384	588
	HDD65	7490	1070	946	904	740	533	274	94	137	308	597	834	1053
	CDD50	1167	0	0	0	2	48	196	395	335	168	22	1	0
	CDD65	35	0	0	0	0	0	3	24	7	1	0	0	0
	CDH74	2653	0	0	0	0	23	335	1144	858	283	10	0	0
	CDH80	465	0	0	0	0	2	53	250	139	21	0	0	0
Wind	WSAvg	5.3	4.6	5.5	6.2	6.3	5.6	5.6	4.7	4.7	4.7	4.7	5.1	5.6
Precipitation	PrecAvg	22.8	3.6	3.5	3.3	1.4	1.2	0.7	0.4	0.5	0.6	1.5	2.5	3.6
	PrecMax	37.4	10.9	8.1	11.1	3.3	3.9	2.5	1.3	1.7	2.6	5.7	6.1	10.1
	PrecMin	12.1	0.2	0.7	0.6	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.2
	PrecStd	5.7	2.5	2.0	2.4	0.8	0.9	0.7	0.4	0.4	0.6	1.3	1.3	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	57.5	63.1	68.9	77.2	85.3	88.2	86.3	82.4	75.4	63.9	55.0
		MCWB	40.3	40.8	45.1	48.2	52.6	57.8	58.6	56.0	53.8	51.8	47.2	39.4
	2%	DB	50.2	53.2	58.3	64.7	72.7	81.1	85.3	83.5	79.8	69.8	59.9	50.5
		MCWB	38.0	38.9	42.4	46.2	50.6	55.3	57.9	55.7	53.1	49.0	43.9	38.1
	5%	DB	46.7	49.0	54.6	61.2	69.3	77.9	82.9	81.4	77.5	66.5	56.0	47.6
		MCWB	36.8	37.4	40.7	44.3	49.2	53.5	56.9	55.0	52.4	47.1	41.8	36.8
	10%	DB	43.5	44.8	50.4	56.8	65.4	74.8	80.5	79.2	74.8	63.2	52.0	44.6
		MCWB	35.4	35.3	38.8	42.5	47.7	52.3	56.2	54.6	52.0	45.9	39.6	36.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.4	43.2	46.2	50.4	54.6	60.1	63.0	60.3	57.9	53.4	48.6	43.8
		MCDB	50.7	53.9	60.2	65.4	70.8	80.4	78.9	77.6	74.3	69.7	60.4	50.1
	2%	WB	40.3	40.5	43.5	47.5	52.4	57.5	61.1	58.5	55.7	50.9	45.6	40.9
		MCDB	47.4	49.7	56.1	61.7	69.4	75.9	78.5	77.3	74.3	66.1	57.1	46.8
	5%	WB	37.9	38.4	41.5	45.3	50.4	55.5	59.5	57.2	54.0	48.8	43.0	38.7
		MCDB	44.8	46.8	52.9	59.1	66.5	73.8	78.4	76.6	74.1	63.4	53.5	45.0
	10%	WB	36.0	36.2	39.4	43.2	48.6	53.5	58.1	55.9	52.4	46.6	40.9	36.7
		MCDB	42.2	43.6	49.0	55.5	63.5	71.5	76.8	75.9	72.9	60.7	50.5	43.2
Mean Daily Temperature Range	5% DB	MDBR	23.4	22.6	22.9	23.9	27.6	32.9	35.4	36.3	35.4	30.5	25.5	22.4
		MCDBR	28.1	29.4	30.9	34.6	36.4	38.8	37.9	39.5	40.8	37.8	33.0	27.0
		MCWBR	18.1	17.9	17.2	18.2	17.4	17.0	15.7	17.3	19.0	20.2	19.7	17.4
	5% WB	MCDBR	25.2	25.7	28.7	32.4	34.8	36.6	34.0	35.8	37.9	35.1	30.5	22.8
		MCWBR	17.3	16.3	16.6	17.7	17.3	16.6	14.6	16.4	18.0	19.5	19.3	16.1
Clear-Sky Solar Irradiance	taub		0.248	0.264	0.273	0.286	0.296	0.296	0.300	0.292	0.282	0.270	0.252	0.247
	taud		2.540	2.524	2.524	2.523	2.533	2.557	2.577	2.575	2.612	2.637	2.632	2.557
	Ebn at Noon		303	310	316	315	311	310	308	309	309	305	300	295
	Edh at Noon		23	27	30	32	33	32	31	30	27	24	21	21
All-Sky Solar Radiation	RadAvg		750	1024	1435	1886	2262	2622	2568	2333	1907	1358	886	648
	RadStd		98	128	146	168	187	153	128	99	80	98	62	94

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.17	N/A	N/A	N/A	N/A	N/A	-304	-461	N/A	N/A
(47)	Regional (25 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+173	+77

Nomenclature: See separate page