

LAKE TAHOE, CA, USA

WMO: 725847

Lat: 38.898N

Lon: 119.995W

Elev: 1925

StdP: 80.24

Time Zone: -8.00 (NAP)

Period: 00-19

WBAN: 93230

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.9	-12.7	-19.8	0.8	-8.2	-17.4	1.0	-5.9	11.5	3.0	10.0	2.8	1.2	190	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	29.1	13.8	27.9	13.2	26.7	12.8	15.6	25.7	14.7	25.1	13.9	24.3	3.5	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.7	10.9	19.0	10.3	9.9	18.8	9.0	9.0	18.3	50.1	25.5	47.2	25.1	44.6	24.3	18.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.4	8.2	7.1	DB	-21.2	31.5	2.8	1.1	-23.2	32.3	-24.9	33.0	-26.4	33.6	-28.4	34.5
			WB	-21.6	17.2	2.7	1.0	-23.6	17.9	-25.2	18.5	-26.7	19.0	-28.6	19.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	-0.8	-0.4	2.1	4.6	8.8	13.3	17.1	16.0	12.6	7.6	2.9	-0.5		
	DBStd	7.24	4.04	4.22	3.97	3.73	3.51	3.24	2.35	2.16	3.22	3.33	4.01	4.15		
	HDD10.0	1749	336	293	244	162	64	9	0	0	14	86	213	327		
	HDD18.3	4161	594	526	502	411	296	152	52	76	171	332	463	585		
	CDD10.0	648	0	0	0	1	27	109	219	186	93	12	1	0		
	CDD18.3	19	0	0	0	0	0	2	13	4	1	0	0	0		
	CDH23.3	1474	0	0	0	0	13	186	636	477	157	6	0	0		
	CDH26.7	258	0	0	0	0	1	29	139	77	12	0	0	0		
(14) Wind	WSAvg	2.4	2.1	2.4	2.8	2.8	2.5	2.5	2.1	2.1	2.1	2.1	2.3	2.5		
(15) Precipitation	PrecAvg	579	92	88	84	35	30	19	11	13	16	37	63	92		
	PrecMax	950	276	205	282	84	100	63	34	44	67	145	154	256		
	PrecMin	307	4	18	15	9	0	1	0	0	1	0	11	6		
	PrecStd	145	64	51	62	21	22	17	9	11	14	34	33	65		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	14.2	17.3	20.5	25.1	29.6	31.2	30.2	28.0	24.1	17.7	12.8		
		MCWB	4.6	4.9	7.3	9.0	11.4	14.4	14.8	13.3	12.1	11.0	8.5	4.1		
	2%	DB	10.1	11.8	14.6	18.1	22.6	27.3	29.6	28.6	26.5	21.0	15.5	10.3		
		MCWB	3.4	3.9	5.8	7.9	10.3	12.9	14.4	13.2	11.7	9.4	6.6	3.4		
	5%	DB	8.2	9.5	12.5	16.2	20.7	25.5	28.3	27.4	25.3	19.2	13.3	8.7		
		MCWB	2.7	3.0	4.8	6.8	9.6	12.0	13.8	12.8	11.3	8.4	5.4	2.6		
	10%	DB	6.4	7.1	10.2	13.8	18.6	23.8	26.9	26.2	23.8	17.3	11.1	7.0		
		MCWB	1.9	1.8	3.8	5.8	8.7	11.3	13.4	12.6	11.1	7.7	4.2	2.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.8	6.2	7.9	10.2	12.5	15.6	17.2	15.7	14.4	11.9	9.2	6.6		
		MCDB	10.4	12.2	15.7	18.5	21.6	26.9	26.1	25.3	23.5	20.9	15.8	10.0		
	2%	WB	4.6	4.7	6.4	8.6	11.3	14.2	16.2	14.7	13.1	10.5	7.6	4.9		
		MCDB	8.6	9.9	13.4	16.5	20.8	24.4	25.8	25.1	23.5	19.0	14.0	8.2		
	5%	WB	3.3	3.5	5.3	7.4	10.2	13.0	15.3	14.0	12.2	9.3	6.1	3.7		
		MCDB	7.1	8.2	11.6	15.0	19.2	23.2	25.8	24.8	23.4	17.5	11.9	7.2		
	10%	WB	2.2	2.3	4.1	6.2	9.2	12.0	14.5	13.3	11.4	8.1	4.9	2.6		
		MCDB	5.7	6.5	9.4	13.1	17.5	21.9	24.9	24.4	22.7	16.0	10.3	6.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.0	12.6	12.7	13.3	15.3	18.3	19.7	20.2	19.7	16.9	14.2	12.4		
		MCDBR	15.6	16.3	17.2	19.2	20.2	21.5	21.0	21.9	22.6	21.0	18.3	15.0		
	5% WB	MCWBR	10.1	9.9	9.6	10.1	9.7	9.4	8.7	9.6	10.6	11.2	11.0	9.7		
		MCWBR	14.0	14.3	15.9	18.0	19.4	20.3	18.9	19.9	21.0	19.5	16.9	12.7		
(40) Clear-Sky Solar Irradiance	taub		0.248	0.264	0.273	0.286	0.296	0.296	0.300	0.292	0.282	0.270	0.252	0.247		
	taud		2.540	2.524	2.524	2.523	2.533	2.557	2.577	2.575	2.612	2.637	2.632	2.557		
	Ebn at Noon		954	977	995	993	981	977	971	975	973	960	945	931		
	Edh at Noon		73	85	95	101	103	100	98	95	86	75	66	66		
(44) All-Sky Solar Radiation	RadAvg		2.37	3.23	4.52	5.95	7.13	8.27	8.10	7.36	6.01	4.28	2.79	2.04		
	RadStd		0.31	0.40	0.46	0.53	0.59	0.48	0.40	0.31	0.25	0.31	0.20	0.30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.65	N/A	N/A	N/A	N/A	N/A	-169	-256	N/A	N/A
(47) Regional (25 neighbors)		+0.37	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+96	+43

Nomenclature: See separate page