

MCCALL, ID, USA

WMO: 725864

Lat: 44.889N

Lon: 116.102W

Elev: 5013

StdP: 12.22

Time Zone: -7.00 (NAM)

Period: 05-19

WBAN: 94182

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.1	0.0	-9.7	3.9	-4.1	-5.5	4.9	0.8	20.4	32.1	17.1	29.4	0.4	50	0.623

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.6	87.7	57.6	84.9	57.2	82.0	56.4	60.5	80.7	59.1	79.2	57.7	77.8	7.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.5	73.4	65.1	51.4	67.9	64.3	49.4	63.0	62.4	28.9	80.7	27.8	79.1	26.8	77.8	67.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.5	15.4	12.7	-13.3	91.7	4.4	3.0	-16.5	93.9	-19.0	95.6	-21.5	97.3	-24.6	99.5		
			-13.8	63.8	4.3	1.9	-16.9	65.1	-19.4	66.2	-21.8	67.3	-25.0	68.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.9	20.9	24.0	30.2	37.6	47.7	54.9	64.6	62.7	53.8	41.7	30.3	20.7
	DBStd	17.00	9.07	8.37	7.13	7.04	7.06	7.30	5.11	5.76	7.29	6.92	8.62	9.50
	HDD50	4598	904	729	612	376	129	33	0	2	44	270	590	909
	HDD65	8919	1369	1149	1077	823	536	311	70	109	339	722	1040	1374
	CDD50	1262	0	0	0	3	58	182	452	396	158	13	0	0
	CDD65	107	0	0	0	0	0	9	56	39	3	0	0	0
	CDH74	3405	0	0	0	2	26	287	1558	1235	289	8	0	0
	CDH80	1031	0	0	0	0	1	79	517	378	54	2	0	0
Wind	WSAvg	4.0	2.5	3.5	4.2	4.9	5.4	4.8	4.5	4.3	3.9	3.6	3.3	3.0
Precipitation	PrecAvg	27.6	3.7	2.8	2.7	1.9	2.0	2.0	0.8	1.1	1.7	1.9	3.3	3.5
	PrecMax	36.7	8.5	5.7	5.1	4.2	4.3	5.6	2.4	3.3	5.2	6.5	9.3	8.7
	PrecMin	18.2	0.4	0.6	0.3	0.3	0.5	0.3	0.0	0.0	0.0	0.0	0.4	0.3
	PrecStd	4.6	1.9	1.5	1.1	0.9	0.9	1.3	0.7	1.1	1.3	1.5	1.8	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.2	44.9	55.3	70.6	77.5	88.2	91.1	90.4	85.1	72.7	57.3	43.4
		MCWB	35.2	36.2	42.0	48.0	53.7	59.9	60.2	57.9	56.2	51.4	45.5	38.1
	2%	DB	36.7	40.7	48.8	63.6	73.0	81.3	88.2	87.2	81.0	65.7	51.1	38.8
		MCWB	33.6	34.9	38.7	46.3	52.0	57.9	58.1	56.7	54.3	48.2	43.1	36.4
	5%	DB	34.5	38.0	44.5	57.3	69.0	76.7	85.7	84.2	77.4	60.5	46.3	35.7
		MCWB	32.7	33.5	36.9	43.0	50.8	55.4	57.7	56.3	53.4	46.4	40.1	33.7
	10%	DB	33.0	35.7	41.0	51.4	64.4	72.8	82.8	81.4	72.9	55.6	42.4	33.5
		MCWB	31.7	32.5	35.2	40.6	49.0	53.6	57.2	55.8	51.9	44.7	37.7	31.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.1	38.6	43.5	50.2	56.3	62.4	63.4	60.7	59.2	53.1	47.9	39.2
		MCDB	38.3	42.2	51.2	68.1	71.6	82.6	83.9	81.8	77.1	68.0	55.1	41.8
	2%	WB	34.4	36.2	40.2	46.8	53.5	59.4	61.2	59.1	56.8	50.2	43.9	36.8
		MCDB	35.9	39.3	46.5	60.4	68.9	78.0	81.6	80.8	74.6	61.6	49.5	38.5
	5%	WB	33.1	34.2	37.9	44.1	51.7	57.0	59.7	57.8	54.8	47.9	41.1	33.9
		MCDB	34.3	36.7	42.8	55.8	66.1	73.5	79.9	79.8	73.5	58.6	45.7	35.1
	10%	WB	31.8	32.8	36.0	41.4	49.9	54.9	58.4	56.6	52.7	45.7	38.4	32.2
		MCDB	33.0	35.2	40.3	50.1	62.6	70.1	78.5	77.8	71.1	54.6	41.7	33.3
Mean Daily Temperature Range	5% DB	MDBR	16.1	17.6	18.7	20.5	24.0	25.9	32.6	33.0	30.9	23.5	17.5	14.8
		MCDBR	14.3	17.8	24.5	32.7	33.6	34.7	36.9	37.6	39.0	33.0	23.6	12.1
		MCWBR	11.7	12.9	15.4	17.4	15.5	14.8	13.2	13.6	16.5	17.9	15.3	9.7
	5% WB	MCDBR	12.0	14.6	20.1	30.4	29.4	31.5	33.9	34.2	34.2	28.4	20.8	10.8
		MCWBR	10.2	11.1	13.0	16.7	14.2	14.0	13.3	13.0	14.7	15.9	13.9	9.4
Clear-Sky Solar Irradiance	taub	0.252	0.259	0.280	0.336	0.340	0.329	0.337	0.349	0.321	0.285	0.268	0.257	
	taud	2.380	2.367	2.394	2.336	2.405	2.464	2.459	2.406	2.494	2.600	2.545	2.436	
	Ebn at Noon	279	298	305	293	294	297	293	286	287	287	274	266	
	Edh at Noon	23	29	32	37	36	34	34	35	29	23	20	20	
All-Sky Solar Radiation	RadAvg	474	756	1124	1603	1911	2207	2415	2062	1542	965	542	372	
	RadStd	62	94	124	136	168	165	109	104	114	86	49	53	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+3.01	N/A	N/A	+3.20	N/A	-1.85	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+148	N/A

Nomenclature: See separate page