

MCCALL, ID, USA

WMO: 725864

Lat: 44.889N

Lon: 116.102W

Elev: 1528

StdP: 84.27

Time Zone: -7.00 (NAM)

Period: 05-19

WBAN: 94182

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.6	-17.8	-23.2	0.6	-20.1	-20.8	0.7	-17.3	9.1	0.0	7.6	-1.4	0.2	50	0.623

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	30.9	14.2	29.4	14.0	27.8	13.6	15.8	27.1	15.0	26.2	14.3	25.4	3.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.9	10.5	18.4	10.8	9.7	18.0	9.7	9.0	16.9	49.5	27.0	46.8	26.2	44.5	25.4	19.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.8	6.9	5.7	-25.2	33.2	2.4	1.7	-26.9	34.4	-28.3	35.3	-29.7	36.3	-31.5	37.5
			-25.4	17.7	2.4	1.0	-27.2	18.4	-28.6	19.0	-29.9	19.6	-31.7	20.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.9	-6.2	-4.5	-1.0	3.1	8.7	12.7	18.1	17.1	12.1	5.4	-0.9	-6.3
	DBStd	9.45	5.04	4.65	3.96	3.91	3.92	4.06	2.84	3.20	4.05	3.84	4.79	5.28
	HDD10.0	2554	502	405	340	209	72	18	0	1	24	150	328	505
	HDD18.3	4955	761	638	598	457	298	173	39	61	188	401	578	763
	CDD10.0	701	0	0	0	2	32	101	251	220	88	7	0	0
	CDD18.3	59	0	0	0	0	0	5	31	22	2	0	0	0
	CDH23.3	1892	0	0	0	1	14	159	866	686	161	4	0	0
	CDH26.7	573	0	0	0	0	1	44	287	210	30	1	0	0
(14) Wind	WSAvg	1.8	1.1	1.6	1.9	2.2	2.4	2.1	2.0	1.9	1.8	1.6	1.5	1.3
(15) Precipitation	PrecAvg	702	95	71	69	49	52	52	20	29	44	48	84	89
	PrecMax	932	215	144	129	106	108	142	62	84	133	164	235	222
	PrecMin	463	10	16	8	7	13	7	0	0	0	0	9	8
	PrecStd	117	49	37	29	24	24	33	18	27	32	39	46	52
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.5	7.2	12.9	21.4	25.3	31.2	32.8	32.5	29.5	22.6	14.0	6.4
		MCWB	1.8	2.3	5.5	8.9	12.1	15.5	15.7	14.4	13.4	10.8	7.5	3.4
	2%	DB	2.6	4.8	9.4	17.5	22.8	27.4	31.2	30.6	27.2	18.7	10.6	3.8
		MCWB	0.9	1.6	3.7	7.9	11.1	14.4	14.5	13.7	12.4	9.0	6.2	2.4
	5%	DB	1.4	3.3	7.0	14.0	20.6	24.8	29.8	29.0	25.2	15.8	7.9	2.0
		MCWB	0.4	0.9	2.7	6.1	10.4	13.0	14.3	13.5	11.9	8.0	4.5	0.9
	10%	DB	0.6	2.0	5.0	10.8	18.0	22.7	28.2	27.4	22.7	13.1	5.8	0.8
		MCWB	-0.2	0.3	1.8	4.8	9.4	12.0	14.0	13.2	11.0	7.0	3.1	0.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.3	3.7	6.4	10.1	13.5	16.9	17.4	16.0	15.1	11.7	8.9	4.0
		MCDB	3.5	5.6	10.6	20.1	22.0	28.1	28.8	27.7	25.1	20.0	12.8	5.4
	2%	WB	1.3	2.3	4.6	8.2	12.0	15.2	16.2	15.0	13.8	10.1	6.6	2.7
		MCDB	2.2	4.1	8.1	15.8	20.5	25.6	27.6	27.1	23.7	16.5	9.7	3.6
	5%	WB	0.6	1.2	3.3	6.7	11.0	13.9	15.4	14.3	12.6	8.8	5.1	1.0
		MCDB	1.3	2.6	6.0	13.2	18.9	23.1	26.6	26.6	23.1	14.8	7.6	1.7
	10%	WB	-0.1	0.4	2.2	5.2	10.0	12.7	14.7	13.7	11.5	7.6	3.5	0.1
		MCDB	0.5	1.8	4.6	10.1	17.0	21.1	25.8	25.4	21.7	12.6	5.4	0.7
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	9.8	10.4	11.4	13.3	14.4	18.1	18.3	17.1	13.1	9.7	8.2
		MCDBR	7.9	9.9	13.6	18.1	18.7	19.3	20.5	20.9	21.6	18.4	13.1	6.7
		MCWBR	6.5	7.2	8.5	9.7	8.6	8.2	7.3	7.6	9.2	9.9	8.5	5.4
	5% WB	MCDBR	6.7	8.1	11.2	16.9	16.3	17.5	18.8	19.0	19.0	15.8	11.5	6.0
		MCWBR	5.7	6.2	7.2	9.3	7.9	7.8	7.4	7.2	8.1	8.8	7.7	5.2
(40) Clear-Sky Solar Irradiance	taub		0.252	0.259	0.280	0.336	0.340	0.329	0.337	0.349	0.321	0.285	0.268	0.257
	taud		2.380	2.367	2.394	2.336	2.405	2.464	2.459	2.406	2.494	2.600	2.545	2.436
	Ebn at Noon		881	940	961	925	928	937	925	901	905	906	864	840
	Edh at Noon		73	90	101	118	114	108	108	109	92	72	63	63
(44) All-Sky Solar Radiation	RadAvg		1.49	2.38	3.54	5.05	6.02	6.96	7.61	6.50	4.86	3.04	1.71	1.17
	RadStd		0.19	0.29	0.39	0.43	0.53	0.52	0.34	0.33	0.36	0.27	0.15	0.17

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+1.67	N/A	N/A	+1.78	N/A	-1.03	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+82	N/A

Nomenclature: See separate page