

BURLEY, ID, USA

WMO: 725867

Lat: 42.542N

Lon: 113.766W

Elev: 1266

StdP: 87.01

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24133

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.2	-12.1	-18.9	0.8	-13.4	-16.0	1.1	-10.2	12.1	1.2	11.2	1.5	2.3	60	0.592

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	34.1	17.4	32.5	16.9	30.9	16.4	19.0	30.3	18.0	29.1	17.3	28.2	2.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.5	12.8	22.3	14.1	11.7	22.0	12.9	10.9	21.8	59.1	30.3	55.9	29.1	53.2	28.3	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.1	9.5	8.5	-19.3	37.6	4.1	1.7	-22.2	38.8	-24.6	39.8	-26.9	40.7	-29.9	42.0
			-19.7	20.8	4.0	1.7	-22.6	22.1	-24.9	23.1	-27.1	24.1	-30.0	25.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	-1.5	0.7	5.2	8.3	13.0	17.5	22.3	21.0	16.0	9.5	3.5	-1.6
	DBStd	9.12	5.05	4.66	3.88	3.82	4.15	3.76	2.61	2.84	3.88	4.30	4.79	4.93
	HDD10.0	1492	358	262	155	77	18	2	0	0	4	60	198	359
	HDD18.3	3484	616	495	407	302	171	58	3	10	87	273	444	617
	CDD10.0	1324	0	0	6	26	111	227	380	340	185	46	4	0
	CDD18.3	276	0	0	0	0	6	34	125	92	19	1	0	0
	CDH23.3	4229	0	0	1	16	154	592	1677	1319	433	36	0	0
	CDH26.7	1777	0	0	0	2	36	208	793	591	141	6	0	0
Wind	WSAvg	3.6	3.9	4.1	4.3	4.5	3.8	3.5	2.9	2.8	2.9	3.4	3.6	3.9
Precipitation	PrecAvg	251	27	19	23	25	29	22	9	13	14	15	25	24
	PrecMax	400	78	97	72	72	110	62	31	105	59	41	71	103
	PrecMin	146	2	0	1	2	1	2	0	0	0	0	1	0
	PrecStd	67	20	17	16	18	22	17	8	19	13	11	16	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	14.6	21.7	25.7	29.9	33.7	37.1	36.1	33.0	27.0	19.4	12.1
		MCWB	5.9	7.1	9.4	11.8	14.8	17.4	19.3	18.4	16.6	13.4	9.6	6.6
	2%	DB	8.6	11.7	18.4	22.3	27.3	31.3	34.6	33.8	30.2	23.7	16.0	9.5
		MCWB	4.3	6.0	8.4	10.4	13.9	16.2	17.7	17.1	15.2	11.9	8.4	5.2
	5%	DB	6.6	9.4	15.7	19.5	24.6	29.1	32.9	32.3	28.0	20.8	13.5	7.3
		MCWB	3.2	4.8	7.2	9.5	13.0	15.6	17.2	16.6	14.4	10.8	7.0	4.0
	10%	DB	4.8	7.3	13.0	16.7	22.2	27.0	31.2	30.3	25.9	18.1	11.0	5.2
		MCWB	2.2	3.8	5.8	8.3	12.1	14.8	16.9	16.2	13.8	9.5	5.9	2.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	8.0	10.3	12.6	16.3	18.6	20.6	21.6	18.3	14.3	10.7	7.2
		MCDB	10.1	13.2	18.8	23.9	26.8	31.1	32.6	32.3	28.6	25.4	16.6	11.0
	2%	WB	4.8	6.5	8.9	11.0	14.7	17.3	19.3	18.5	16.8	12.8	8.9	5.6
		MCDB	7.9	10.7	17.1	20.1	24.6	28.9	30.7	29.8	26.4	21.7	14.9	8.8
	5%	WB	3.5	5.3	7.7	9.9	13.7	16.3	18.5	17.6	15.6	11.5	7.6	4.3
		MCDB	6.2	8.8	14.6	18.2	23.0	27.4	29.5	28.9	24.9	19.0	12.6	7.0
	10%	WB	2.4	4.0	6.5	8.7	12.5	15.2	17.7	16.8	14.5	10.1	6.3	2.8
		MCDB	4.6	7.1	12.3	16.1	21.0	25.6	28.6	27.8	24.0	17.1	10.7	5.0
Mean Daily Temperature Range	5% DB	MDBR	8.1	9.2	11.9	12.7	13.5	15.1	17.2	17.5	16.4	14.0	11.1	8.0
		MCDBR	9.9	11.7	16.8	18.3	18.3	19.7	20.1	20.7	20.7	19.0	15.0	9.4
		MCWBR	6.6	7.2	8.8	8.8	7.7	7.7	7.5	7.7	8.2	9.1	8.5	6.2
	5% WB	MCDBR	9.0	10.7	15.4	16.5	16.5	18.5	17.8	18.0	17.4	16.5	13.7	8.8
		MCWBR	6.2	6.8	8.4	8.2	7.1	7.4	7.0	7.1	7.1	8.2	8.0	6.1
Clear-Sky Solar Irradiance	taub	0.250	0.259	0.273	0.297	0.316	0.313	0.328	0.323	0.300	0.276	0.259	0.249	
	taud	2.535	2.580	2.572	2.498	2.476	2.525	2.493	2.487	2.549	2.598	2.593	2.557	
	Ebn at Noon	922	967	984	974	956	956	938	934	939	931	904	893	
	Edh at Noon	67	76	87	102	107	103	105	102	89	74	63	61	
All-Sky Solar Radiation	RadAvg	1.79	2.67	4.00	5.41	6.54	7.61	7.48	6.52	5.24	3.52	2.16	1.42	
	RadStd	0.23	0.34	0.34	0.36	0.60	0.56	0.39	0.32	0.31	0.24	0.19	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	-0.70	-1.19	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	-0.38	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page