

KLAMATH FALLS, OR, USA

WMO: 725895

Lat: 42.147N

Lon: 121.724W

Elev: 4084

StdP: 12.65

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 94236

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	8.1	13.8	3.0	7.5	12.5	8.6	9.9	20.8	30.9	41.5	26.5	40.6	2.4	340	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.4	91.1	61.7	88.1	60.5	85.1	59.2	64.3	84.6	62.5	82.5	61.0	80.8	7.7	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.0	80.6	70.6	54.9	74.7	68.5	53.6	71.3	67.5	31.4	84.8	30.0	82.1	28.9	81.0	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.1	20.1	17.8	DB	0.0	96.0	8.1	2.7	-5.9	97.9	-10.7	99.5	-15.2	100.9	-21.1	102.9	(4)
(5)			WB	-0.6	67.0	8.0	3.0	-6.4	69.2	-11.1	70.9	-15.6	72.6	-21.4	74.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.4	32.0	35.0	39.5	43.6	51.9	59.1	67.7	65.7	58.5	47.3	37.3	30.6		
	DBStd	14.28	7.54	6.58	6.23	6.90	7.39	7.18	5.52	5.17	6.84	6.57	7.56	7.94		
	HDD50	2724	558	419	328	214	67	12	0	0	12	129	384	601		
	HDD65	6647	1023	839	791	643	409	201	36	53	208	548	830	1066		
	CDD50	1785	0	0	2	21	126	284	548	487	268	46	3	0		
	CDD65	234	0	0	0	0	3	23	119	75	14	0	0	0		
	CDH74	5835	0	0	0	14	181	718	2363	1779	734	46	0	0		
	CDH80	2150	0	0	0	0	34	214	1004	673	217	8	0	0		
	WSAvg	6.4	6.0	7.1	7.9	7.8	7.3	6.8	5.7	5.3	5.2	5.4	5.8	6.1		
	PrecAvg	13.7	2.0	1.3	1.4	0.9	1.0	0.7	0.3	0.6	0.5	1.0	2.0	2.2		
(15) Precipitation	PrecMax	21.1	4.9	4.6	3.1	2.6	4.8	1.9	2.4	2.7	2.4	4.6	5.8	8.9		
	PrecMin	7.9	0.2	0.1	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.2	0.2		
	PrecStd	3.1	1.3	0.9	0.9	0.6	0.9	0.5	0.5	0.7	0.6	0.9	1.3	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	60.3	68.1	75.8	84.1	90.2	95.5	94.3	89.9	79.8	64.1	51.2		
		MCWB	43.7	46.9	49.0	53.0	57.8	60.8	64.5	62.6	60.5	54.8	49.5	45.0		
	2%	DB	48.7	54.0	63.0	70.5	79.3	85.6	91.9	90.3	85.4	73.0	58.8	47.8		
		MCWB	41.8	43.4	46.4	50.9	56.3	59.2	62.2	61.4	57.5	52.4	47.4	42.5		
	5%	DB	45.4	49.4	57.8	65.2	74.5	81.9	89.4	87.1	82.0	69.0	54.1	45.0		
		MCWB	39.9	41.6	44.5	48.3	54.4	57.5	61.4	59.7	56.8	50.6	45.1	39.9		
	10%	DB	42.8	45.7	53.0	59.8	70.1	78.2	86.0	83.8	78.7	63.7	49.7	42.4		
		MCWB	38.1	39.1	42.7	46.1	52.2	56.0	60.2	58.8	55.4	48.5	43.3	38.2		
	0.4%	WB	46.3	48.2	50.6	54.5	60.2	63.3	68.3	66.5	63.6	56.3	51.8	46.6		
		MCDB	50.1	57.7	64.0	71.6	79.3	83.7	89.7	88.0	84.7	73.0	60.9	50.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	42.7	44.9	47.8	51.9	57.9	61.0	65.1	63.4	60.0	54.0	48.8	43.2		
		MCDB	47.1	51.8	59.7	67.9	75.4	81.2	85.6	83.5	79.7	70.5	56.3	46.7		
	5%	WB	40.6	42.1	45.7	49.4	55.8	59.1	63.3	61.6	57.9	51.7	46.2	40.8		
		MCDB	44.8	48.0	55.8	63.2	71.2	77.5	83.2	82.3	77.8	65.8	52.9	44.1		
	10%	WB	38.5	39.8	43.6	47.0	53.4	57.3	61.9	60.1	56.1	49.5	43.7	38.4		
		MCDB	42.1	45.2	52.2	58.3	66.7	74.8	81.5	79.7	75.6	62.0	49.3	41.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.8	18.8	22.8	25.0	27.4	31.0	34.4	35.0	34.5	29.8	20.9	16.5		
		MCDBR	20.3	25.0	33.7	36.5	36.2	36.8	37.6	38.5	40.6	38.9	29.0	19.0		
		MCWBR	13.9	15.6	19.0	18.6	15.7	13.8	12.6	13.4	16.5	19.7	18.1	13.4		
		MCDBR	17.7	22.6	29.7	33.8	33.4	34.6	34.9	35.6	38.1	34.7	26.0	15.6		
	5% WB	MCWBR	12.6	14.6	17.3	17.8	14.6	13.5	12.4	13.0	16.1	18.3	16.7	11.6		
(40) Clear-Sky Solar Irradiance	taub		0.281	0.287	0.288	0.312	0.316	0.309	0.312	0.309	0.289	0.291	0.274	0.277		
	taud		2.521	2.547	2.570	2.487	2.511	2.560	2.564	2.553	2.601	2.588	2.600	2.532		
	Ebn at Noon		279	296	307	304	304	305	303	301	303	290	282	271		
	Edh at Noon		22	25	28	33	33	31	31	30	27	24	20	20		
(44) All-Sky Solar Radiation	RadAvg		594	882	1257	1717	2130	2475	2549	2234	1758	1151	667	478		
	RadStd		88	107	128	160	167	129	89	101	84	103	79	87		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	+1.06	N/A	N/A	N/A	+184	+81

Nomenclature: See separate page