

KLAMATH FALLS, OR, USA

WMO: 725895

Lat: 42.147N

Lon: 121.724W

Elev: 1245

StdP: 87.24

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 94236

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-13.3	-10.1	-16.1	1.1	-10.8	-13.0	1.4	-6.2	13.8	5.3	11.9	4.8	1.1	340	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	32.8	16.5	31.2	15.8	29.5	15.1	17.9	29.2	16.9	28.1	16.1	27.1	3.4	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.9	11.5	21.5	12.7	10.7	20.3	12.0	10.2	19.7	55.1	29.3	51.9	27.8	49.3	27.2	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.8	9.0	8.0	-17.8	35.6	4.5	1.5	-21.1	36.6	-23.7	37.5	-26.2	38.3	-29.5	39.4		
			-18.1	19.5	4.5	1.7	-21.3	20.7	-23.9	21.6	-26.4	22.6	-29.7	23.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	0.0	1.7	4.2	6.4	11.1	15.0	19.8	18.7	14.7	8.5	3.0	-0.8
	DBStd	7.93	4.19	3.65	3.46	3.83	4.11	3.99	3.07	2.87	3.80	3.65	4.20	4.41
	HDD10.0	1513	310	233	182	119	37	7	0	0	7	72	213	334
	HDD18.3	3693	568	466	439	357	227	112	20	29	116	304	461	592
	CDD10.0	992	0	0	1	12	70	158	304	271	149	26	2	0
	CDD18.3	130	0	0	0	0	2	13	66	42	8	0	0	0
	CDH23.3	3242	0	0	0	8	101	399	1313	988	408	26	0	0
	CDH26.7	1194	0	0	0	0	19	119	558	374	121	4	0	0
Wind	WSAvg	2.8	2.7	3.2	3.5	3.5	3.3	3.0	2.5	2.4	2.3	2.4	2.6	2.7
Precipitation	PrecAvg	349	51	33	35	22	26	18	8	14	12	25	51	55
	PrecMax	535	125	118	78	66	123	47	61	69	62	116	147	227
	PrecMin	201	4	2	2	2	3	0	0	0	0	0	6	6
	PrecStd	78	34	23	22	16	24	13	12	19	15	23	34	47
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	15.7	20.0	24.4	28.9	32.4	35.3	34.6	32.2	26.6	17.8	10.7
		MCWB	6.5	8.3	9.5	11.6	14.3	16.0	18.0	17.0	15.8	12.7	9.7	7.2
	2%	DB	9.3	12.2	17.2	21.4	26.3	29.8	33.3	32.4	29.6	22.8	14.9	8.8
		MCWB	5.4	6.3	8.0	10.5	13.5	15.1	16.8	16.3	14.1	11.3	8.6	5.8
	5%	DB	7.5	9.7	14.3	18.5	23.6	27.7	31.9	30.6	27.8	20.6	12.3	7.2
		MCWB	4.4	5.3	6.9	9.0	12.4	14.2	16.3	15.4	13.8	10.3	7.3	4.4
	10%	DB	6.0	7.6	11.7	15.5	21.2	25.7	30.0	28.8	25.9	17.6	9.8	5.8
		MCWB	3.4	3.9	5.9	7.8	11.2	13.3	15.7	14.9	13.0	9.1	6.3	3.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	9.0	10.4	12.5	15.7	17.4	20.2	19.2	17.6	13.5	11.0	8.1
		MCDB	10.0	14.3	17.8	22.0	26.3	28.7	32.0	31.1	29.3	22.8	16.1	10.1
	2%	WB	6.0	7.2	8.8	11.1	14.4	16.1	18.4	17.4	15.6	12.2	9.3	6.2
		MCDB	8.4	11.0	15.4	19.9	24.1	27.3	29.8	28.6	26.5	21.4	13.5	8.1
	5%	WB	4.8	5.6	7.6	9.7	13.2	15.1	17.4	16.5	14.4	10.9	7.9	4.9
		MCDB	7.1	8.9	13.2	17.4	21.8	25.3	28.4	28.0	25.4	18.8	11.6	6.7
	10%	WB	3.6	4.3	6.4	8.3	11.9	14.1	16.6	15.6	13.4	9.7	6.5	3.5
		MCDB	5.6	7.3	11.2	14.6	19.3	23.8	27.5	26.5	24.2	16.7	9.6	5.4
Mean Daily Temperature Range	5% DB	MDBR	9.3	10.5	12.6	13.9	15.2	17.2	19.1	19.4	19.2	16.5	11.6	9.2
		MCDBR	11.3	13.9	18.7	20.3	20.1	20.4	20.9	21.4	22.5	21.6	16.1	10.5
		MCWBR	7.7	8.7	10.5	10.3	8.7	7.7	7.0	7.4	9.2	11.0	10.1	7.5
	5% WB	MCDBR	9.9	12.5	16.5	18.8	18.5	19.2	19.4	19.8	21.2	19.3	14.4	8.6
		MCWBR	7.0	8.1	9.6	9.9	8.1	7.5	6.9	7.2	9.0	10.2	9.3	6.5
Clear-Sky Solar Irradiance	taub	0.281	0.287	0.288	0.312	0.316	0.309	0.312	0.309	0.289	0.291	0.274	0.277	
	taud	2.521	2.547	2.570	2.487	2.511	2.560	2.564	2.553	2.601	2.588	2.600	2.532	
	Ebn at Noon	880	932	968	958	957	961	954	950	954	915	888	854	
	Edh at Noon	70	80	88	103	104	99	98	96	85	76	64	64	
All-Sky Solar Radiation	RadAvg	1.87	2.78	3.96	5.41	6.71	7.80	8.04	7.04	5.54	3.63	2.10	1.51	
	RadStd	0.28	0.34	0.40	0.50	0.53	0.41	0.28	0.32	0.27	0.33	0.25	0.28	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	N/A	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	N/A	+102	+45

Nomenclature: See separate page