

UKIAH, CA, USA

WMO: 725905

Lat: 39.126N

Lon: 123.201W

Elev: 183

StdP: 99.14

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23275

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-2.0	-0.8	-6.1	2.3	9.5	-4.0	2.8	8.0	8.1	10.9	7.2	10.5	0.1	310	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	38.0	19.7	36.3	19.2	34.4	18.7	21.2	35.1	20.3	33.8	19.5	32.6	3.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.0	11.6	26.4	14.8	10.8	25.1	14.0	10.2	23.9	62.0	35.2	58.7	33.9	56.0	32.6	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	6.0	5.4	DB	-4.0	41.5	1.7	1.4	-5.2	42.5	-6.3	43.4	-7.2	44.2	-8.5	45.2	(4)
(5)			WB	-4.6	22.9	1.7	1.1	-5.8	23.7	-6.8	24.3	-7.8	24.9	-9.1	25.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.3	8.6	9.6	11.5	13.2	16.8	20.5	23.8	23.1	20.9	16.2	11.0	8.0	(6)
(7)		DBStd	6.31	2.61	2.93	3.27	3.55	3.48	3.54	2.85	2.52	3.12	3.09	3.10	2.81	(7)
(8)		HDD10.0	228	58	39	21	9	1	0	0	0	1	24	76	(8)	
(9)		HDD18.3	1639	301	244	212	158	72	17	1	11	82	219	322	(9)	
(10)		CDD10.0	2163	15	28	68	105	212	316	426	407	327	191	55	13	(10)
(11)		CDD18.3	532	0	0	1	4	25	83	168	149	88	14	0	0	(11)
(12)		CDH23.3	8213	0	4	54	173	534	1297	2343	2057	1338	395	18	0	(12)
(13)		CDH26.7	4355	0	0	8	53	224	663	1364	1168	722	151	1	0	(13)
(14)	Wind	WSAvg	1.6	1.2	1.5	1.7	2.0	2.2	2.3	2.0	1.8	1.5	1.2	1.1	1.2	(14)
(15)	Precipitation	PrecAvg	1068	210	172	142	65	26	7	1	4	13	52	151	202	(15)
(16)		PrecMax	2092	636	567	474	249	163	55	23	37	82	209	442	569	(16)
(17)		PrecMin	380	13	9	4	4	0	0	0	0	0	0	8	0	(17)
(18)		PrecStd	325	142	126	108	55	35	13	4	9	21	47	110	152	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.1	23.6	27.8	31.2	35.3	39.1	40.9	40.2	38.6	34.1	26.1	18.4	(19)
(20)			MCWB	11.8	13.7	15.3	16.3	18.7	20.6	20.8	19.8	18.5	16.9	14.8	11.3	(20)
(21)		2%	DB	17.6	20.7	24.5	28.0	32.1	36.1	38.0	37.4	36.1	30.6	22.5	16.1	(21)
(22)			MCWB	11.0	12.4	13.9	15.6	17.4	19.6	20.0	19.3	18.2	15.9	13.5	11.3	(22)
(23)		5%	DB	15.2	17.8	22.0	25.0	29.1	33.1	36.2	35.2	33.8	27.8	19.2	14.4	(23)
(24)			MCWB	10.7	11.1	12.9	14.5	16.4	18.4	19.7	18.6	17.7	15.1	12.2	11.1	(24)
(25)		10%	DB	13.3	15.1	18.8	21.6	26.2	30.7	33.9	33.1	31.3	24.9	16.7	13.0	(25)
(26)			MCWB	10.5	10.6	11.6	13.0	15.3	17.5	19.2	18.4	17.2	14.2	11.7	10.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.1	15.1	16.4	17.7	19.9	22.3	22.7	21.4	20.8	18.4	16.3	14.3	(27)
(28)			MCD B	16.7	20.8	26.1	28.7	32.8	36.5	37.1	36.3	35.3	29.4	23.3	15.7	(28)
(29)		2%	WB	12.7	13.5	14.8	16.0	18.4	20.6	21.5	20.3	19.5	17.1	14.7	13.2	(29)
(30)			MCD B	14.7	18.2	23.1	26.3	30.3	33.8	35.4	34.5	32.9	27.3	19.7	14.5	(30)
(31)		5%	WB	11.8	12.3	13.4	14.9	17.0	19.2	20.6	19.7	18.5	16.0	13.5	12.1	(31)
(32)			MCD B	13.8	15.9	19.8	24.0	27.8	31.4	34.0	33.4	31.7	25.4	17.4	13.4	(32)
(33)		10%	WB	10.8	11.2	12.2	13.5	15.7	18.0	19.7	18.9	17.5	15.0	12.4	11.0	(33)
(34)			MCD B	13.0	14.4	17.2	20.7	24.9	29.3	32.7	32.0	29.9	23.0	15.6	12.5	(34)
(35)	Mean Daily Temperature Range	MDBR	10.4	11.1	12.6	13.7	15.5	17.4	19.8	20.2	19.7	17.1	12.0	10.2	(35)	
(36)		5% DB	MCD BR	15.2	17.1	19.4	20.5	21.6	22.1	22.7	23.2	24.1	22.8	17.5	13.3	(36)
(37)			MCWBR	9.2	9.5	9.6	9.5	9.0	8.4	8.3	8.4	9.1	9.6	9.2	8.4	(37)
(38)		5% WB	MCD BR	10.3	13.6	16.4	18.6	19.6	20.6	21.1	21.4	21.7	19.4	13.5	8.0	(38)
(39)			MCWBR	6.9	7.9	8.7	9.0	8.8	8.6	8.6	8.5	8.9	8.9	7.6	5.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.316	0.319	0.324	0.346	0.339	0.343	0.341	0.332	0.328	0.320	0.312	0.317	(40)	
(41)		taud	2.559	2.550	2.548	2.445	2.505	2.501	2.508	2.525	2.525	2.588	2.582	2.552	(41)	
(42)		Ebn at Noon	864	910	939	930	939	931	929	933	920	897	861	833	(42)	
(43)		Edh at Noon	74	84	93	110	106	106	105	100	94	80	71	69	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.18	3.09	4.39	5.88	7.08	7.88	7.63	6.72	5.57	3.94	2.57	1.86	(44)	
(45)		RadStd	0.35	0.44	0.46	0.51	0.45	0.38	0.28	0.26	0.23	0.30	0.23	0.33	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.39	N/A	-1.08	N/A	-0.38	N/A	N/A	N/A	N/A	N/A
(47) Regional (36 neighbors)		N/A	N/A	-1.35	N/A	N/A	N/A	N/A	N/A	+135	+39

Nomenclature: See separate page