

SALINAS, CA, USA

WMO: 725930

Lat: 36.664N

Lon: 121.608W

Elev: 74

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23233

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	34.3	36.7	21.6	16.3	51.9	25.6	19.7	48.7	26.9	55.9	24.6	55.1	5.1	120	0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	18.1	83.6	61.9	79.0	61.0	75.3	60.6	65.0	77.8	63.6	74.8	62.4	72.5	9.3	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.6	79.3	67.5	59.1	75.1	66.4	58.1	72.2	65.5	29.8	77.8	28.9	74.9	28.0	72.6	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.9	18.6	17.0	DB	30.1	94.5	2.7	4.4	28.1	97.7	26.5	100.3	25.0	102.8	23.0	106.0	(4)
(5)			WB	28.2	69.3	2.8	3.2	26.2	71.6	24.5	73.4	23.0	75.2	21.0	77.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.1	52.3	53.1	55.3	56.6	59.0	61.4	62.6	63.7	63.9	61.3	56.2	51.4
	DBStd	6.14	5.09	5.06	4.71	4.64	3.69	3.44	2.77	2.98	4.04	4.89	5.33	4.86
	HDD50	117	34	21	9	3	0	0	0	0	0	0	9	41
	HDD65	2641	393	334	304	257	193	120	85	62	66	139	268	420
	CDD50	3075	106	108	172	202	280	341	392	424	418	350	196	86
	CDD65	122	0	1	2	5	7	11	12	21	34	24	5	0
	CDH74	1131	12	21	40	86	94	117	57	101	267	264	68	4
	CDH80	331	1	1	7	29	30	38	9	23	85	92	16	0
(14) Wind	WSAvg	7.8	7.4	7.7	7.5	8.1	9.0	9.3	8.6	8.0	7.2	6.7	6.6	7.4
(15) Precipitation	PrecAvg	12.4	2.4	2.2	2.0	1.0	0.2	0.1	0.0	0.0	0.2	0.5	1.7	2.0
	PrecMax	23.7	7.9	10.0	6.0	5.7	1.9	0.6	0.6	0.7	1.2	1.9	4.8	5.1
	PrecMin	6.4	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	4.5	2.0	2.2	1.5	1.1	0.4	0.1	0.1	0.1	0.4	0.6	1.4	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.1	77.5	79.0	84.0	84.0	85.0	79.8	82.5	89.6	89.5	81.8	72.0
		MCWB	55.1	58.6	59.6	61.8	62.8	63.3	64.4	64.6	64.3	62.8	59.4	52.9
	2%	DB	69.2	70.7	72.4	74.2	74.9	76.3	74.7	76.0	81.2	81.2	73.9	66.4
		MCWB	54.5	56.7	57.4	58.5	60.2	61.6	62.5	63.2	62.8	59.8	57.1	54.0
	5%	DB	64.3	65.4	67.8	69.0	69.9	71.8	71.8	72.9	75.7	75.0	68.9	63.1
		MCWB	54.3	54.7	56.1	56.8	58.4	60.1	61.6	62.3	62.0	58.6	56.0	53.6
	10%	DB	60.8	61.8	64.0	65.0	66.3	68.8	69.3	70.4	72.1	70.4	65.0	60.1
		MCWB	53.5	53.5	54.8	55.2	56.9	59.0	60.4	61.1	61.1	58.0	55.3	52.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.3	62.2	62.0	63.4	65.0	65.7	65.4	66.1	67.1	65.2	62.4	60.6
		MCDB	65.2	71.2	75.6	77.3	79.1	81.4	78.0	78.6	81.7	78.6	73.5	65.0
	2%	WB	57.7	58.9	59.3	60.2	61.4	62.5	63.2	64.1	64.5	62.7	60.1	58.2
		MCDB	62.9	66.3	68.4	70.9	72.1	74.1	73.3	74.6	76.6	74.6	69.1	62.0
	5%	WB	55.9	56.7	57.4	58.1	59.3	60.8	61.9	62.7	63.0	61.1	58.5	56.1
		MCDB	61.4	63.7	64.7	67.2	68.3	70.2	71.0	71.9	73.4	71.3	66.0	59.8
	10%	WB	54.2	54.7	55.7	56.1	57.5	59.4	60.6	61.6	61.7	59.5	56.9	54.2
		MCDB	59.6	60.5	62.5	63.9	65.3	67.7	68.3	70.0	71.1	67.8	63.3	58.3
(35) Mean Daily Temperature Range	5% DB	MDBR	18.7	18.3	19.4	18.5	15.8	15.5	14.3	15.2	18.1	21.6	20.7	18.7
		MCDBR	24.5	25.3	26.3	26.8	24.3	22.6	18.6	19.6	26.7	30.7	26.7	23.1
		MCWBR	13.6	13.5	13.5	13.6	11.7	10.8	8.7	8.9	12.0	14.0	13.5	13.3
	5% WB	MCDBR	18.4	20.8	21.9	23.7	21.0	20.0	17.4	18.5	22.1	24.8	21.6	15.3
		MCWBR	11.3	11.8	12.0	12.7	10.7	9.9	8.3	8.6	10.3	12.1	11.8	10.1
(40) Clear-Sky Solar Irradiance	taub		0.318	0.323	0.325	0.349	0.360	0.347	0.354	0.339	0.345	0.329	0.311	0.312
	taud		2.544	2.538	2.533	2.446	2.430	2.476	2.476	2.507	2.486	2.554	2.571	2.575
	Ebn at Noon		279	291	300	296	292	295	292	295	289	285	279	274
	Edh at Noon		25	28	31	35	36	35	35	33	32	27	24	23
(44) All-Sky Solar Radiation	RadAvg		836	1112	1565	1981	2309	2527	2399	2170	1839	1369	965	737
	RadStd		91	122	129	167	123	88	60	65	56	77	50	91

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.74	N/A	-2.43	N/A	N/A	N/A	N/A	-317	+301	N/A
(47) Regional (40 neighbors)		+0.74	N/A	-2.16	N/A	N/A	N/A	N/A	-229	+270	+67

Nomenclature: See separate page