

SALINAS, CA, USA

WMO: 725930

Lat: 36.664N

Lon: 121.608W

Elev: 23

StdP: 101.05

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23233

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	1.3	2.6	-5.8	2.3	11.0	-3.5	2.8	9.3	12.0	13.3	11.0	12.8	2.3	120	0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	10.0	28.7	16.6	26.1	16.1	24.0	15.9	18.3	25.5	17.5	23.8	16.9	22.5	4.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.9	11.3	19.7	15.1	10.7	19.1	14.5	10.3	18.6	51.5	25.5	49.3	23.8	47.3	22.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.3	8.3	7.6	-1.1	34.7	1.5	2.5	-2.2	36.5	-3.0	38.0	-3.9	39.3	-5.0	41.1
			-2.1	20.7	1.5	1.8	-3.2	22.0	-4.1	23.0	-5.0	24.0	-6.1	25.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.5	11.3	11.7	12.9	13.7	15.0	16.3	17.0	17.6	17.7	16.3	13.5	10.8
	DBStd	3.41	2.83	2.81	2.62	2.58	2.05	1.91	1.54	1.65	2.24	2.71	2.96	2.70
	HDD10.0	65	19	12	5	2	0	0	0	0	0	0	5	23
	HDD18.3	1467	218	186	169	143	107	67	47	34	37	77	149	233
	CDD10.0	1708	59	60	96	112	156	189	218	236	232	194	109	48
	CDD18.3	68	0	1	1	3	4	6	7	12	19	13	3	0
	CDH23.3	628	7	12	22	48	52	65	32	56	148	147	38	2
	CDH26.7	184	1	1	4	16	17	21	5	13	47	51	9	0
Wind	WSAvg	3.5	3.3	3.4	3.3	3.6	4.0	4.2	3.8	3.6	3.2	3.0	3.0	3.3
Precipitation	PrecAvg	314	62	57	52	25	5	2	1	1	5	13	43	51
	PrecMax	602	201	253	152	144	48	14	14	18	31	47	121	130
	PrecMin	162	2	2	0	0	0	0	0	0	0	0	0	1
	PrecStd	114	50	55	37	29	10	3	3	3	9	14	35	34
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.9	25.3	26.1	28.9	28.9	29.5	26.6	28.1	32.0	32.0	27.6	22.2
		MCWB	12.8	14.8	15.3	16.5	17.1	17.4	18.0	18.1	17.9	17.1	15.2	11.6
	2%	DB	20.7	21.5	22.4	23.4	23.8	24.6	23.7	24.4	27.3	27.3	23.3	19.1
		MCWB	12.5	13.7	14.1	14.7	15.7	16.5	17.0	17.3	17.1	15.4	14.0	12.2
	5%	DB	17.9	18.5	19.9	20.5	21.0	22.1	22.1	22.7	24.3	23.9	20.5	17.3
		MCWB	12.4	12.6	13.4	13.8	14.7	15.6	16.4	16.8	16.7	14.8	13.3	12.0
	10%	DB	16.0	16.5	17.8	18.3	19.1	20.4	20.7	21.3	22.3	21.3	18.3	15.6
		MCWB	11.9	12.0	12.7	12.9	13.9	15.0	15.8	16.2	16.1	14.4	13.0	11.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.7	16.8	16.7	17.5	18.3	18.7	18.5	18.9	19.5	18.4	16.9	15.9
		MCDB	18.4	21.8	24.2	25.2	26.2	27.5	25.6	25.9	27.6	25.9	23.1	18.3
	2%	WB	14.3	14.9	15.2	15.7	16.4	16.9	17.3	17.9	18.0	17.1	15.6	14.6
		MCDB	17.1	19.0	20.2	21.6	22.3	23.4	22.9	23.7	24.8	23.7	20.6	16.6
	5%	WB	13.3	13.7	14.1	14.5	15.1	16.0	16.6	17.0	17.2	16.2	14.7	13.4
		MCDB	16.3	17.6	18.2	19.6	20.2	21.2	21.7	22.1	23.0	21.8	18.9	15.5
	10%	WB	12.4	12.6	13.2	13.4	14.2	15.2	15.9	16.4	16.5	15.3	13.8	12.3
		MCDB	15.3	15.8	17.0	17.7	18.5	19.8	20.2	21.1	21.7	19.9	17.4	14.6
Mean Daily Temperature Range	5% DB	MDBR	10.4	10.2	10.8	10.3	8.8	8.6	7.9	8.4	10.0	12.0	11.5	10.4
		MCDBR	13.6	14.0	14.6	14.9	13.5	12.6	10.3	10.9	14.8	17.1	14.8	12.8
		MCWBR	7.5	7.5	7.5	7.6	6.5	6.0	4.8	5.0	6.6	7.8	7.5	7.4
	5% WB	MCDBR	10.2	11.5	12.2	13.2	11.7	11.1	9.7	10.3	12.3	13.8	12.0	8.5
MCWBR		6.3	6.6	6.7	7.1	5.9	5.5	4.6	4.8	5.7	6.7	6.5	5.6	
Clear-Sky Solar Irradiance	taub	0.318	0.323	0.325	0.349	0.360	0.347	0.354	0.339	0.345	0.329	0.311	0.312	
	taud	2.544	2.538	2.533	2.446	2.430	2.476	2.476	2.507	2.486	2.554	2.571	2.575	
	Ebn at Noon	879	918	946	933	922	929	920	931	910	898	881	863	
	Edh at Noon	78	88	97	111	115	110	109	103	100	85	75	71	
All-Sky Solar Radiation	RadAvg	2.64	3.51	4.93	6.24	7.28	7.97	7.56	6.84	5.80	4.32	3.04	2.32	
	RadStd	0.29	0.38	0.41	0.53	0.39	0.28	0.19	0.20	0.18	0.24	0.16	0.29	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.41	N/A	-1.35	N/A	N/A	N/A	N/A	-176	+167
(47) Regional (40 neighbors)		+0.41	N/A	-1.20	N/A	N/A	N/A	N/A	-127	+150

Nomenclature: See separate page