

WOODLEY ISLAND, CA, USA

WMO: 725940

Lat: 40.8097N

Lon: 124.1600W

Elev: 6

StdP: 101.25

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24213

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	0.6	1.9	-2.8	3.0	5.5	-1.1	3.4	4.7	11.7	14.1	10.0	12.2	1.4	90	0.539

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.8	20.5	15.1	19.1	14.9	18.1	14.5	16.4	19.0	15.7	18.1	15.2	17.3	4.2	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.3	10.9	17.3	14.7	10.4	16.7	14.1	10.0	16.1	45.8	19.1	44.0	18.2	42.3	17.4	19.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	8.1	7.3	-1.4	25.8	0.9	2.7	-2.1	27.8	-2.6	29.3	-3.1	30.9	-3.7	32.8		
(5)			-1.9	17.7	0.9	1.0	-2.6	18.4	-3.1	19.0	-3.6	19.6	-4.3	20.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	8.8	8.7	9.2	9.8	11.2	12.7	13.7	14.0	13.3	12.0	10.0	8.5		
	DBStd	3.01	2.84	2.64	2.29	2.11	1.88	1.50	1.44	1.61	2.15	2.36	2.64	3.01		
	HDD10.0	297	57	52	43	27	9	1	0	0	1	8	33	66		
	HDD18.3	2677	296	269	284	254	222	168	143	133	153	198	251	304		
	CDD10.0	663	19	16	18	23	45	82	115	126	98	68	32	21		
	CDD18.3	1	0	0	0	0	0	0	0	0	1	0	0	0		
	CDH23.3	13	0	0	0	1	1	1	1	1	6	3	0	0		
	CDH26.7	2	0	0	0	0	0	0	0	0	2	0	0	0		
(14) Wind	WSAvg	2.7	2.5	2.7	3.1	3.2	3.1	3.0	2.6	2.3	2.2	2.2	2.3	2.7		
(15) Precipitation	PrecAvg	993	163	131	137	81	42	15	4	10	18	61	156	181		
	PrecMax	1707	354	354	284	286	154	78	29	87	85	172	421	592		
	PrecMin	552	17	14	30	9	2	0	0	0	0	1	34	13		
	PrecStd	257	85	70	68	59	31	16	6	17	21	45	97	120		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.8	18.4	18.0	19.6	20.6	19.8	20.0	21.0	23.2	22.5	19.1	17.3		
		MCWB	12.3	12.7	12.0	12.8	15.1	14.8	15.7	16.2	16.2	14.3	13.1	12.7		
	2%	DB	15.8	16.0	15.5	16.3	17.1	17.4	18.3	19.4	20.0	19.3	16.8	15.8		
		MCWB	11.9	12.2	11.7	12.5	13.9	14.0	15.1	15.8	15.7	14.2	13.2	12.5		
	5%	DB	14.5	14.5	14.2	14.4	15.4	16.5	17.3	18.3	18.5	17.5	15.5	14.6		
		MCWB	11.7	11.4	11.1	11.6	12.9	13.6	14.6	15.3	15.0	14.0	12.8	12.0		
	10%	DB	13.4	13.0	13.1	13.4	14.5	15.7	16.5	17.2	17.3	16.3	14.4	13.5		
		MCWB	11.1	10.6	10.7	10.9	12.2	13.1	14.2	14.7	14.5	13.3	12.2	11.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.2	14.4	13.7	14.6	16.2	15.9	16.6	17.1	17.4	16.8	15.2	14.6		
		MCDB	15.5	16.4	15.7	17.6	19.2	18.6	18.8	19.5	21.1	19.0	16.7	15.8		
	2%	WB	13.2	13.2	12.6	12.9	14.3	14.9	15.6	16.3	16.3	15.5	14.3	13.6		
		MCDB	14.7	15.2	14.3	15.2	16.4	16.7	17.6	18.8	18.9	17.8	15.8	14.8		
	5%	WB	12.3	11.9	11.8	12.0	13.2	14.0	14.9	15.5	15.5	14.7	13.5	12.7		
		MCDB	13.9	13.5	13.4	13.8	15.0	15.8	16.9	17.8	17.8	16.8	14.9	14.1		
	10%	WB	11.4	11.0	11.0	11.3	12.4	13.4	14.4	14.9	14.8	13.8	12.6	11.7		
		MCDB	13.0	12.6	12.6	13.1	14.0	15.2	16.2	16.9	16.9	15.7	14.0	13.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.1	6.2	6.0	5.9	5.2	5.4	4.6	4.8	6.4	6.8	6.3	6.2		
		MCDBR	7.3	8.0	7.6	7.9	7.0	6.9	6.2	7.1	9.4	9.4	7.5	6.4		
	5% WB	MCWBR	4.6	4.9	4.6	4.9	4.4	4.2	3.5	4.1	5.2	5.3	4.7	4.2		
		MCWBR	5.2	5.9	6.1	6.7	6.1	6.0	5.7	6.4	7.8	7.2	5.5	4.3		
(40) Clear-Sky Solar Irradiance	taub	taub	0.327	0.334	0.337	0.360	0.365	0.355	0.368	0.355	0.346	0.340	0.321	0.331		
		taud	2.535	2.521	2.531	2.428	2.453	2.492	2.461	2.501	2.503	2.550	2.582	2.521		
	Edn at Noon	Edn at Noon	834	883	918	913	911	918	901	906	895	863	836	796		
		Edh at Noon	73	85	94	111	111	107	109	102	95	82	69	69		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.88	2.70	3.91	5.36	6.55	7.29	7.16	6.19	5.11	3.49	2.15	1.55		
	RadStd	RadStd	0.29	0.38	0.40	0.48	0.42	0.42	0.35	0.31	0.27	0.29	0.23	0.29		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	+0.51	N/A	N/A	N/A	N/A	+118	+5

Nomenclature: See separate page