

CALIFORNIA REDWOOD COAST, CA, USA

WMO: 725945

Lat: 40.978N

Lon: 124.109W

Elev: 61

StdP: 100.59

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24283

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-0.3	0.9	-3.3	2.9	5.3	-1.6	3.3	3.8	11.0	12.4	9.5	11.9	1.6	90	0.555

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.3	21.6	15.2	20.0	15.1	18.7	14.7	16.9	19.5	16.2	18.7	15.5	17.7	4.3	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	11.4	17.6	15.1	10.8	16.8	14.5	10.4	16.3	47.5	19.8	45.2	18.6	43.6	17.8	20.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.0	8.2	7.3	DB	-2.3	27.7	1.1	2.8	-3.1	29.7	-3.8	31.4	-4.4	32.9	-5.3	35.0	(4)
(5)			WB	-2.7	18.4	1.2	1.0	-3.6	19.1	-4.3	19.7	-5.0	20.2	-5.9	21.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	9.0	8.9	9.2	9.8	11.4	12.8	13.9	14.1	13.5	12.1	10.3	8.7
	DBStd	3.07	2.94	2.78	2.33	2.18	2.02	1.61	1.47	1.52	2.13	2.51	2.81	3.04
	HDD10.0	286	54	50	43	28	8	1	0	0	1	8	31	62
	HDD18.3	2625	289	265	283	256	217	166	138	131	145	195	242	298
	CDD10.0	704	23	18	18	23	50	85	120	128	106	72	38	22
	CDD18.3	2	0	0	0	0	1	0	0	0	1	1	0	0
	CDH23.3	34	0	0	0	2	6	2	2	2	11	11	1	0
	CDH26.7	7	0	0	0	0	2	0	0	1	2	3	0	0
Wind	WSAvg	2.7	2.7	2.9	3.1	3.1	3.0	3.0	2.6	2.3	2.2	2.3	2.5	2.9
Precipitation	PrecAvg	1178	200	145	164	101	48	23	5	6	17	68	145	258
	PrecMax	1883	413	383	358	314	130	90	24	18	98	292	407	614
	PrecMin	550	48	17	53	32	1	1	0	0	0	0	30	27
	PrecStd	303	107	85	88	64	37	22	6	5	24	63	83	142
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.9	19.1	18.7	21.0	22.7	21.4	21.2	21.8	24.7	23.9	20.6	18.3
		MCWB	12.2	12.8	12.5	13.6	15.7	15.7	15.9	16.2	16.6	14.5	13.8	12.3
	2%	DB	16.5	16.5	16.1	16.8	17.7	18.3	18.9	19.9	20.8	20.2	17.5	16.3
		MCWB	12.0	11.8	11.9	12.9	14.7	14.4	15.5	16.1	15.8	14.3	13.4	12.3
	5%	DB	14.9	14.7	14.5	14.8	16.0	17.2	17.7	18.6	19.1	18.0	16.1	14.9
		MCWB	11.8	11.6	11.6	11.9	13.3	14.1	14.9	15.6	15.2	13.8	12.8	12.0
	10%	DB	13.7	13.3	13.3	13.6	14.8	16.1	16.9	17.4	17.7	16.6	14.7	13.7
		MCWB	11.4	10.8	10.9	11.2	12.5	13.5	14.5	15.0	14.6	13.4	12.4	11.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.7	14.8	14.3	15.1	17.7	16.4	17.1	17.7	17.9	17.0	15.8	14.7
		MCDB	16.0	17.1	16.1	18.2	19.8	19.7	19.1	19.8	21.8	19.9	17.7	16.1
	2%	WB	13.5	13.4	12.9	13.4	15.0	15.3	16.1	16.7	16.7	15.7	14.7	13.8
		MCDB	15.1	15.2	15.0	15.8	17.4	17.5	18.2	19.0	19.7	18.3	16.3	15.1
	5%	WB	12.5	12.2	12.1	12.4	13.7	14.5	15.3	15.8	15.8	14.8	13.8	12.7
		MCDB	14.1	13.8	13.7	14.2	15.6	16.5	17.2	17.9	18.3	17.2	15.3	14.2
	10%	WB	11.7	11.2	11.3	11.7	12.8	13.9	14.7	15.2	15.1	13.9	12.8	11.8
		MCDB	13.2	12.8	12.9	13.2	14.5	15.6	16.5	17.0	17.2	16.0	14.2	13.2
Mean Daily Temperature Range	5% DB	MDBR	7.9	7.9	7.7	7.4	6.8	6.9	5.9	6.3	8.1	9.0	8.1	8.0
		MCDBR	9.4	9.8	9.3	9.3	9.0	8.8	7.4	8.9	10.9	11.8	9.2	9.1
		MCWBR	5.9	6.0	6.1	6.1	5.9	5.5	4.5	5.4	6.3	6.8	5.7	6.1
	5% WB	MCDBR	7.2	7.9	8.0	8.2	8.0	7.6	6.8	7.7	9.4	9.9	7.4	6.5
		MCWBR	5.2	5.4	5.8	5.7	5.5	5.0	4.3	4.9	5.8	6.4	5.2	5.2
Clear-Sky Solar Irradiance	taub	0.323	0.328	0.333	0.355	0.361	0.352	0.364	0.353	0.342	0.336	0.317	0.325	
	taud	2.544	2.535	2.544	2.442	2.467	2.502	2.473	2.510	2.514	2.562	2.590	2.536	
	Ebn at Noon	838	888	922	917	915	920	905	909	898	867	840	802	
	Edh at Noon	72	84	92	109	109	106	108	101	94	81	68	68	
All-Sky Solar Radiation	RadAvg	1.86	2.69	3.89	5.34	6.55	7.31	7.22	6.24	5.12	3.48	2.13	1.54	
	RadStd	0.29	0.39	0.40	0.49	0.42	0.43	0.35	0.32	0.27	0.30	0.24	0.29	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (15 neighbors)	N/A	N/A	N/A	+0.53	N/A	N/A	N/A	N/A	+112	+14

Nomenclature: See separate page