

CRESCENT CITY DEL NORTE, CA, USA

WMO: 725946

Lat: 41.780N

Lon: 124.237W

Elev: 57

StdP: 14.67

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24286

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	35.0	36.7	23.8	18.0	43.4	27.9	21.9	43.6	34.3	52.5	31.3	52.7	4.6	90	0.596

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	67.7	59.2	65.5	58.8	63.7	57.8	61.4	65.3	60.1	63.8	59.1	62.6	8.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.4	75.9	62.5	58.3	72.8	61.4	57.2	70.0	60.4	27.2	65.3	26.4	63.9	25.7	62.6	68.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	24.5	20.8	31.4	77.6	2.2	4.1	29.8	80.6	28.5	83.0	27.3	85.3	25.7	88.3
			29.2	63.8	2.4	2.0	27.5	65.3	26.1	66.4	24.7	67.6	22.9	69.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.2	48.5	48.3	48.7	49.9	52.5	54.7	56.7	57.6	53.9	50.9	48.0	(6)	
(7)		DBStd	4.98	4.43	4.34	3.61	3.29	3.00	2.58	2.41	2.63	3.24	3.96	4.09	4.54	(7)
(8)		HDD50	413	80	77	68	40	8	1	0	0	0	8	37	94	(8)
(9)		HDD65	4674	510	469	505	454	387	310	256	230	257	345	423	528	(9)
(10)		CDD50	1213	35	28	27	35	86	140	209	235	194	129	64	31	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	13	0	0	0	1	1	2	0	0	3	6	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	8.4	9.1	9.5	9.8	9.3	8.6	8.6	6.9	6.4	6.9	7.5	8.3	9.5	(14)
(15)	Precipitation	PrecAvg	75.0	11.8	9.4	9.3	6.9	3.8	1.7	0.4	0.6	1.1	4.7	10.3	15.0	(15)
(16)		PrecMax	115.6	23.5	21.4	19.1	15.9	8.4	5.7	1.7	2.1	5.4	9.8	25.2	35.0	(16)
(17)		PrecMin	45.2	3.7	2.7	3.8	1.7	0.0	0.1	0.0	0.0	0.4	3.1	4.5	(17)	
(18)		PrecStd	18.0	5.7	5.0	4.3	3.8	2.2	1.5	0.4	0.6	1.3	2.8	5.2	7.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.5	63.8	62.5	66.0	68.1	65.8	67.1	68.6	70.4	73.0	64.6	62.1	(19)
(20)			MCWB	51.3	52.3	52.3	55.2	57.9	59.7	60.4	61.5	60.4	57.2	55.1	52.5	(20)
(21)		2%	DB	59.0	59.0	58.2	59.0	61.5	62.9	64.4	66.2	66.2	65.7	61.1	58.7	(21)
(22)			MCWB	51.4	52.1	52.2	53.1	56.1	57.3	59.0	60.5	59.8	56.1	54.1	53.0	(22)
(23)		5%	DB	56.7	56.5	56.2	56.8	59.2	61.2	63.1	64.3	64.1	62.6	58.9	56.7	(23)
(24)			MCWB	51.5	51.4	51.5	51.9	54.9	56.4	58.2	59.3	58.5	55.8	53.8	52.4	(24)
(25)		10%	DB	55.0	54.6	54.6	55.2	57.3	59.7	61.5	62.9	62.7	60.5	57.1	54.9	(25)
(26)			MCWB	51.2	50.6	50.7	51.1	53.4	55.4	57.2	58.4	57.6	55.5	53.1	51.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.9	56.1	55.4	57.0	59.8	60.5	62.2	62.6	62.6	60.6	58.6	57.3	(27)
(28)			MCD B	58.6	59.9	58.7	63.4	65.0	64.4	65.4	66.3	66.8	65.3	61.1	58.5	(28)
(29)		2%	WB	54.2	54.1	53.8	54.3	57.1	58.4	60.1	61.3	60.8	59.0	56.8	55.4	(29)
(30)			MCD B	56.2	56.9	55.9	57.1	60.9	61.4	63.4	65.0	64.6	62.8	59.0	57.3	(30)
(31)		5%	WB	53.2	52.7	52.7	53.1	55.4	57.2	58.9	60.0	59.5	57.6	55.3	53.8	(31)
(32)			MCD B	55.2	55.3	54.9	55.5	58.8	60.2	62.2	63.7	63.0	61.1	57.4	55.3	(32)
(33)		10%	WB	51.9	51.3	51.4	51.9	54.2	56.1	57.8	58.8	58.4	56.2	54.1	52.3	(33)
(34)			MCD B	54.5	53.6	54.0	54.5	56.8	59.1	61.0	62.3	61.7	59.5	56.2	54.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.1	10.9	10.8	10.4	9.8	10.1	8.9	9.4	11.2	12.0	11.3	11.0	(35)
(36)			MCDBR	13.2	13.3	12.2	12.2	11.9	11.5	10.8	12.0	14.1	16.0	13.4	12.1	(36)
(37)			MCWBR	8.6	8.5	8.7	8.4	8.0	7.7	6.9	7.6	8.8	9.7	8.9	7.9	(37)
(38)		5% WB	MCD BR	9.5	10.3	10.0	10.5	10.6	10.5	10.0	11.5	12.8	13.3	10.0	8.1	(38)
(39)			MCWBR	7.2	7.2	7.6	7.8	7.5	7.3	6.5	7.4	8.4	8.9	7.7	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.321	0.321	0.327	0.352	0.357	0.348	0.353	0.349	0.341	0.330	0.315	0.319	(40)	
(41)		taud	2.560	2.571	2.576	2.462	2.491	2.524	2.516	2.540	2.534	2.589	2.604	2.569	(41)	
(42)		Ebn at Noon	265	284	294	292	291	293	290	289	285	276	266	255	(42)	
(43)		Edh at Noon	22	25	28	34	34	33	33	31	29	24	21	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	554	812	1186	1645	2049	2269	2276	1937	1571	1041	627	456	(44)	
(45)		RadStd	85	115	124	148	123	136	111	114	91	95	73	83	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+4

Nomenclature: See separate page