

SISKIYOU COUNTY AP, CA, USA

WMO: 725955

Lat: 41.781N

Lon: 122.468W

Elev: 2651

StdP: 13.34

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24259

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	16.5	19.5	8.1	9.2	25.1	12.3	11.3	28.0	34.6	45.8	31.5	45.6	1.9	30	0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.3	97.2	63.7	93.9	62.5	90.9	61.5	66.0	91.2	64.4	89.3	63.0	87.5	7.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.6	75.3	72.1	54.4	69.4	72.2	52.5	64.6	71.4	32.0	91.6	30.7	89.4	29.6	87.6	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.6	21.7	18.3	DB	8.7	103.4	7.6	3.0	3.3	105.5	-1.2	107.3	-5.4	109.0	-10.9	111.1	(4)
(5)			WB	7.9	68.9	7.3	2.0	2.6	70.4	-1.7	71.5	-5.8	72.6	-11.1	74.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.4	36.4	39.5	43.8	48.6	56.4	64.3	73.6	71.7	64.2	52.2	41.7	35.3		
	DBStd	14.52	6.07	5.71	5.76	6.68	7.11	7.30	5.39	4.81	6.47	6.46	6.63	7.09		
	HDD50	1817	421	294	204	106	21	2	0	0	2	49	262	456		
	HDD65	5245	885	713	658	491	279	99	6	6	91	397	700	920		
	CDD50	2693	1	1	12	65	219	430	733	674	428	118	11	1		
	CDD65	647	0	0	0	0	12	77	274	216	67	1	0	0		
	CDH74	11191	0	0	1	67	456	1541	4062	3379	1552	133	0	0		
	CDH80	5482	0	0	0	8	140	668	2216	1744	679	27	0	0		
	WSAvg	6.1	5.0	6.2	6.9	6.8	6.8	7.5	6.6	6.1	5.4	5.1	4.8	5.3		
	PrecAvg	19.1	3.1	2.0	2.0	1.5	1.4	0.8	0.4	0.3	0.4	1.3	2.4	3.3		
(15) Precipitation	PrecMax	30.8	6.2	5.0	8.1	3.5	3.7	2.4	1.7	1.4	1.1	4.8	7.8	8.9		
	PrecMin	10.9	0.7	0.9	0.5	0.6	0.4	0.0	0.0	0.0	0.0	0.2	0.4	0.6		
	PrecStd	5.2	1.8	1.1	1.6	0.7	0.9	0.7	0.4	0.3	0.3	1.1	1.6	2.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.9	63.5	71.6	80.8	89.7	97.0	102.1	100.2	94.5	83.7	67.9	55.8		
		MCWB	46.6	49.6	51.9	56.8	60.5	63.6	66.0	64.2	60.7	57.8	52.1	48.1		
	2%	DB	53.0	58.4	66.3	75.0	83.8	91.5	98.4	96.3	90.9	77.8	62.1	52.2		
		MCWB	45.2	46.4	50.0	54.9	59.0	61.7	64.5	63.0	59.8	55.1	49.9	45.7		
	5%	DB	49.7	54.3	62.0	70.0	79.2	87.8	95.1	92.9	88.0	72.8	57.4	49.4		
		MCWB	43.3	44.8	48.2	52.4	57.1	60.2	63.5	61.8	59.1	53.2	47.6	43.7		
	10%	DB	46.5	50.8	57.1	64.3	74.2	83.4	91.4	90.0	83.8	68.3	53.9	46.5		
		MCWB	41.5	42.8	45.8	49.9	55.2	58.9	62.7	61.0	58.0	51.3	45.8	41.7		
	0.4%	WB	48.9	51.0	54.3	58.8	63.1	66.2	68.8	66.9	64.0	59.2	54.4	49.5		
		MCDB	53.8	60.5	67.5	76.6	84.6	91.1	95.1	93.6	89.9	78.2	64.6	54.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	46.1	48.1	51.4	55.6	60.3	63.5	66.9	64.9	61.6	57.2	51.3	46.4		
		MCDB	51.1	56.6	63.5	72.6	80.2	87.6	92.0	90.8	86.0	75.3	59.8	50.8		
	5%	WB	44.0	45.7	49.2	53.1	58.4	61.3	65.2	63.5	59.9	54.6	48.9	44.4		
		MCDB	48.7	52.9	59.5	68.1	76.4	84.2	90.1	89.2	84.4	70.0	56.1	48.5		
	10%	WB	42.0	43.6	46.9	50.5	56.2	59.6	63.8	62.0	58.5	52.3	46.4	42.2		
		MCDB	46.4	50.2	56.2	62.9	72.2	80.8	88.4	86.8	81.8	65.6	52.9	46.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.5	21.5	24.2	26.5	28.8	32.3	35.3	35.9	35.6	30.1	21.3	16.9		
		MCDBR	22.1	27.9	34.2	37.6	38.3	39.0	39.0	39.9	42.1	38.5	27.8	18.0		
		MCWBR	15.2	17.5	19.7	19.8	17.4	15.2	14.4	15.5	18.8	20.3	17.6	12.4		
		MCDBR	18.9	25.3	30.1	35.3	35.4	36.7	36.4	37.1	39.5	34.3	24.5	15.7		
	5% WB	MCWBR	13.4	16.4	17.7	19.3	16.4	14.8	13.7	14.7	18.3	18.6	15.8	11.2		
(40) Clear-Sky Solar Irradiance	taub		0.291	0.295	0.301	0.319	0.326	0.319	0.324	0.320	0.302	0.301	0.286	0.295		
	taud		2.531	2.545	2.554	2.494	2.513	2.566	2.563	2.555	2.592	2.592	2.598	2.516		
	Ebn at Noon		276	293	303	302	301	302	299	298	298	287	277	264		
	Edh at Noon		23	26	29	33	33	31	31	30	27	24	21	21		
(44) All-Sky Solar Radiation	RadAvg		594	879	1245	1706	2139	2485	2552	2254	1777	1167	678	486		
	RadStd		93	111	131	167	169	141	93	95	85	111	80	95		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.86	N/A	N/A	+1.13	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	N/A	N/A	N/A	+0.94	N/A	N/A	N/A	N/A	+176	+32

Nomenclature: See separate page