

SEXTON SUMMIT, OR, USA

WMO: 725975

Lat: 42.600N

Lon: 123.366W

Elev: 1168

StdP: 88.06

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24235

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-5.4	-4.1	-13.9	1.3	5.0	-11.5	1.6	4.9	12.1	4.4	11.3	3.9	3.1	110	0.587

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	29.3	16.4	27.4	15.8	25.8	15.2	17.8	26.9	16.8	25.6	15.9	24.2	1.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	11.6	22.0	13.1	10.8	20.5	12.4	10.3	19.3	54.5	26.8	51.1	25.5	48.5	24.2	21.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	8.9	8.1	-7.5	32.5	2.1	1.9	-9.0	33.9	-10.2	35.0	-11.4	36.1	-12.9	37.5		
(5)			-8.1	19.6	2.3	0.9	-9.7	20.2	-11.0	20.7	-12.3	21.2	-13.9	21.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.2	3.4	3.1	4.1	6.0	10.2	13.5	18.4	15.5	10.0	5.2	2.6			
	DBStd	7.23	4.15	4.11	4.20	4.76	5.01	4.56	3.88	3.96	5.03	4.69	4.37	3.84		
	HDD10.0	1265	207	197	189	140	60	16	1	9	60	156	229			
	HDD18.3	3464	462	427	441	369	256	156	48	49	113	262	394	487		
	CDD10.0	991	4	3	7	21	67	122	259	260	175	59	12	1		
	CDD18.3	148	0	0	0	1	5	12	48	51	29	3	0	0		
	CDH23.3	1024	0	0	0	2	40	97	359	349	168	9	0	0		
	CDH26.7	242	0	0	0	0	7	22	90	88	34	1	0	0		
(14) Wind	WSAvg	3.9	5.0	4.4	4.0	3.5	3.2	3.3	3.4	3.2	3.2	3.8	4.6	5.0		
(15) Precipitation	PrecAvg	937	143	109	104	56	42	22	8	19	31	74	172	156		
	PrecMax	1485	483	263	228	192	184	71	46	107	108	248	612	509		
	PrecMin	377	5	7	7	18	3	0	0	0	0	19	12			
	PrecStd	289	117	66	59	37	43	15	11	27	30	59	123	102		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.5	15.4	17.6	23.0	27.4	29.6	31.9	32.1	29.9	24.5	17.9	13.5		
		MCWB	6.0	8.0	9.7	12.3	14.7	17.2	17.9	16.8	14.8	12.3	9.3	5.1		
	2%	DB	12.8	12.8	14.8	19.3	23.7	26.1	29.1	28.9	27.4	21.4	15.6	11.1		
		MCWB	5.2	6.6	8.2	10.6	13.8	15.6	17.3	16.1	14.1	11.1	8.1	4.1		
	5%	DB	10.8	10.8	12.6	16.4	20.9	23.6	27.1	27.0	25.3	19.2	13.5	9.3		
		MCWB	4.3	5.7	6.9	9.4	12.5	14.4	16.5	15.7	13.6	10.2	7.4	4.2		
	10%	DB	9.2	9.1	10.6	13.6	18.2	21.3	25.2	25.1	23.0	17.1	11.6	8.0		
		MCWB	4.3	4.9	6.1	7.9	11.2	13.4	15.7	15.0	13.0	9.4	6.7	4.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	9.2	10.5	12.9	15.9	18.5	19.5	18.7	16.8	13.8	11.6	8.8		
		MCDB	10.2	12.3	16.2	20.4	25.2	27.1	29.0	28.1	26.0	21.0	14.2	9.1		
	2%	WB	7.6	8.0	9.0	11.2	14.5	16.3	18.1	17.4	15.5	12.6	9.9	7.6		
		MCDB	9.3	10.9	13.3	18.0	22.4	24.8	27.2	26.7	24.0	18.3	12.5	8.1		
	5%	WB	6.3	6.8	7.8	9.8	13.0	15.1	17.1	16.4	14.7	11.5	8.8	6.4		
		MCDB	8.7	9.6	11.3	15.7	19.7	22.5	25.7	25.4	22.8	16.8	11.6	7.5		
	10%	WB	5.3	5.7	6.6	8.4	11.7	13.8	16.2	15.6	13.7	10.4	7.8	5.3		
		MCDB	7.8	8.3	9.7	12.9	17.3	20.5	24.4	23.8	21.5	15.3	10.5	7.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.6	5.1	6.5	8.2	10.0	11.1	11.9	11.4	9.3	7.1	5.0	4.4		
		MCDBR	6.4	7.5	9.3	11.8	12.4	12.8	12.3	11.9	10.6	8.9	7.0	6.0		
	5% WB	MCWBR	3.6	4.4	5.9	6.7	6.6	6.1	5.5	5.0	4.9	3.8	3.6			
		MCWBR	5.0	6.1	8.3	11.1	12.0	12.5	12.0	11.6	10.0	8.2	6.0	5.0		
(40) Clear-Sky Solar Irradiance	taub		0.269	0.270	0.273	0.289	0.295	0.294	0.297	0.295	0.283	0.279	0.266	0.273		
		taud	2.650	2.662	2.679	2.599	2.614	2.635	2.633	2.639	2.658	2.668	2.671	2.629		
	Ebn at Noon		904	956	987	984	979	975	969	965	961	931	899	864		
		Edh at Noon	62	71	79	92	94	92	91	88	80	70	60	58		
(44) All-Sky Solar Radiation	RadAvg		1.66	2.49	3.59	4.97	6.39	7.29	7.83	6.81	5.24	3.31	1.83	1.32		
	RadStd		0.23	0.35	0.39	0.46	0.52	0.47	0.30	0.33	0.34	0.33	0.22	0.23		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+94	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+4

Nomenclature: See separate page